



# Cleveland Elementary School Lead in Water Test Results

## FY23 Filter Test

Less than 5ppb - Devices requiring no remediation

| Record ID  | Filter Installed Date | Filter Expiration Date | Floor        | Device Type    | Device Location                                  | Water Filter's Name | Date Analyzed | 1st Draw - Sample ID      | FT Final Result - 1st Draw (ppb) | 2nd Draw - Sample ID      | FT Final Result - 2nd Draw (ppb) |
|------------|-----------------------|------------------------|--------------|----------------|--|---------------------|---------------|---------------------------|----------------------------------|---------------------------|----------------------------------|
| WS- 003992 | 3/7/2022              | 3/7/2023               | Ground Floor | Health Suite   | In health suite G07 in unisex restroom           | WF-03072022-003992  | 1/21/2023     | FT-FY23-12292022-003992-A | <1                               | FT-FY23-12292022-003992-B | <1                               |
| WS- 003993 | 3/7/2022              | 3/7/2023               | Ground Floor | Cooler         | In hallway adjacent to room G31 High Left        | WF-03072022-003993  | 1/21/2023     | FT-FY23-12292022-003993-A | <1                               | FT-FY23-12292022-003993-B | <1                               |
| WS- 003994 | 3/7/2022              | 3/7/2023               | Ground Floor | Cooler         | In hallway adjacent to room G32 Low Right        | WF-03072022-003994  | 1/21/2023     | FT-FY23-12292022-003994-A | <1                               | FT-FY23-12292022-003994-B | <1                               |
| WS- 003999 | 3/7/2022              | 3/7/2023               | 1            | Cooler         | In hallway adjacent to south stairwell High Left | WF-03072022-003999  | 1/21/2023     | FT-FY23-12292022-003999-A | <1                               | FT-FY23-12292022-003999-B | <1                               |
| WS- 004000 | 3/7/2022              | 3/7/2023               | 1            | Cooler         | In hallway adjacent to south stairwell Low Right | WF-03072022-004000  | 1/21/2023     | FT-FY23-12292022-004000-A | <1                               | FT-FY23-12292022-004000-B | <1                               |
| WS- 004002 | 8/15/2022             | 8/15/2023              | 1            | Combo Faucet   | In classroom 111                                 | WF-08152022-004002  | 1/21/2023     | FT-FY23-12292022-004002-A | <1                               | FT-FY23-12292022-004002-B | <1                               |
| WS- 004004 | 3/7/2022              | 3/7/2023               | 1            | Combo Fountain | In classroom 111                                 | WF-03072022-004004  | 1/21/2023     | FT-FY23-12292022-004004-A | <1                               | FT-FY23-12292022-004004-B | <1                               |
| WS- 004005 | 8/15/2022             | 8/15/2023              | 1            | Combo Faucet   | In classroom 115                                 | WF-08152022-004005  | 1/21/2023     | FT-FY23-12292022-004005-A | <1                               | FT-FY23-12292022-004005-B | <1                               |
| WS- 004006 | 3/7/2022              | 3/7/2023               | 1            | Combo Fountain | In classroom 115                                 | WF-03072022-004006  | 1/21/2023     | FT-FY23-12292022-004006-A | <1                               | FT-FY23-12292022-004006-B | <1                               |
| WS- 004007 | 8/15/2022             | 8/15/2023              | 1            | Combo Faucet   | In classroom 117                                 | WF-08152022-004007  | 1/21/2023     | FT-FY23-12292022-004007-A | <1                               | FT-FY23-12292022-004007-B | <1                               |
| WS- 004008 | 3/7/2022              | 3/7/2023               | 1            | Combo Fountain | In classroom 117                                 | WF-03072022-004008  | 1/21/2023     | FT-FY23-12292022-004008-A | <1                               | FT-FY23-12292022-004008-B | <1                               |
| WS- 004009 | 8/15/2022             | 8/15/2023              | 1            | Combo Faucet   | In classroom 120                                 | WF-08152022-004009  | 1/21/2023     | FT-FY23-12292022-004009-A | <1                               | FT-FY23-12292022-004009-B | <1                               |
| WS- 004010 | 3/7/2022              | 3/7/2023               | 1            | Combo Fountain | In classroom 120                                 | WF-03072022-004010  | 1/21/2023     | FT-FY23-12292022-004010-A | <1                               | FT-FY23-12292022-004010-B | <1                               |
| WS- 004011 | 3/7/2022              | 3/7/2023               | 2            | Cooler         | In hallway adjacent to south stairwell High Left | WF-03072022-004011  | 1/21/2023     | FT-FY23-12292022-004011-A | <1                               | FT-FY23-12292022-004011-B | <1                               |
| WS- 004012 | 8/15/2022             | 8/15/2023              | 1            | Combo Faucet   | In classroom 101                                 | WF-08152022-004012  | 1/21/2023     | FT-FY23-12292022-004012-A | <1                               | FT-FY23-12292022-004012-B | <1                               |
| WS- 004013 | 3/7/2022              | 3/7/2023               | 1            | Combo Fountain | In classroom 101                                 | WF-03072022-004013  | 1/21/2023     | FT-FY23-12292022-004013-A | <1                               | FT-FY23-12292022-004013-B | <1                               |
| WS- 004014 | 3/7/2022              | 3/7/2023               | 2            | Cooler         | In hallway adjacent to south stairwell Low Right | WF-03072022-004014  | 1/21/2023     | FT-FY23-12292022-004014-A | <1                               | FT-FY23-12292022-004014-B | <1                               |
| WS- 004015 | 8/15/2022             | 8/15/2023              | 2            | Combo Faucet   | In classroom 207                                 | WF-08152022-004015  | 1/21/2023     | FT-FY23-12292022-004015-A | <1                               | FT-FY23-12292022-004015-B | <1                               |
| WS- 004016 | 3/7/2022              | 3/7/2023               | 2            | Combo Fountain | In classroom 207                                 | WF-03072022-004016  | 1/21/2023     | FT-FY23-12292022-004016-A | <1                               | FT-FY23-12292022-004016-B | <1                               |
| WS- 004017 | 8/15/2022             | 8/15/2023              | 2            | Combo Faucet   | In classroom 212                                 | WF-08152022-004017  | 1/21/2023     | FT-FY23-12292022-004017-A | <1                               | FT-FY23-12292022-004017-B | <1                               |
| WS- 004018 | 3/7/2022              | 3/7/2023               | 2            | Combo Fountain | In classroom 212                                 | WF-03072022-004018  | 1/21/2023     | FT-FY23-12292022-004018-A | <1                               | FT-FY23-12292022-004018-B | <1                               |
| WS- 004019 | 8/15/2022             | 8/15/2023              | 2            | Combo Faucet   | In classroom 216 Left                            | WF-08152022-004019  | 1/21/2023     | FT-FY23-12292022-004019-A | <1                               | FT-FY23-12292022-004019-B | <1                               |
| WS- 004020 | 3/7/2022              | 3/7/2023               | 2            | Combo Fountain | In classroom 216 Left                            | WF-03072022-004020  | 1/21/2023     | FT-FY23-12292022-004020-A | <1                               | FT-FY23-12292022-004020-B | <1                               |
| WS- 004021 | 8/15/2022             | 8/15/2023              | 2            | Combo Faucet   | In classroom 216 Right                           | WF-08152022-004021  | 1/21/2023     | FT-FY23-12292022-004021-A | <1                               | FT-FY23-12292022-004021-B | <1                               |
| WS- 004022 | 3/7/2022              | 3/7/2023               | 2            | Combo Fountain | In classroom 216 Right                           | WF-03072022-004022  | 1/21/2023     | FT-FY23-12292022-004022-A | <1                               | FT-FY23-12292022-004022-B | <1                               |
| WS- 004023 | 8/15/2022             | 8/15/2023              | 2            | Combo Faucet   | In classroom 218                                 | WF-08152022-004023  | 1/21/2023     | FT-FY23-12292022-004023-A | <1                               | FT-FY23-12292022-004023-B | <1                               |
| WS- 004024 | 3/7/2022              | 3/7/2023               | 2            | Combo Fountain | In classroom 218                                 | WF-03072022-004024  | 1/21/2023     | FT-FY23-12292022-004024-A | <1                               | FT-FY23-12292022-004024-B | <1                               |
| WS- 004025 | 8/15/2022             | 8/15/2023              | 2            | Combo Faucet   | In classroom 201                                 | WF-08152022-004025  | 1/21/2023     | FT-FY23-12292022-004025-A | <1                               | FT-FY23-12292022-004025-B | <1                               |
| WS- 004026 | 3/7/2022              | 3/7/2023               | 2            | Combo Fountain | In classroom 201                                 | WF-03072022-004026  | 1/21/2023     | FT-FY23-12292022-004026-A | <1                               | FT-FY23-12292022-004026-B | <1                               |
| WS- 004027 | 8/15/2022             | 8/15/2023              | 2            | Combo Faucet   | In classroom 203                                 | WF-08152022-004027  | 1/21/2023     | FT-FY23-12292022-004027-A | <1                               | FT-FY23-12292022-004027-B | <1                               |
| WS- 004028 | 3/7/2022              | 3/7/2023               | 2            | Combo Fountain | In classroom 203                                 | WF-03072022-004028  | 1/21/2023     | FT-FY23-12292022-004028-A | <1                               | FT-FY23-12292022-004028-B | <1                               |
| WS- 004029 | 3/7/2022              | 3/7/2023               | 3            | Cooler         | In hallway adjacent to south stairwell High Left | WF-03072022-004029  | 1/21/2023     | FT-FY23-12292022-004029-A | <1                               | FT-FY23-12292022-004029-B | <1                               |
| WS- 004030 | 3/7/2022              | 3/7/2023               | 3            | Cooler         | In hallway adjacent to south stairwell Low Right | WF-03072022-004030  | 1/21/2023     | FT-FY23-12292022-004030-A | <1                               | FT-FY23-12292022-004030-B | <1                               |
| WS- 004034 | 8/15/2022             | 8/15/2023              | 3            | Combo Faucet   | In classroom 304                                 | WF-08152022-004034  | 1/21/2023     | FT-FY23-12292022-004034-A | <1                               | FT-FY23-12292022-004034-B | <1                               |
| WS- 004035 | 3/7/2022              | 3/7/2023               | 3            | Combo Fountain | In classroom 304                                 | WF-03072022-004035  | 1/21/2023     | FT-FY23-12292022-004035-A | <1                               | FT-FY23-12292022-004035-B | <1                               |

|            |           |           |   |                |                              |       |                    |           |                           |    |                           |    |
|------------|-----------|-----------|---|----------------|------------------------------|-------|--------------------|-----------|---------------------------|----|---------------------------|----|
| WS- 004036 | 8/15/2022 | 8/15/2023 | 3 | Combo Faucet   | In classroom 308             |       | WF-08152022-004036 | 1/21/2023 | FT-FY23-12292022-004036-A | <1 | FT-FY23-12292022-004036-B | <1 |
| WS- 004039 | 3/7/2022  | 3/7/2023  | 3 | Combo Fountain | In staff lounge 313          |       | WF-03072022-004039 | 1/21/2023 | FT-FY23-12292022-004039-A | <1 | FT-FY23-12292022-004039-B | <1 |
| WS- 004040 | 8/15/2022 | 8/15/2023 | 3 | Combo Faucet   | In classroom 302             |       | WF-08152022-004040 | 1/21/2023 | FT-FY23-12292022-004040-A | <1 | FT-FY23-12292022-004040-B | <1 |
| WS- 004041 | 3/7/2022  | 3/7/2023  | 3 | Combo Fountain | In classroom 302             |       | WF-03072022-004041 | 1/21/2023 | FT-FY23-12292022-004041-A | <1 | FT-FY23-12292022-004041-B | <1 |
| WS- 004042 | 8/15/2022 | 8/15/2023 | 3 | Combo Faucet   | In classroom 301             |       | WF-08152022-004042 | 1/21/2023 | FT-FY23-12292022-004042-A | <1 | FT-FY23-12292022-004042-B | <1 |
| WS- 004043 | 3/7/2022  | 3/7/2023  | 3 | Combo Fountain | In classroom 301             |       | WF-03072022-004043 | 1/21/2023 | FT-FY23-12292022-004043-A | <1 | FT-FY23-12292022-004043-B | <1 |
| WS- 004044 | 8/15/2022 | 8/15/2023 | 3 | Combo Faucet   | In classroom 315             |       | WF-08152022-004044 | 1/21/2023 | FT-FY23-12292022-004044-A | <1 | FT-FY23-12292022-004044-B | <1 |
| WS- 004045 | 3/7/2022  | 3/7/2023  | 3 | Combo Fountain | In classroom 315             |       | WF-03072022-004045 | 1/21/2023 | FT-FY23-12292022-004045-A | <1 | FT-FY23-12292022-004045-B | <1 |
| WS- 004046 | 8/15/2022 | 8/15/2023 | 1 | Combo Faucet   | In classroom 103             |       | WF-08152022-004046 | 1/21/2023 | FT-FY23-12292022-004046-A | <1 | FT-FY23-12292022-004046-B | <1 |
| WS- 004047 | 3/7/2022  | 3/7/2023  | 1 | Combo Fountain | In classroom 103             |       | WF-03072022-004047 | 1/21/2023 | FT-FY23-12292022-004047-A | <1 | FT-FY23-12292022-004047-B | <1 |
| WS- 004048 | 8/15/2022 | 8/15/2023 | 2 | Combo Faucet   | In classroom 216             | Left  | WF-08152022-004048 | 1/21/2023 | FT-FY23-12292022-004048-A | <1 | FT-FY23-12292022-004048-B | <1 |
| WS- 004049 | 3/7/2022  | 3/7/2023  | 2 | Combo Fountain | In classroom 216             | Left  | WF-03072022-004049 | 1/21/2023 | FT-FY23-12292022-004049-A | <1 | FT-FY23-12292022-004049-B | <1 |
| WS- 004050 | 8/15/2022 | 8/15/2023 | 2 | Combo Faucet   | In classroom 216             | Right | WF-08152022-004050 | 1/21/2023 | FT-FY23-12292022-004050-A | <1 | FT-FY23-12292022-004050-B | <1 |
| WS- 004051 | 3/7/2022  | 3/7/2023  | 2 | Combo Fountain | In classroom 216             | Right | WF-03072022-004051 | 1/21/2023 | FT-FY23-12292022-004051-A | <1 | FT-FY23-12292022-004051-B | <1 |
| WS- 004269 | 8/15/2022 | 8/15/2023 | 1 | Bathroom       | In classroom 101 in bathroom |       | WF-08152022-004269 | 1/21/2023 | FT-FY23-12292022-004269-A | <1 | FT-FY23-12292022-004269-B | <1 |
| WS- 004270 | 8/15/2022 | 8/15/2023 | 1 | Bathroom       | In classroom 103 in bathroom |       | WF-08152022-004270 | 1/21/2023 | FT-FY23-12292022-004270-A | <1 | FT-FY23-12292022-004270-B | <1 |
| WS- 004271 | 8/15/2022 | 8/15/2023 | 1 | Bathroom       | In classroom 106 in bathroom |       | WF-08152022-004271 | 1/21/2023 | FT-FY23-12292022-004271-A | <1 | FT-FY23-12292022-004271-B | <1 |
| WS- 004272 | 8/15/2022 | 8/15/2023 | 1 | Bathroom       | In classroom 111 in bathroom |       | WF-08152022-004272 | 1/21/2023 | FT-FY23-12292022-004272-A | <1 | FT-FY23-12292022-004272-B | <1 |
| WS- 004273 | 8/15/2022 | 8/15/2023 | 1 | Bathroom       | In classroom 115 in bathroom |       | WF-08152022-004273 | 1/21/2023 | FT-FY23-12292022-004273-A | <1 | FT-FY23-12292022-004273-B | <1 |
| WS- 004274 | 8/15/2022 | 8/15/2023 | 1 | Bathroom       | In classroom 117 in bathroom |       | WF-08152022-004274 | 1/21/2023 | FT-FY23-12292022-004274-A | <1 | FT-FY23-12292022-004274-B | <1 |
| WS- 004275 | 8/15/2022 | 8/15/2023 | 1 | Bathroom       | In classroom 120 in bathroom |       | WF-08152022-004275 | 1/21/2023 | FT-FY23-12292022-004275-A | <1 | FT-FY23-12292022-004275-B | <1 |

### Food Prep Sink

| Less than 5ppb - Devices requiring no remediation |                       |                        |              |                |                      |                     |                    |                      |                                  |                      |                                  |    |
|---|-----------------------|------------------------|--------------|----------------|----------------------|---------------------|--------------------|----------------------|----------------------------------|----------------------|----------------------------------|----|
| Record ID   | Filter Installed Date | Filter Expiration Date | Floor        | Device Type    | Device Location      | Water Filter's Name | Date Analyzed      | 1st Draw - Sample ID | FT Final Result - 1st Draw (ppb) | 2nd Draw - Sample ID | FT Final Result - 2nd Draw (ppb) |    |
| WS- 003997  | 2/16/2022             | 2/16/2023              | Ground Floor | Food Prep Sink | In kitchen east wall | Right               | WF-02162022-003997 | 1/21/2023            | FT-FY23-12292022-003997-A        | <1                   | FT-FY23-12292022-003997-B        | <1 |