



Cleveland ES Lead in Water Test Results



FY20 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 003992	4/3/2019	4/3/2020	Ground Floor	Health Suite	In health suite G07 in unisex restroom	WF-04032019-003992	11/24/2019	FT-FY20-112019-003992-A	<1	FT-FY20-112019-003992-B	<1
WS- 003993	4/3/2019	4/3/2020	Ground Floor	Cooler	In hallway adjacent to room G31 High Left	WF-04032019-003993	11/24/2019	FT-FY20-112019-003993-A	<1	FT-FY20-112019-003993-B	<1
WS- 003994	4/3/2019	4/3/2020	Ground Floor	Cooler	In hallway adjacent to room G32 Low Right	WF-04032019-003994	11/24/2019	FT-FY20-112019-003994-A	<1	FT-FY20-112019-003994-B	<1
WS- 003998	4/3/2019	4/3/2020	Ground Floor	Break Room	In conference room G17	WF-04032019-003998	11/24/2019	FT-FY20-112019-003998-A	<1	FT-FY20-112019-003998-B	<1
WS- 003999	4/3/2019	4/3/2020	1	Cooler	In hallway adjacent to south stairwell High Left	WF-04032019-003999	11/24/2019	FT-FY20-112019-003999-A	<1	FT-FY20-112019-003999-B	<1
WS- 004000	4/3/2019	4/3/2020	1	Cooler	In hallway adjacent to south stairwell Low Right	WF-04032019-004000	11/24/2019	FT-FY20-112019-004000-A	<1	FT-FY20-112019-004000-B	<1
WS- 004001	4/3/2019	4/3/2020	1	Combo Fountain	In classroom 106	WF-04032019-004001	11/24/2019	FT-FY20-112019-004001-A	<1	FT-FY20-112019-004001-B	<1
WS- 004002	9/9/2019	9/9/2020	1	Combo Faucet	In classroom 111	WF-09092019-004002	11/24/2019	FT-FY20-112019-004002-A	1.9	FT-FY20-112019-004002-B	<1
WS- 004003	9/9/2019	9/9/2020	1	Combo Faucet	In classroom 106	WF-09092019-004003	11/24/2019	FT-FY20-112019-004003-A	<1	FT-FY20-112019-004003-B	<1
WS- 004004	4/3/2019	4/3/2020	1	Combo Fountain	In classroom 111	WF-04032019-004004	11/24/2019	FT-FY20-112019-004004-A	<1	FT-FY20-112019-004004-B	<1
WS- 004005	9/9/2019	9/9/2020	1	Combo Faucet	In classroom 115	WF-09092019-004005	11/24/2019	FT-FY20-112019-004005-A	<1	FT-FY20-112019-004005-B	<1
WS- 004006	4/3/2019	4/3/2020	1	Combo Fountain	In classroom 115	WF-04032019-004006	11/24/2019	FT-FY20-112019-004006-A	<1	FT-FY20-112019-004006-B	<1
WS- 004007	9/9/2019	9/9/2020	1	Combo Faucet	In classroom 117	WF-09092019-004007	11/24/2019	FT-FY20-112019-004007-A	<1	FT-FY20-112019-004007-B	<1
WS- 004008	4/3/2019	4/3/2020	1	Combo Fountain	In classroom 117	WF-04032019-004008	11/24/2019	FT-FY20-112019-004008-A	<1	FT-FY20-112019-004008-B	<1
WS- 004009	9/9/2019	9/9/2020	1	Combo Faucet	In classroom 120	WF-09092019-004009	11/24/2019	FT-FY20-112019-004009-A	<1	FT-FY20-112019-004009-B	<1
WS- 004010	4/3/2019	4/3/2020	1	Combo Fountain	In classroom 120	WF-04032019-004010	11/24/2019	FT-FY20-112019-004010-A	<1	FT-FY20-112019-004010-B	<1
WS- 004011	4/3/2019	4/3/2020	2	Cooler	In hallway adjacent to south stairwell High Left	WF-04032019-004011	11/24/2019	FT-FY20-112019-004011-A	<1	FT-FY20-112019-004011-B	<1
WS- 004012	9/9/2019	9/9/2020	1	Combo Faucet	In classroom 101	WF-09092019-004012	11/24/2019	FT-FY20-112019-004012-A	<1	FT-FY20-112019-004012-B	<1
WS- 004013	4/3/2019	4/3/2020	1	Combo Fountain	In classroom 101	WF-04032019-004013	11/24/2019	FT-FY20-112019-004013-A	<1	FT-FY20-112019-004013-B	<1
WS- 004014	4/3/2019	4/3/2020	2	Cooler	In hallway adjacent to south stairwell Low Right	WF-04032019-004014	11/24/2019	FT-FY20-112019-004014-A	<1	FT-FY20-112019-004014-B	<1
WS- 004015	9/9/2019	9/9/2020	2	Combo Faucet	In classroom 207	WF-09092019-004015	11/24/2019	FT-FY20-112019-004015-A	1.5	FT-FY20-112019-004015-B	<1
WS- 004016	4/3/2019	4/3/2020	2	Combo Fountain	In classroom 207	WF-04032019-004016	11/24/2019	FT-FY20-112019-004016-A	<1	FT-FY20-112019-004016-B	<1
WS- 004017	9/9/2019	9/9/2020	2	Combo Faucet	In classroom 212	WF-09092019-004017	11/24/2019	FT-FY20-112019-004017-A	<1	FT-FY20-112019-004017-B	<1
WS- 004018	4/3/2019	4/3/2020	2	Combo Fountain	In classroom 212	WF-04032019-004018	11/24/2019	FT-FY20-112019-004018-A	<1	FT-FY20-112019-004018-B	<1
WS- 004019	9/9/2019	9/9/2020	2	Combo Faucet	In classroom 216 Left	WF-09092019-004019	11/24/2019	FT-FY20-112019-004019-A	<1	FT-FY20-112019-004019-B	<1
WS- 004020	4/3/2019	4/3/2020	2	Combo Fountain	In classroom 216 Left	WF-04032019-004020	11/24/2019	FT-FY20-112019-004020-A	<1	FT-FY20-112019-004020-B	<1
WS- 004021	9/9/2019	9/9/2020	2	Combo Faucet	In classroom 216 Right	WF-09092019-004021	11/24/2019	FT-FY20-112019-004021-A	<1	FT-FY20-112019-004021-B	<1
WS- 004022	4/3/2019	4/3/2020	2	Combo Fountain	In classroom 216 Right	WF-04032019-004022	11/24/2019	FT-FY20-112019-004022-A	<1	FT-FY20-112019-004022-B	<1
WS- 004023	9/9/2019	9/9/2020	2	Combo Faucet	In classroom 218	WF-09092019-004023	11/24/2019	FT-FY20-112019-004023-A	<1	FT-FY20-112019-004023-B	<1
WS- 004024	4/3/2019	4/3/2020	2	Combo Fountain	In classroom 218	WF-04032019-004024	11/24/2019	FT-FY20-112019-004024-A	<1	FT-FY20-112019-004024-B	<1

WS- 004025	9/9/2019	9/9/2020	2	Combo Faucet	In classroom 201		WF-09092019-004025	11/24/2019	FT-FY20-112019-004025-A	2.4	FT-FY20-112019-004025-B	<1
WS- 004026	4/3/2019	4/3/2020	2	Combo Fountain	In classroom 201		WF-04032019-004026	11/24/2019	FT-FY20-112019-004026-A	<1	FT-FY20-112019-004026-B	<1
WS- 004027	9/9/2019	9/9/2020	2	Combo Faucet	In classroom 203		WF-09092019-004027	11/24/2019	FT-FY20-112019-004027-A	<1	FT-FY20-112019-004027-B	<1
WS- 004028	4/3/2019	4/3/2020	2	Combo Fountain	In classroom 203		WF-04032019-004028	11/24/2019	FT-FY20-112019-004028-A	1.3	FT-FY20-112019-004028-B	<1
WS- 004029	4/3/2019	4/3/2020	3	Cooler	In hallway adjacent to south stairwell	High Left	WF-04032019-004029	11/24/2019	FT-FY20-112019-004029-A	<1	FT-FY20-112019-004029-B	<1
WS- 004030	4/3/2019	4/3/2020	3	Cooler	In hallway adjacent to south stairwell	Low Right	WF-04032019-004030	11/24/2019	FT-FY20-112019-004030-A	<1	FT-FY20-112019-004030-B	<1
WS- 004034	9/9/2019	9/9/2020	3	Combo Faucet	In classroom 304		WF-09092019-004034	11/24/2019	FT-FY20-112019-004034-A	1.9	FT-FY20-112019-004034-B	<1
WS- 004035	4/3/2019	4/3/2020	3	Combo Fountain	In classroom 304		WF-04032019-004035	11/24/2019	FT-FY20-112019-004035-A	<1	FT-FY20-112019-004035-B	<1
WS- 004036	9/9/2019	9/9/2020	3	Combo Faucet	In classroom 308		WF-09092019-004036	11/24/2019	FT-FY20-112019-004036-A	<1	FT-FY20-112019-004036-B	<1
WS- 004037	4/3/2019	4/3/2020	3	Combo Fountain	In classroom 308		WF-04032019-004037	11/24/2019	FT-FY20-112019-004037-A	<1	FT-FY20-112019-004037-B	<1
WS- 004038	4/3/2019	4/3/2020	3	Break Room	In staff lounge 313		WF-04032019-004038	11/24/2019	FT-FY20-112019-004038-A	<1	FT-FY20-112019-004038-B	<1
WS- 004039	4/3/2019	4/3/2020	3	Combo Fountain	In staff lounge 313		WF-04032019-004039	11/24/2019	FT-FY20-112019-004039-A	<1	FT-FY20-112019-004039-B	<1
WS- 004040	9/9/2019	9/9/2020	3	Combo Faucet	In classroom 302		WF-09092019-004040	11/24/2019	FT-FY20-112019-004040-A	1.2	FT-FY20-112019-004040-B	<1
WS- 004041	4/3/2019	4/3/2020	3	Combo Fountain	In classroom 302		WF-04032019-004041	11/24/2019	FT-FY20-112019-004041-A	<1	FT-FY20-112019-004041-B	<1
WS- 004042	9/9/2019	9/9/2020	3	Combo Faucet	In classroom 301		WF-09092019-004042	11/24/2019	FT-FY20-112019-004042-A	<1	FT-FY20-112019-004042-B	<1
WS- 004043	4/3/2019	4/3/2020	3	Combo Fountain	In classroom 301		WF-04032019-004043	11/24/2019	FT-FY20-112019-004043-A	<1	FT-FY20-112019-004043-B	<1
WS- 004044	9/9/2019	9/9/2020	3	Combo Faucet	In classroom 315		WF-09092019-004044	11/24/2019	FT-FY20-112019-004044-A	<1	FT-FY20-112019-004044-B	<1
WS- 004045	4/3/2019	4/3/2020	3	Combo Fountain	In classroom 315		WF-04032019-004045	11/24/2019	FT-FY20-112019-004045-A	<1	FT-FY20-112019-004045-B	<1
WS- 004046	9/9/2019	9/9/2020	1	Combo Faucet	In classroom 103		WF-09092019-004046	11/24/2019	FT-FY20-112019-004046-A	<1	FT-FY20-112019-004046-B	<1
WS- 004047	4/3/2019	4/3/2020	1	Combo Fountain	In classroom 103		WF-04032019-004047	11/24/2019	FT-FY20-112019-004047-A	<1	FT-FY20-112019-004047-B	<1
WS- 004048	9/9/2019	9/9/2020	2	Combo Faucet	In classroom 216	Left	WF-09092019-004048	11/24/2019	FT-FY20-112019-004048-A	1.5	FT-FY20-112019-004048-B	<1
WS- 004049	4/3/2019	4/3/2020	2	Combo Fountain	In classroom 216	Left	WF-04032019-004049	11/24/2019	FT-FY20-112019-004049-A	<1	FT-FY20-112019-004049-B	<1
WS- 004050	9/9/2019	9/9/2020	2	Combo Faucet	In classroom 216	Right	WF-09092019-004050	11/24/2019	FT-FY20-112019-004050-A	1.9	FT-FY20-112019-004050-B	<1
WS- 004051	4/3/2019	4/3/2020	2	Combo Fountain	In classroom 216	Right	WF-04032019-004051	11/24/2019	FT-FY20-112019-004051-A	<1	FT-FY20-112019-004051-B	<1
WS- 004269	9/9/2019	9/9/2020	1	Bathroom	In classroom 101 in bathroom		WF-09092019-004269	11/24/2019	FT-FY20-112019-004269-A	<1	FT-FY20-112019-004269-B	<1
WS- 004270	9/9/2019	9/9/2020	1	Bathroom	In classroom 103 in bathroom		WF-09092019-004270	11/24/2019	FT-FY20-112019-004270-A	<1	FT-FY20-112019-004270-B	<1
WS- 004271	9/9/2019	9/9/2020	1	Bathroom	In classroom 106 in bathroom		WF-09092019-004271	11/24/2019	FT-FY20-112019-004271-A	<1	FT-FY20-112019-004271-B	<1
WS- 004272	9/9/2019	9/9/2020	1	Bathroom	In classroom 111 in bathroom		WF-09092019-004272	11/24/2019	FT-FY20-112019-004272-A	<1	FT-FY20-112019-004272-B	<1
WS- 004273	9/9/2019	9/9/2020	1	Bathroom	In classroom 115 in bathroom		WF-09092019-004273	11/24/2019	FT-FY20-112019-004273-A	<1	FT-FY20-112019-004273-B	<1
WS- 004274	9/9/2019	9/9/2020	1	Bathroom	In classroom 117 in bathroom		WF-09092019-004274	11/24/2019	FT-FY20-112019-004274-A	<1	FT-FY20-112019-004274-B	<1
WS- 004275	9/9/2019	9/9/2020	1	Bathroom	In classroom 120 in bathroom		WF-09092019-004275	11/24/2019	FT-FY20-112019-004275-A	<1	FT-FY20-112019-004275-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation													
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)		
WS- 003997	6/26/2019	6/26/2020	Ground Floor	Food Prep Sink	In kitchen east wall		Right	WF-06262019-003997	11/24/2019	FT-FY20-112019-003997-A	<1	FT-FY20-112019-003997-B	<1