



# Cleveland Elementary School Lead in Water Test Results

## FY22 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-003992	3/15/2021	3/15/2022	Ground Floor	Health Suite	In health suite G07 in unisex restroom	WF-03152021-003992	11/18/2021	FT-FY22-11022021-003992-A	<1	FT-FY22-11022021-003992-B	<1
WS-003993	3/15/2021	3/15/2022	Ground Floor	Cooler	In hallway adjacent to room G31 High Left	WF-03152021-003993	11/18/2021	FT-FY22-11022021-003993-A	<1	FT-FY22-11022021-003993-B	<1
WS-003994	3/15/2021	3/15/2022	Ground Floor	Cooler	In hallway adjacent to room G32 Low Right	WF-03152021-003994	11/18/2021	FT-FY22-11022021-003994-A	<1	FT-FY22-11022021-003994-B	<1
WS-003998	3/15/2021	3/15/2022	Ground Floor	Break Room	In conference room G17	WF-03152021-003998	11/18/2021	FT-FY22-11022021-003998-A	<1	FT-FY22-11022021-003998-B	<1
WS-004001	3/15/2021	3/15/2022	1	Combo Fountain	In classroom 106	WF-03152021-004001	11/18/2021	FT-FY22-11022021-004001-A	<1	FT-FY22-11022021-004001-B	<1
WS-004002	8/24/2021	8/24/2022	1	Combo Faucet	In classroom 111	WF-08242021-004002	11/18/2021	FT-FY22-11022021-004002-A	<1	FT-FY22-11022021-004002-B	<1
WS-004003	8/24/2021	8/24/2022	1	Combo Faucet	In classroom 106	WF-08242021-004003	11/18/2021	FT-FY22-11022021-004003-A	<1	FT-FY22-11022021-004003-B	<1
WS-004004	3/15/2021	3/15/2022	1	Combo Fountain	In classroom 111	WF-03152021-004004	11/18/2021	FT-FY22-11022021-004004-A	<1	FT-FY22-11022021-004004-B	<1
WS-004005	8/24/2021	8/24/2022	1	Combo Faucet	In classroom 115	WF-08242021-004005	11/18/2021	FT-FY22-11022021-004005-A	<1	FT-FY22-11022021-004005-B	<1
WS-004006	3/15/2021	3/15/2022	1	Combo Fountain	In classroom 115	WF-03152021-004006	11/18/2021	FT-FY22-11022021-004006-A	<1	FT-FY22-11022021-004006-B	<1
WS-004007	8/24/2021	8/24/2022	1	Combo Faucet	In classroom 117	WF-08242021-004007	11/18/2021	FT-FY22-11022021-004007-A	<1	FT-FY22-11022021-004007-B	<1
WS-004008	3/15/2021	3/15/2022	1	Combo Fountain	In classroom 117	WF-03152021-004008	11/18/2021	FT-FY22-11022021-004008-A	<1	FT-FY22-11022021-004008-B	<1
WS-004009	8/24/2021	8/24/2022	1	Combo Faucet	In classroom 120	WF-08242021-004009	11/18/2021	FT-FY22-11022021-004009-A	<1	FT-FY22-11022021-004009-B	<1
WS-004010	3/15/2021	3/15/2022	1	Combo Fountain	In classroom 120	WF-03152021-004010	11/18/2021	FT-FY22-11022021-004010-A	<1	FT-FY22-11022021-004010-B	<1
WS-004011	3/15/2021	3/15/2022	2	Cooler	In hallway adjacent to south stairwell High Left	WF-03152021-004011	11/18/2021	FT-FY22-11022021-004011-A	<1	FT-FY22-11022021-004011-B	<1
WS-004012	8/24/2021	8/24/2022	1	Combo Faucet	In classroom 101	WF-08242021-004012	11/18/2021	FT-FY22-11022021-004012-A	<1	FT-FY22-11022021-004012-B	<1
WS-004013	3/15/2021	3/15/2022	1	Combo Fountain	In classroom 101	WF-03152021-004013	11/18/2021	FT-FY22-11022021-004013-A	<1	FT-FY22-11022021-004013-B	<1
WS-004014	3/15/2021	3/15/2022	2	Cooler	In hallway adjacent to south stairwell Low Right	WF-03152021-004014	11/18/2021	FT-FY22-11022021-004014-A	<1	FT-FY22-11022021-004014-B	<1
WS-004015	8/24/2021	8/24/2022	2	Combo Faucet	In classroom 207	WF-08242021-004015	11/18/2021	FT-FY22-11022021-004015-A	<1	FT-FY22-11022021-004015-B	<1
WS-004016	3/15/2021	3/15/2022	2	Combo Fountain	In classroom 207	WF-03152021-004016	11/18/2021	FT-FY22-11022021-004016-A	1.0	FT-FY22-11022021-004016-B	<1
WS-004017	8/24/2021	8/24/2022	2	Combo Faucet	In classroom 212	WF-08242021-004017	11/18/2021	FT-FY22-11022021-004017-A	<1	FT-FY22-11022021-004017-B	<1
WS-004018	3/15/2021	3/15/2022	2	Combo Fountain	In classroom 212	WF-03152021-004018	11/18/2021	FT-FY22-11022021-004018-A	1.2	FT-FY22-11022021-004018-B	<1
WS-004019	8/24/2021	8/24/2022	2	Combo Faucet	In classroom 216 Left	WF-08242021-004019	11/18/2021	FT-FY22-11022021-004019-A	<1	FT-FY22-11022021-004019-B	<1
WS-004020	3/15/2021	3/15/2022	2	Combo Fountain	In classroom 216 Left	WF-03152021-004020	11/18/2021	FT-FY22-11022021-004020-A	1.4	FT-FY22-11022021-004020-B	<1
WS-004021	8/24/2021	8/24/2022	2	Combo Faucet	In classroom 216 Right	WF-08242021-004021	11/18/2021	FT-FY22-11022021-004021-A	<1	FT-FY22-11022021-004021-B	<1
WS-004022	3/15/2021	3/15/2022	2	Combo Fountain	In classroom 216 Right	WF-03152021-004022	11/18/2021	FT-FY22-11022021-004022-A	2.1	FT-FY22-11022021-004022-B	1.1
WS-004023	8/24/2021	8/24/2022	2	Combo Faucet	In classroom 218	WF-08242021-004023	11/18/2021	FT-FY22-11022021-004023-A	<1	FT-FY22-11022021-004023-B	<1
WS-004024	10/6/2021	10/6/2022	2	Combo Fountain	In classroom 218	WF-10062021-004024	11/18/2021	FT-FY22-11022021-004024-A	<1	FT-FY22-11022021-004024-B	<1
WS-004025	8/24/2021	8/24/2022	2	Combo Faucet	In classroom 201	WF-08242021-004025	11/18/2021	FT-FY22-11022021-004025-A	<1	FT-FY22-11022021-004025-B	<1
WS-004026	3/15/2021	3/15/2022	2	Combo Fountain	In classroom 201	WF-03152021-004026	11/18/2021	FT-FY22-11022021-004026-A	<1	FT-FY22-11022021-004026-B	<1
WS-004027	8/24/2021	8/24/2022	2	Combo Faucet	In classroom 203	WF-08242021-004027	11/18/2021	FT-FY22-11022021-004027-A	1.4	FT-FY22-11022021-004027-B	<1
WS-004028	3/15/2021	3/15/2022	2	Combo Fountain	In classroom 203	WF-03152021-004028	11/18/2021	FT-FY22-11022021-004028-A	1.1	FT-FY22-11022021-004028-B	<1
WS-004029	3/15/2021	3/15/2022	3	Cooler	In hallway adjacent to south stairwell High Left	WF-03152021-004029	11/18/2021	FT-FY22-11022021-004029-A	<1	FT-FY22-11022021-004029-B	<1
WS-004030	3/15/2021	3/15/2022	3	Cooler	In hallway adjacent to south stairwell Low Right	WF-03152021-004030	11/18/2021	FT-FY22-11022021-004030-A	<1	FT-FY22-11022021-004030-B	<1
WS-004034	8/24/2021	8/24/2022	3	Combo Faucet	In classroom 304	WF-08242021-004034	11/18/2021	FT-FY22-11022021-004034-A	<1	FT-FY22-11022021-004034-B	<1

WS-004035	3/15/2021	3/15/2022	3	Combo Fountain	In classroom 304		WF-03152021-004035	11/18/2021	FT-FY22-11022021-004035-A	<1	FT-FY22-11022021-004035-B	<1
WS-004036	8/24/2021	8/24/2022	3	Combo Faucet	In classroom 308		WF-08242021-004036	11/18/2021	FT-FY22-11022021-004036-A	<1	FT-FY22-11022021-004036-B	<1
WS-004037	3/15/2021	3/15/2022	3	Combo Fountain	In classroom 308		WF-03152021-004037	11/18/2021	FT-FY22-11022021-004037-A	<1	FT-FY22-11022021-004037-B	<1
WS-004038	3/15/2021	3/15/2022	3	Break Room	In staff lounge 313		WF-03152021-004038	11/18/2021	FT-FY22-11022021-004038-A	<1	FT-FY22-11022021-004038-B	<1
WS-004039	3/15/2021	3/15/2022	3	Combo Fountain	In staff lounge 313		WF-03152021-004039	11/18/2021	FT-FY22-11022021-004039-A	<1	FT-FY22-11022021-004039-B	<1
WS-004040	8/24/2021	8/24/2022	3	Combo Faucet	In classroom 302		WF-08242021-004040	11/18/2021	FT-FY22-11022021-004040-A	<1	FT-FY22-11022021-004040-B	<1
WS-004041	3/15/2021	3/15/2022	3	Combo Fountain	In classroom 302		WF-03152021-004041	11/18/2021	FT-FY22-11022021-004041-A	<1	FT-FY22-11022021-004041-B	<1
WS-004042	8/24/2021	8/24/2022	3	Combo Faucet	In classroom 301		WF-08242021-004042	11/18/2021	FT-FY22-11022021-004042-A	<1	FT-FY22-11022021-004042-B	<1
WS-004043	3/15/2021	3/15/2022	3	Combo Fountain	In classroom 301		WF-03152021-004043	11/18/2021	FT-FY22-11022021-004043-A	<1	FT-FY22-11022021-004043-B	<1
WS-004044	8/24/2021	8/24/2022	3	Combo Faucet	In classroom 315		WF-08242021-004044	11/18/2021	FT-FY22-11022021-004044-A	<1	FT-FY22-11022021-004044-B	<1
WS-004045	3/15/2021	3/15/2022	3	Combo Fountain	In classroom 315		WF-03152021-004045	11/18/2021	FT-FY22-11022021-004045-A	<1	FT-FY22-11022021-004045-B	<1
WS-004046	8/24/2021	8/24/2022	1	Combo Faucet	In classroom 103		WF-08242021-004046	11/18/2021	FT-FY22-11022021-004046-A	<1	FT-FY22-11022021-004046-B	<1
WS-004047	3/15/2021	3/15/2022	1	Combo Fountain	In classroom 103		WF-03152021-004047	11/18/2021	FT-FY22-11022021-004047-A	<1	FT-FY22-11022021-004047-B	<1
WS-004048	8/24/2021	8/24/2022	2	Combo Faucet	In classroom 216	Left	WF-08242021-004048	11/18/2021	FT-FY22-11022021-004048-A	<1	FT-FY22-11022021-004048-B	<1
WS-004049	3/15/2021	3/15/2022	2	Combo Fountain	In classroom 216	Left	WF-03152021-004049	11/18/2021	FT-FY22-11022021-004049-A	<1	FT-FY22-11022021-004049-B	<1
WS-004050	8/24/2021	8/24/2022	2	Combo Faucet	In classroom 216	Right	WF-08242021-004050	11/18/2021	FT-FY22-11022021-004050-A	<1	FT-FY22-11022021-004050-B	<1
WS-004051	3/15/2021	3/15/2022	2	Combo Fountain	In classroom 216	Right	WF-03152021-004051	11/18/2021	FT-FY22-11022021-004051-A	<1	FT-FY22-11022021-004051-B	<1
WS-004269	8/24/2021	8/24/2022	1	Bathroom	In classroom 101 in bathroom		WF-08242021-004269	11/18/2021	FT-FY22-11022021-004269-A	<1	FT-FY22-11022021-004269-B	<1
WS-004270	8/24/2021	8/24/2022	1	Bathroom	In classroom 103 in bathroom		WF-08242021-004270	11/18/2021	FT-FY22-11022021-004270-A	<1	FT-FY22-11022021-004270-B	<1
WS-004271	8/24/2021	8/24/2022	1	Bathroom	In classroom 106 in bathroom		WF-08242021-004271	11/18/2021	FT-FY22-11022021-004271-A	<1	FT-FY22-11022021-004271-B	<1
WS-004272	8/24/2021	8/24/2022	1	Bathroom	In classroom 111 in bathroom		WF-08242021-004272	11/18/2021	FT-FY22-11022021-004272-A	<1	FT-FY22-11022021-004272-B	<1
WS-004273	8/24/2021	8/24/2022	1	Bathroom	In classroom 115 in bathroom		WF-08242021-004273	11/18/2021	FT-FY22-11022021-004273-A	<1	FT-FY22-11022021-004273-B	<1
WS-004274	8/24/2021	8/24/2022	1	Bathroom	In classroom 117 in bathroom		WF-08242021-004274	11/18/2021	FT-FY22-11022021-004274-A	<1	FT-FY22-11022021-004274-B	<1
WS-004275	8/24/2021	8/24/2022	1	Bathroom	In classroom 120 in bathroom		WF-08242021-004275	11/18/2021	FT-FY22-11022021-004275-A	<1	FT-FY22-11022021-004275-B	<1

### Food Prep Sink

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-003997	2/22/2021	2/22/2022	Ground Floor	Food Prep Sink	In kitchen east wall Right	WF-02222021-003997	11/18/2021	FT-FY22-11022021-003997-A	<1	FT-FY22-11022021-003997-B	<1