



# Cleveland Elementary School Lead in Water Test Results

## FY24 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 003992	2/27/2023	2/27/2024	Ground Floor	Health Suite	In health suite G07 in unisex restroom	WF-02272023-003992	10/10/2023	FT-FY24-09182023-003992-A	<1	FT-FY24-09182023-003992-B	<1
WS- 003993	2/27/2023	2/27/2024	Ground Floor	Cooler	In hallway adjacent to room G31 High Left	WF-02272023-003993	10/10/2023	FT-FY24-09182023-003993-A	<1	FT-FY24-09182023-003993-B	<1
WS- 003994	2/27/2023	2/27/2024	Ground Floor	Cooler	In hallway adjacent to room G32 Low Right	WF-02272023-003994	10/10/2023	FT-FY24-09182023-003994-A	<1	FT-FY24-09182023-003994-B	<1
WS- 003998	2/27/2023	2/27/2024	Ground Floor	Break Room	In conference room G17	WF-02272023-003998	10/10/2023	FT-FY24-09182023-003998-A	<1	FT-FY24-09182023-003998-B	<1
WS- 003999	2/27/2023	2/27/2024	1	Cooler	In hallway adjacent to south stairwell High Left	WF-02272023-003999	10/10/2023	FT-FY24-09182023-003999-A	<1	FT-FY24-09182023-003999-B	<1
WS- 004000	2/27/2023	2/27/2024	1	Cooler	In hallway adjacent to south stairwell Low Right	WF-02272023-004000	10/10/2023	FT-FY24-09182023-004000-A	<1	FT-FY24-09182023-004000-B	<1
WS- 004002	8/7/2023	8/7/2024	1	Combo Faucet	In classroom 111	WF-08072023-004002	10/10/2023	FT-FY24-09182023-004002-A	<1	FT-FY24-09182023-004002-B	<1
WS- 004004	2/27/2023	2/27/2024	1	Combo Fountain	In classroom 111	WF-02272023-004004	10/10/2023	FT-FY24-09182023-004004-A	<1	FT-FY24-09182023-004004-B	<1
WS- 004005	8/7/2023	8/7/2024	1	Combo Faucet	In classroom 115	WF-08072023-004005	10/10/2023	FT-FY24-09182023-004005-A	<1	FT-FY24-09182023-004005-B	<1
WS- 004006	2/27/2023	2/27/2024	1	Combo Fountain	In classroom 115	WF-02272023-004006	10/10/2023	FT-FY24-09182023-004006-A	<1	FT-FY24-09182023-004006-B	<1
WS- 004007	8/7/2023	8/7/2024	1	Combo Faucet	In classroom 117	WF-08072023-004007	10/10/2023	FT-FY24-09182023-004007-A	<1	FT-FY24-09182023-004007-B	<1
WS- 004008	2/27/2023	2/27/2024	1	Combo Fountain	In classroom 117	WF-02272023-004008	10/10/2023	FT-FY24-09182023-004008-A	<1	FT-FY24-09182023-004008-B	<1
WS- 004009	8/7/2023	8/7/2024	1	Combo Faucet	In classroom 120	WF-08072023-004009	10/10/2023	FT-FY24-09182023-004009-A	<1	FT-FY24-09182023-004009-B	<1
WS- 004010	2/27/2023	2/27/2024	1	Combo Fountain	In classroom 120	WF-02272023-004010	10/10/2023	FT-FY24-09182023-004010-A	<1	FT-FY24-09182023-004010-B	<1
WS- 004011	2/27/2023	2/27/2024	2	Cooler	In hallway adjacent to south stairwell High Left	WF-02272023-004011	10/10/2023	FT-FY24-09182023-004011-A	<1	FT-FY24-09182023-004011-B	<1
WS- 004014	2/27/2023	2/27/2024	2	Cooler	In hallway adjacent to south stairwell Low Right	WF-02272023-004014	10/10/2023	FT-FY24-09182023-004014-A	<1	FT-FY24-09182023-004014-B	<1
WS- 004015	8/7/2023	8/7/2024	2	Combo Faucet	In classroom 207	WF-08072023-004015	10/10/2023	FT-FY24-09182023-004015-A	<1	FT-FY24-09182023-004015-B	<1
WS- 004016	2/27/2023	2/27/2024	2	Combo Fountain	In classroom 207	WF-02272023-004016	10/10/2023	FT-FY24-09182023-004016-A	<1	FT-FY24-09182023-004016-B	<1
WS- 004017	8/7/2023	8/7/2024	2	Combo Faucet	In classroom 212	WF-08072023-004017	10/10/2023	FT-FY24-09182023-004017-A	<1	FT-FY24-09182023-004017-B	<1
WS- 004018	2/27/2023	2/27/2024	2	Combo Fountain	In classroom 212	WF-02272023-004018	10/10/2023	FT-FY24-09182023-004018-A	<1	FT-FY24-09182023-004018-B	<1
WS- 004019	8/7/2023	8/7/2024	2	Combo Faucet	In classroom 216 Left	WF-08072023-004019	10/10/2023	FT-FY24-09182023-004019-A	<1	FT-FY24-09182023-004019-B	<1
WS- 004020	2/27/2023	2/27/2024	2	Combo Fountain	In classroom 216 Left	WF-02272023-004020	10/10/2023	FT-FY24-09182023-004020-A	<1	FT-FY24-09182023-004020-B	<1
WS- 004021	8/7/2023	8/7/2024	2	Combo Faucet	In classroom 216 Right	WF-08072023-004021	10/10/2023	FT-FY24-09182023-004021-A	<1	FT-FY24-09182023-004021-B	<1
WS- 004022	2/27/2023	2/27/2024	2	Combo Fountain	In classroom 216 Right	WF-02272023-004022	10/10/2023	FT-FY24-09182023-004022-A	<1	FT-FY24-09182023-004022-B	<1
WS- 004023	8/7/2023	8/7/2024	2	Combo Faucet	In classroom 218	WF-08072023-004023	10/10/2023	FT-FY24-09182023-004023-A	<1	FT-FY24-09182023-004023-B	<1
WS- 004024	2/27/2023	2/27/2024	2	Combo Fountain	In classroom 218	WF-02272023-004024	10/10/2023	FT-FY24-09182023-004024-A	<1	FT-FY24-09182023-004024-B	<1
WS- 004025	8/7/2023	8/7/2024	2	Combo Faucet	In classroom 201	WF-08072023-004025	10/10/2023	FT-FY24-09182023-004025-A	<1	FT-FY24-09182023-004025-B	<1
WS- 004026	2/27/2023	2/27/2024	2	Combo Fountain	In classroom 201	WF-02272023-004026	10/10/2023	FT-FY24-09182023-004026-A	<1	FT-FY24-09182023-004026-B	<1
WS- 004027	8/7/2023	8/7/2024	2	Combo Faucet	In classroom 203	WF-08072023-004027	10/10/2023	FT-FY24-09182023-004027-A	<1	FT-FY24-09182023-004027-B	<1
WS- 004028	2/27/2023	2/27/2024	2	Combo Fountain	In classroom 203	WF-02272023-004028	10/10/2023	FT-FY24-09182023-004028-A	<1	FT-FY24-09182023-004028-B	<1
WS- 004029	2/27/2023	2/27/2024	3	Cooler	In hallway adjacent to south stairwell High Left	WF-02272023-004029	10/10/2023	FT-FY24-09182023-004029-A	<1	FT-FY24-09182023-004029-B	<1
WS- 004030	2/27/2023	2/27/2024	3	Cooler	In hallway adjacent to south stairwell Low Right	WF-02272023-004030	10/10/2023	FT-FY24-09182023-004030-A	<1	FT-FY24-09182023-004030-B	<1
WS- 004034	8/7/2023	8/7/2024	3	Combo Faucet	In classroom 304	WF-08072023-004034	10/10/2023	FT-FY24-09182023-004034-A	<1	FT-FY24-09182023-004034-B	<1
WS- 004035	2/27/2023	2/27/2024	3	Combo Fountain	In classroom 304	WF-02272023-004035	10/10/2023	FT-FY24-09182023-004035-A	<1	FT-FY24-09182023-004035-B	<1
WS- 004036	8/7/2023	8/7/2024	3	Combo Faucet	In classroom 308	WF-08072023-004036	10/10/2023	FT-FY24-09182023-004036-A	<1	FT-FY24-09182023-004036-B	<1

WS-004040	8/7/2023	8/7/2024	3	Combo Faucet	In classroom 302		WF-08072023-004040	10/10/2023	FT-FY24-09182023-004040-A	<1	FT-FY24-09182023-004040-B	<1
WS-004041	2/27/2023	2/27/2024	3	Combo Fountain	In classroom 302		WF-02272023-004041	10/10/2023	FT-FY24-09182023-004041-A	<1	FT-FY24-09182023-004041-B	<1
WS-004042	8/7/2023	8/7/2024	3	Combo Faucet	In classroom 301		WF-08072023-004042	10/10/2023	FT-FY24-09182023-004042-A	<1	FT-FY24-09182023-004042-B	<1
WS-004043	2/27/2023	2/27/2024	3	Combo Fountain	In classroom 301		WF-02272023-004043	10/10/2023	FT-FY24-09182023-004043-A	<1	FT-FY24-09182023-004043-B	<1
WS-004044	8/7/2023	8/7/2024	3	Combo Faucet	In classroom 315		WF-08072023-004044	10/10/2023	FT-FY24-09182023-004044-A	<1	FT-FY24-09182023-004044-B	<1
WS-004045	2/27/2023	2/27/2024	3	Combo Fountain	In classroom 315		WF-02272023-004045	10/10/2023	FT-FY24-09182023-004045-A	<1	FT-FY24-09182023-004045-B	<1
WS-004046	8/7/2023	8/7/2024	1	Combo Faucet	In classroom 103		WF-08072023-004046	10/10/2023	FT-FY24-09182023-004046-A	<1	FT-FY24-09182023-004046-B	<1
WS-004047	2/27/2023	2/27/2024	1	Combo Fountain	In classroom 103		WF-02272023-004047	10/10/2023	FT-FY24-09182023-004047-A	<1	FT-FY24-09182023-004047-B	<1
WS-004048	8/7/2023	8/7/2024	2	Combo Faucet	In classroom 216	Left	WF-08072023-004048	10/10/2023	FT-FY24-09182023-004048-A	<1	FT-FY24-09182023-004048-B	<1
WS-004049	2/27/2023	2/27/2024	2	Combo Fountain	In classroom 216	Left	WF-02272023-004049	10/10/2023	FT-FY24-09182023-004049-A	<1	FT-FY24-09182023-004049-B	<1
WS-004050	8/7/2023	8/7/2024	2	Combo Faucet	In classroom 216	Right	WF-08072023-004050	10/10/2023	FT-FY24-09182023-004050-A	<1	FT-FY24-09182023-004050-B	<1
WS-004051	2/27/2023	2/27/2024	2	Combo Fountain	In classroom 216	Right	WF-02272023-004051	10/10/2023	FT-FY24-09182023-004051-A	<1	FT-FY24-09182023-004051-B	<1
WS-004270	8/7/2023	8/7/2024	1	Bathroom	In classroom 103 in bathroom		WF-08072023-004270	10/10/2023	FT-FY24-09182023-004270-A	<1	FT-FY24-09182023-004270-B	<1
WS-004271	8/7/2023	8/7/2024	1	Bathroom	In classroom 106 in bathroom		WF-08072023-004271	10/10/2023	FT-FY24-09182023-004271-A	<1	FT-FY24-09182023-004271-B	<1
WS-004272	8/7/2023	8/7/2024	1	Bathroom	In classroom 111 in bathroom		WF-08072023-004272	10/10/2023	FT-FY24-09182023-004272-A	<1	FT-FY24-09182023-004272-B	<1
WS-004274	8/7/2023	8/7/2024	1	Bathroom	In classroom 117 in bathroom		WF-08072023-004274	10/10/2023	FT-FY24-09182023-004274-A	<1	FT-FY24-09182023-004274-B	<1
WS-004275	8/7/2023	8/7/2024	1	Bathroom	In classroom 120 in bathroom		WF-08072023-004275	10/10/2023	FT-FY24-09182023-004275-A	<1	FT-FY24-09182023-004275-B	<1

### Food Prep Sink

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS-003997	1/24/2023	1/24/2024	Ground Floor	Food Prep Sink	In kitchen east wall	Right	WF-01242023-003997	10/10/2023	FT-FY24-09182023-003997-A	<1	FT-FY24-09182023-003997-B	<1