



# Cleveland Elementary School Lead in Water Test Results

## FY21 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-003992	3/23/2020	3/23/2021	Ground Floor	Health Suite	In health suite G07 in unisex restroom	WF-03232020-003992	2/20/2021	FT-FY21-022021-003992-A	<1	FT-FY21-022021-003992-B	<1
WS-003993	3/23/2020	3/23/2021	Ground Floor	Cooler	In hallway adjacent to room G31 High Left	WF-03232020-003993	2/20/2021	FT-FY21-022021-003993-A	<1	FT-FY21-022021-003993-B	<1
WS-003994	3/23/2020	3/23/2021	Ground Floor	Cooler	In hallway adjacent to room G32 Low Right	WF-03232020-003994	2/20/2021	FT-FY21-022021-003994-A	<1	FT-FY21-022021-003994-B	<1
WS-003998	3/23/2020	3/23/2021	Ground Floor	Break Room	In conference room G17	WF-03232020-003998	2/20/2021	FT-FY21-022021-003998-A	<1	FT-FY21-022021-003998-B	<1
WS-004001	3/23/2020	3/23/2021	1	Combo Fountain	In classroom 106	WF-03232020-004001	2/20/2021	FT-FY21-022021-004001-A	1.0	FT-FY21-022021-004001-B	<1
WS-004002	8/31/2020	8/31/2021	1	Combo Faucet	In classroom 111	WF-08312020-004002	2/20/2021	FT-FY21-022021-004002-A	<1	FT-FY21-022021-004002-B	<1
WS-004003	8/31/2020	8/31/2021	1	Combo Faucet	In classroom 106	WF-08312020-004003	2/20/2021	FT-FY21-022021-004003-A	1.1	FT-FY21-022021-004003-B	<1
WS-004004	3/23/2020	3/23/2021	1	Combo Fountain	In classroom 111	WF-03232020-004004	2/20/2021	FT-FY21-022021-004004-A	<1	FT-FY21-022021-004004-B	<1
WS-004005	8/31/2020	8/31/2021	1	Combo Faucet	In classroom 115	WF-08312020-004005	2/20/2021	FT-FY21-022021-004005-A	<1	FT-FY21-022021-004005-B	<1
WS-004006	3/23/2020	3/23/2021	1	Combo Fountain	In classroom 115	WF-03232020-004006	2/20/2021	FT-FY21-022021-004006-A	<1	FT-FY21-022021-004006-B	<1
WS-004007	8/31/2020	8/31/2021	1	Combo Faucet	In classroom 117	WF-08312020-004007	2/20/2021	FT-FY21-022021-004007-A	<1	FT-FY21-022021-004007-B	<1
WS-004008	3/23/2020	3/23/2021	1	Combo Fountain	In classroom 117	WF-03232020-004008	2/20/2021	FT-FY21-022021-004008-A	<1	FT-FY21-022021-004008-B	<1
WS-004009	8/31/2020	8/31/2021	1	Combo Faucet	In classroom 120	WF-08312020-004009	2/20/2021	FT-FY21-022021-004009-A	<1	FT-FY21-022021-004009-B	<1
WS-004010	3/23/2020	3/23/2021	1	Combo Fountain	In classroom 120	WF-03232020-004010	2/20/2021	FT-FY21-022021-004010-A	<1	FT-FY21-022021-004010-B	<1
WS-004011	3/23/2020	3/23/2021	2	Cooler	In hallway adjacent to south stairwell High Left	WF-03232020-004011	2/20/2021	FT-FY21-022021-004011-A	<1	FT-FY21-022021-004011-B	<1
WS-004012	8/31/2020	8/31/2021	1	Combo Faucet	In classroom 101	WF-08312020-004012	2/20/2021	FT-FY21-022021-004012-A	2.0	FT-FY21-022021-004012-B	<1
WS-004013	3/23/2020	3/23/2021	1	Combo Fountain	In classroom 101	WF-03232020-004013	2/20/2021	FT-FY21-022021-004013-A	<1	FT-FY21-022021-004013-B	<1
WS-004014	3/23/2020	3/23/2021	2	Cooler	In hallway adjacent to south stairwell Low Right	WF-03232020-004014	2/20/2021	FT-FY21-022021-004014-A	<1	FT-FY21-022021-004014-B	<1
WS-004015	8/31/2020	8/31/2021	2	Combo Faucet	In classroom 207	WF-08312020-004015	2/20/2021	FT-FY21-022021-004015-A	<1	FT-FY21-022021-004015-B	<1
WS-004016	3/23/2020	3/23/2021	2	Combo Fountain	In classroom 207	WF-03232020-004016	2/20/2021	FT-FY21-022021-004016-A	<1	FT-FY21-022021-004016-B	<1
WS-004017	8/31/2020	8/31/2021	2	Combo Faucet	In classroom 212	WF-08312020-004017	2/20/2021	FT-FY21-022021-004017-A	<1	FT-FY21-022021-004017-B	<1
WS-004018	3/23/2020	3/23/2021	2	Combo Fountain	In classroom 212	WF-03232020-004018	2/20/2021	FT-FY21-022021-004018-A	<1	FT-FY21-022021-004018-B	<1
WS-004019	8/31/2020	8/31/2021	2	Combo Faucet	In classroom 216 Left	WF-08312020-004019	2/20/2021	FT-FY21-022021-004019-A	2.2	FT-FY21-022021-004019-B	<1
WS-004020	3/23/2020	3/23/2021	2	Combo Fountain	In classroom 216 Left	WF-03232020-004020	2/20/2021	FT-FY21-022021-004020-A	<1	FT-FY21-022021-004020-B	<1
WS-004021	8/31/2020	8/31/2021	2	Combo Faucet	In classroom 216 Right	WF-08312020-004021	2/20/2021	FT-FY21-022021-004021-A	<1	FT-FY21-022021-004021-B	<1
WS-004022	3/23/2020	3/23/2021	2	Combo Fountain	In classroom 216 Right	WF-03232020-004022	2/20/2021	FT-FY21-022021-004022-A	1.1	FT-FY21-022021-004022-B	<1
WS-004023	8/31/2020	8/31/2021	2	Combo Faucet	In classroom 218	WF-08312020-004023	2/20/2021	FT-FY21-022021-004023-A	<1	FT-FY21-022021-004023-B	<1
WS-004024	3/23/2020	3/23/2021	2	Combo Fountain	In classroom 218	WF-03232020-004024	2/20/2021	FT-FY21-022021-004024-A	<1	FT-FY21-022021-004024-B	<1
WS-004025	8/31/2020	8/31/2021	2	Combo Faucet	In classroom 201	WF-08312020-004025	2/20/2021	FT-FY21-022021-004025-A	1.4	FT-FY21-022021-004025-B	<1
WS-004026	3/23/2020	3/23/2021	2	Combo Fountain	In classroom 201	WF-03232020-004026	2/20/2021	FT-FY21-022021-004026-A	<1	FT-FY21-022021-004026-B	<1
WS-004027	8/31/2020	8/31/2021	2	Combo Faucet	In classroom 203	WF-08312020-004027	2/20/2021	FT-FY21-022021-004027-A	1.4	FT-FY21-022021-004027-B	<1
WS-004028	3/23/2020	3/23/2021	2	Combo Fountain	In classroom 203	WF-03232020-004028	2/20/2021	FT-FY21-022021-004028-A	<1	FT-FY21-022021-004028-B	<1

WS- 004029	3/23/2020	3/23/2021	3	Cooler	In hallway adjacent to south stairwell	High	Left	WF-03232020-004029	2/20/2021	FT-FY21-022021-004029-A	<1	FT-FY21-022021-004029-B	<1
WS- 004030	3/23/2020	3/23/2021	3	Cooler	In hallway adjacent to south stairwell	Low	Right	WF-03232020-004030	2/20/2021	FT-FY21-022021-004030-A	<1	FT-FY21-022021-004030-B	<1
WS- 004035	3/23/2020	3/23/2021	3	Combo Fountain	In classroom 304			WF-03232020-004035	2/20/2021	FT-FY21-022021-004035-A	<1	FT-FY21-022021-004035-B	<1
WS- 004036	8/31/2020	8/31/2021	3	Combo Faucet	In classroom 308			WF-08312020-004036	2/20/2021	FT-FY21-022021-004036-A	<1	FT-FY21-022021-004036-B	<1
WS- 004037	3/23/2020	3/23/2021	3	Combo Fountain	In classroom 308			WF-03232020-004037	2/20/2021	FT-FY21-022021-004037-A	<1	FT-FY21-022021-004037-B	<1
WS- 004038	3/23/2020	3/23/2021	3	Break Room	In staff lounge 313			WF-03232020-004038	2/20/2021	FT-FY21-022021-004038-A	<1	FT-FY21-022021-004038-B	<1
WS- 004039	3/23/2020	3/23/2021	3	Combo Fountain	In staff lounge 313			WF-03232020-004039	2/20/2021	FT-FY21-022021-004039-A	<1	FT-FY21-022021-004039-B	<1
WS- 004040	8/31/2020	8/31/2021	3	Combo Faucet	In classroom 302			WF-08312020-004040	2/20/2021	FT-FY21-022021-004040-A	1.1	FT-FY21-022021-004040-B	<1
WS- 004041	3/23/2020	3/23/2021	3	Combo Fountain	In classroom 302			WF-03232020-004041	2/20/2021	FT-FY21-022021-004041-A	<1	FT-FY21-022021-004041-B	<1
WS- 004042	8/31/2020	8/31/2021	3	Combo Faucet	In classroom 301			WF-08312020-004042	2/20/2021	FT-FY21-022021-004042-A	<1	FT-FY21-022021-004042-B	<1
WS- 004043	3/23/2020	3/23/2021	3	Combo Fountain	In classroom 301			WF-03232020-004043	2/20/2021	FT-FY21-022021-004043-A	<1	FT-FY21-022021-004043-B	<1
WS- 004044	8/31/2020	8/31/2021	3	Combo Faucet	In classroom 315			WF-08312020-004044	2/20/2021	FT-FY21-022021-004044-A	<1	FT-FY21-022021-004044-B	<1
WS- 004045	3/23/2020	3/23/2021	3	Combo Fountain	In classroom 315			WF-03232020-004045	2/20/2021	FT-FY21-022021-004045-A	<1	FT-FY21-022021-004045-B	<1
WS- 004046	8/31/2020	8/31/2021	1	Combo Faucet	In classroom 103			WF-08312020-004046	2/20/2021	FT-FY21-022021-004046-A	<1	FT-FY21-022021-004046-B	<1
WS- 004047	3/23/2020	3/23/2021	1	Combo Fountain	In classroom 103			WF-03232020-004047	2/20/2021	FT-FY21-022021-004047-A	<1	FT-FY21-022021-004047-B	<1
WS- 004048	8/31/2020	8/31/2021	2	Combo Faucet	In classroom 216		Left	WF-08312020-004048	2/20/2021	FT-FY21-022021-004048-A	<1	FT-FY21-022021-004048-B	<1
WS- 004049	3/23/2020	3/23/2021	2	Combo Fountain	In classroom 216		Left	WF-03232020-004049	2/20/2021	FT-FY21-022021-004049-A	<1	FT-FY21-022021-004049-B	<1
WS- 004050	8/31/2020	8/31/2021	2	Combo Faucet	In classroom 216		Right	WF-08312020-004050	2/20/2021	FT-FY21-022021-004050-A	<1	FT-FY21-022021-004050-B	<1
WS- 004051	3/23/2020	3/23/2021	2	Combo Fountain	In classroom 216		Right	WF-03232020-004051	2/20/2021	FT-FY21-022021-004051-A	<1	FT-FY21-022021-004051-B	<1
WS- 004269	8/31/2020	8/31/2021	1	Bathroom	In classroom 101 in bathroom			WF-08312020-004269	2/20/2021	FT-FY21-022021-004269-A	<1	FT-FY21-022021-004269-B	<1
WS- 004270	8/31/2020	8/31/2021	1	Bathroom	In classroom 103 in bathroom			WF-08312020-004270	2/20/2021	FT-FY21-022021-004270-A	2.1	FT-FY21-022021-004270-B	<1
WS- 004271	8/31/2020	8/31/2021	1	Bathroom	In classroom 106 in bathroom			WF-08312020-004271	2/20/2021	FT-FY21-022021-004271-A	<1	FT-FY21-022021-004271-B	<1
WS- 004272	8/31/2020	8/31/2021	1	Bathroom	In classroom 111 in bathroom			WF-08312020-004272	2/20/2021	FT-FY21-022021-004272-A	<1	FT-FY21-022021-004272-B	<1
WS- 004273	8/31/2020	8/31/2021	1	Bathroom	In classroom 115 in bathroom			WF-08312020-004273	2/20/2021	FT-FY21-022021-004273-A	<1	FT-FY21-022021-004273-B	<1
WS- 004274	8/31/2020	8/31/2021	1	Bathroom	In classroom 117 in bathroom			WF-08312020-004274	2/20/2021	FT-FY21-022021-004274-A	<1	FT-FY21-022021-004274-B	<1
WS- 004275	8/31/2020	8/31/2021	1	Bathroom	In classroom 120 in bathroom			WF-08312020-004275	2/20/2021	FT-FY21-022021-004275-A	<1	FT-FY21-022021-004275-B	<1

### Food Prep Sink

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS- 003997	1/15/2020	1/15/2021	Ground Floor	Food Prep Sink	In kitchen east wall	Right	WF-01152020-003997	2/20/2021	FT-FY21-022021-003997-A	<1	FT-FY21-022021-003997-B	<1

### FY21 Filter Test

Greater than 5ppb - Devices requiring remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS- 004034	8/31/2020	8/31/2021	3	Combo Faucet	In classroom 304		WF-08312020-004034	2/20/2021	FT-FY21-022021-004034-A	10	FT-FY21-022021-004034-B	<1

### FY21 Filter Test

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 004034	2/26/2021	2/26/2022	3	Combo Faucet	In classroom 304	WF-02262021-004034	3/5/2021	FT-FY21-032021-004034-A	<1	FT-FY21-032021-004034-B	<1