



Cleveland Elementary School Lead in Water Test Results

FY25 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 003992	2/27/2024	2/27/2025	Ground Floor	Health Suite	In health suite G07 in unix restroom	WF-02272024-003992	10/18/2024	FT-FY25-10032024-003992-A	<2	FT-FY25-10032024-003992-B	<2
WS- 003993	2/27/2024	2/27/2025	Ground Floor	Cooler	In hallway adjacent to room G31 High Left	WF-02272024-003993	10/18/2024	FT-FY25-10032024-003993-A	<2	FT-FY25-10032024-003993-B	<2
WS- 003994	2/27/2024	2/27/2025	Ground Floor	Cooler	In hallway adjacent to room G32 Low Right	WF-02272024-003994	10/18/2024	FT-FY25-10032024-003994-A	<2	FT-FY25-10032024-003994-B	<2
WS- 003998	2/27/2024	2/27/2025	Ground Floor	Break Room	In conference room G17	WF-02272024-003998	10/18/2024	FT-FY25-10032024-003998-A	<2	FT-FY25-10032024-003998-B	<2
WS- 003999	2/27/2024	2/27/2025	1	Cooler	In hallway adjacent to south stairwell High Left	WF-02272024-003999	10/18/2024	FT-FY25-10032024-003999-A	<2	FT-FY25-10032024-003999-B	<2
WS- 004000	2/27/2024	2/27/2025	1	Cooler	In hallway adjacent to south stairwell Low Right	WF-02272024-004000	10/18/2024	FT-FY25-10032024-004000-A	<2	FT-FY25-10032024-004000-B	<2
WS- 004002	8/5/2024	8/5/2025	1	Combo Faucet	In classroom 111	WF-08052024-004002	10/18/2024	FT-FY25-10032024-004002-A	<2	FT-FY25-10032024-004002-B	<2
WS- 004004	2/27/2024	2/27/2025	1	Combo Fountain	In classroom 111	WF-02272024-004004	10/18/2024	FT-FY25-10032024-004004-A	<2	FT-FY25-10032024-004004-B	<2
WS- 004005	8/5/2024	8/5/2025	1	Combo Faucet	In classroom 115	WF-08052024-004005	10/18/2024	FT-FY25-10032024-004005-A	<2	FT-FY25-10032024-004005-B	<2
WS- 004006	2/27/2024	2/27/2025	1	Combo Fountain	In classroom 115	WF-02272024-004006	10/18/2024	FT-FY25-10032024-004006-A	<2	FT-FY25-10032024-004006-B	<2
WS- 004007	8/5/2024	8/5/2025	1	Combo Faucet	In classroom 117	WF-08052024-004007	10/18/2024	FT-FY25-10032024-004007-A	<2	FT-FY25-10032024-004007-B	<2
WS- 004008	2/27/2024	2/27/2025	1	Combo Fountain	In classroom 117	WF-02272024-004008	10/18/2024	FT-FY25-10032024-004008-A	<2	FT-FY25-10032024-004008-B	<2
WS- 004009	8/5/2024	8/5/2025	1	Combo Faucet	In classroom 120	WF-08052024-004009	10/18/2024	FT-FY25-10032024-004009-A	<2	FT-FY25-10032024-004009-B	<2
WS- 004010	2/27/2024	2/27/2025	1	Combo Fountain	In classroom 120	WF-02272024-004010	10/18/2024	FT-FY25-10032024-004010-A	<2	FT-FY25-10032024-004010-B	<2
WS- 004011	2/27/2024	2/27/2025	2	Cooler	In hallway adjacent to south stairwell High Left	WF-02272024-004011	10/18/2024	FT-FY25-10032024-004011-A	<2	FT-FY25-10032024-004011-B	<2
WS- 004012	8/5/2024	8/5/2025	1	Combo Faucet	In classroom 101	WF-08052024-004012	10/18/2024	FT-FY25-10032024-004012-A	<2	FT-FY25-10032024-004012-B	<2
WS- 004013	2/27/2024	2/27/2025	1	Combo Fountain	In classroom 101	WF-02272024-004013	10/18/2024	FT-FY25-10032024-004013-A	<2	FT-FY25-10032024-004013-B	<2
WS- 004014	2/27/2024	2/27/2025	2	Cooler	In hallway adjacent to south stairwell Low Right	WF-02272024-004014	10/18/2024	FT-FY25-10032024-004014-A	<2	FT-FY25-10032024-004014-B	<2
WS- 004015	8/5/2024	8/5/2025	2	Combo Faucet	In classroom 207	WF-08052024-004015	10/18/2024	FT-FY25-10032024-004015-A	<2	FT-FY25-10032024-004015-B	<2
WS- 004016	2/27/2024	2/27/2025	2	Combo Fountain	In classroom 207	WF-02272024-004016	10/18/2024	FT-FY25-10032024-004016-A	<2	FT-FY25-10032024-004016-B	<2
WS- 004017	8/5/2024	8/5/2025	2	Combo Faucet	In classroom 212	WF-08052024-004017	10/18/2024	FT-FY25-10032024-004017-A	<2	FT-FY25-10032024-004017-B	<2
WS- 004018	2/27/2024	2/27/2025	2	Combo Fountain	In classroom 212	WF-02272024-004018	10/18/2024	FT-FY25-10032024-004018-A	<2	FT-FY25-10032024-004018-B	<2
WS- 004019	8/5/2024	8/5/2025	2	Combo Faucet	In classroom 216 Left	WF-08052024-004019	10/18/2024	FT-FY25-10032024-004019-A	<2	FT-FY25-10032024-004019-B	<2
WS- 004020	2/27/2024	2/27/2025	2	Combo Fountain	In classroom 216 Left	WF-02272024-004020	10/18/2024	FT-FY25-10032024-004020-A	<2	FT-FY25-10032024-004020-B	<2
WS- 004021	8/5/2024	8/5/2025	2	Combo Faucet	In classroom 216 Right	WF-08052024-004021	10/18/2024	FT-FY25-10032024-004021-A	<2	FT-FY25-10032024-004021-B	<2
WS- 004022	2/27/2024	2/27/2025	2	Combo Fountain	In classroom 216 Right	WF-02272024-004022	10/18/2024	FT-FY25-10032024-004022-A	2.1	FT-FY25-10032024-004022-B	<2
WS- 004023	8/5/2024	8/5/2025	2	Combo Faucet	In classroom 218	WF-08052024-004023	10/18/2024	FT-FY25-10032024-004023-A	<2	FT-FY25-10032024-004023-B	<2
WS- 004024	2/27/2024	2/27/2025	2	Combo Fountain	In classroom 218	WF-02272024-004024	10/18/2024	FT-FY25-10032024-004024-A	<2	FT-FY25-10032024-004024-B	<2
WS- 004025	8/5/2024	8/5/2025	2	Combo Faucet	In classroom 201	WF-08052024-004025	10/18/2024	FT-FY25-10032024-004025-A	4.1	FT-FY25-10032024-004025-B	<2
WS- 004026	2/27/2024	2/27/2025	2	Combo Fountain	In classroom 201	WF-02272024-004026	10/18/2024	FT-FY25-10032024-004026-A	<2	FT-FY25-10032024-004026-B	<2
WS- 004028	2/27/2024	2/27/2025	2	Combo Fountain	In classroom 203	WF-02272024-004028	10/18/2024	FT-FY25-10032024-004028-A	<2	FT-FY25-10032024-004028-B	<2
WS- 004029	2/27/2024	2/27/2025	3	Cooler	In hallway adjacent to south stairwell High Left	WF-02272024-004029	10/18/2024	FT-FY25-10032024-004029-A	<2	FT-FY25-10032024-004029-B	<2
WS- 004030	2/27/2024	2/27/2025	3	Cooler	In hallway adjacent to south stairwell Low Right	WF-02272024-004030	10/18/2024	FT-FY25-10032024-004030-A	<2	FT-FY25-10032024-004030-B	<2

WS-004034	8/5/2024	8/5/2025	3	Combo Faucet	In classroom 304		WF-08052024-004034	10/18/2024	FT-FY25-10032024-004034-A	<2	FT-FY25-10032024-004034-B	<2
WS-004035	2/27/2024	2/27/2025	3	Combo Fountain	In classroom 304		WF-02272024-004035	10/18/2024	FT-FY25-10032024-004035-A	<2	FT-FY25-10032024-004035-B	<2
WS-004036	8/5/2024	8/5/2025	3	Combo Faucet	In classroom 308		WF-08052024-004036	10/18/2024	FT-FY25-10032024-004036-A	<2	FT-FY25-10032024-004036-B	<2
WS-004037	2/27/2024	2/27/2025	3	Combo Fountain	In classroom 308		WF-02272024-004037	10/18/2024	FT-FY25-10032024-004037-A	<2	FT-FY25-10032024-004037-B	<2
WS-004038	2/27/2024	2/27/2025	3	Break Room	In staff lounge 313		WF-02272024-004038	10/18/2024	FT-FY25-10032024-004038-A	<2	FT-FY25-10032024-004038-B	<2
WS-004039	2/27/2024	2/27/2025	3	Combo Fountain	In staff lounge 313		WF-02272024-004039	10/18/2024	FT-FY25-10032024-004039-A	<2	FT-FY25-10032024-004039-B	<2
WS-004040	8/5/2024	8/5/2025	3	Combo Faucet	In classroom 302		WF-08052024-004040	10/18/2024	FT-FY25-10032024-004040-A	<2	FT-FY25-10032024-004040-B	<2
WS-004041	2/27/2024	2/27/2025	3	Combo Fountain	In classroom 302		WF-02272024-004041	10/18/2024	FT-FY25-10032024-004041-A	<2	FT-FY25-10032024-004041-B	<2
WS-004042	8/5/2024	8/5/2025	3	Combo Faucet	In classroom 301		WF-08052024-004042	10/18/2024	FT-FY25-10032024-004042-A	<2	FT-FY25-10032024-004042-B	<2
WS-004043	2/27/2024	2/27/2025	3	Combo Fountain	In classroom 301		WF-02272024-004043	10/18/2024	FT-FY25-10032024-004043-A	<2	FT-FY25-10032024-004043-B	<2
WS-004046	8/5/2024	8/5/2025	1	Combo Faucet	In classroom 103		WF-08052024-004046	10/18/2024	FT-FY25-10032024-004046-A	<2	FT-FY25-10032024-004046-B	<2
WS-004047	2/27/2024	2/27/2025	1	Combo Fountain	In classroom 103		WF-02272024-004047	10/18/2024	FT-FY25-10032024-004047-A	<2	FT-FY25-10032024-004047-B	<2
WS-004049	2/27/2024	2/27/2025	2	Combo Fountain	In classroom 216	Left	WF-02272024-004049	10/18/2024	FT-FY25-10032024-004049-A	<2	FT-FY25-10032024-004049-B	<2
WS-004051	2/27/2024	2/27/2025	2	Combo Fountain	In classroom 216	Right	WF-02272024-004051	10/18/2024	FT-FY25-10032024-004051-A	2.2	FT-FY25-10032024-004051-B	<2
WS-004269	8/5/2024	8/5/2025	1	Bathroom	In classroom 101 in bathroom		WF-08052024-004269	10/18/2024	FT-FY25-10032024-004269-A	<2	FT-FY25-10032024-004269-B	<2
WS-004270	8/5/2024	8/5/2025	1	Bathroom	In classroom 103 in bathroom		WF-08052024-004270	10/18/2024	FT-FY25-10032024-004270-A	<2	FT-FY25-10032024-004270-B	<2
WS-004271	8/5/2024	8/5/2025	1	Bathroom	In classroom 106 in bathroom		WF-08052024-004271	10/18/2024	FT-FY25-10032024-004271-A	<2	FT-FY25-10032024-004271-B	<2
WS-004272	8/5/2024	8/5/2025	1	Bathroom	In classroom 111 in bathroom		WF-08052024-004272	10/18/2024	FT-FY25-10032024-004272-A	<2	FT-FY25-10032024-004272-B	<2
WS-004273	8/5/2024	8/5/2025	1	Bathroom	In classroom 115 in bathroom		WF-08052024-004273	10/18/2024	FT-FY25-10032024-004273-A	<2	FT-FY25-10032024-004273-B	<2
WS-004274	8/5/2024	8/5/2025	1	Bathroom	In classroom 117 in bathroom		WF-08052024-004274	10/18/2024	FT-FY25-10032024-004274-A	<2	FT-FY25-10032024-004274-B	<2
WS-004275	8/5/2024	8/5/2025	1	Bathroom	In classroom 120 in bathroom		WF-08052024-004275	10/18/2024	FT-FY25-10032024-004275-A	<2	FT-FY25-10032024-004275-B	<2

Food Prep Sink

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS-003997	11/14/2023	11/14/2024	Ground Floor	Food Prep Sink	In kitchen east wall	Right	WF-11142023-003997	10/18/2024	FT-FY25-10032024-003997-A	<2	FT-FY25-10032024-003997-B	<2

FY25 Filter Test

Greater than 5ppb - Devices requiring remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS-004027	8/5/2024	8/5/2025	2	Combo Faucet	In classroom 203		WF-08052024-004027	10/18/2024	FT-FY25-10032024-004027-A	12.6	FT-FY25-10032024-004027-B	<2
WS-004048	8/5/2024	8/5/2025	2	Combo Faucet	In classroom 216	Left	WF-08052024-004048	10/18/2024	FT-FY25-10032024-004048-A	11.1	FT-FY25-10032024-004048-B	<2
WS-004050	8/5/2024	8/5/2025	2	Combo Faucet	In classroom 216	Right	WF-08052024-004050	10/18/2024	FT-FY25-10032024-004050-A	5.9	FT-FY25-10032024-004050-B	<2

First Re-test (After Plumbing Check)

FY25 Filter Test

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS- 004027	10/22/2024	10/22/2025	2	Combo Faucet	in classroom 203	WF-10222024-004027	10/24/2024	FT-FY25-10222024-004027-A	<2	FT-FY25-10222024-004027-B	<2	
WS- 004048	10/22/2024	10/22/2025	2	Combo Faucet	in classroom 216	Left	WF-10222024-004048	10/24/2024	FT-FY25-10222024-004048-A	<2	FT-FY25-10222024-004048-B	<2
WS- 004050	10/22/2024	10/22/2025	2	Combo Faucet	in classroom 216	Right	WF-10222024-004050	10/24/2024	FT-FY25-10222024-004050-A	<2	FT-FY25-10222024-004050-B	<2

Due to changes in water sampling analysis equipment at the laboratory from previous years, the level of detection (LOD) for lead in drinking water is now <2ppb.