



CLEVELAND ES LEAD WATER TEST RESULTS



	Building Location: Building Name	RECORD ID	Date Analyzed	Floor	Device Type	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)
1	CLEVELAND ELEMENTARY SCHOOL	WS- 003992	8/12/2016	Ground Floor	Health Suite	In unisex restroom in health suite G07	FT-72016-003992-A	< 1	FT-72016-003992-B	< 1
2	CLEVELAND ELEMENTARY SCHOOL	WS- 003993	8/12/2016	Ground Floor	Cooler	In hallway adjacent to room G31 High Left	FT-72016-003993-A	< 1	FT-72016-003993-B	< 1
3	CLEVELAND ELEMENTARY SCHOOL	WS- 003994	8/12/2016	Ground Floor	Cooler	In hallway adjacent to room G32 Low Right	FT-72016-003994-A	< 1	FT-72016-003994-B	< 1
4	CLEVELAND ELEMENTARY SCHOOL	WS- 003997	8/12/2016	Ground Floor	Food Prep Sink	In kitchen east wall Right	FT-72016-003997-A	< 1	FT-72016-003997-B	< 1
5	CLEVELAND ELEMENTARY SCHOOL	WS- 003999	8/12/2016	1	Cooler	In hallway adjacent to south stairwell High Left	FT-72016-003999-A	< 1	FT-72016-003999-B	< 1
6	CLEVELAND ELEMENTARY SCHOOL	WS- 004000	8/12/2016	1	Cooler	In hallway adjacent to south stairwell Low Right	FT-72016-004000-A	< 1	FT-72016-004000-B	< 1
7	CLEVELAND ELEMENTARY SCHOOL	WS- 004001	8/12/2016	1	Fountain	In classroom 106	FT-72016-004001-A	< 1	FT-72016-004001-B	< 1
8	CLEVELAND ELEMENTARY SCHOOL	WS- 004004	8/12/2016	1	Fountain	In classroom 111	FT-72016-004004-A	< 1	FT-72016-004004-B	< 1
9	CLEVELAND ELEMENTARY SCHOOL	WS- 004006	8/12/2016	1	Fountain	In classroom 115	FT-72016-004006-A	< 1	FT-72016-004006-B	< 1
10	CLEVELAND ELEMENTARY SCHOOL	WS- 004008	8/12/2016	1	Fountain	In classroom 117	FT-72016-004008-A	< 1	FT-72016-004008-B	< 1
11	CLEVELAND ELEMENTARY SCHOOL	WS- 004010	8/12/2016	1	Fountain	In classroom 120	FT-82016-004010-A	< 1	FT-82016-004010-B	< 1
12	CLEVELAND ELEMENTARY SCHOOL	WS- 004011	8/12/2016	2	Cooler	In hallway adjacent to south stairwell High Left	FT-72016-004011-A	< 1	FT-72016-004011-B	< 1
13	CLEVELAND ELEMENTARY SCHOOL	WS- 004013	8/12/2016	1	Fountain	In classroom 101	FT-72016-004013-A	< 1	FT-72016-004013-B	< 1
14	CLEVELAND ELEMENTARY SCHOOL	WS- 004014	8/12/2016	2	Cooler	In hallway adjacent to south stairwell Low Right	FT-72016-004014-A	< 1	FT-72016-004014-B	< 1
15	CLEVELAND ELEMENTARY SCHOOL	WS- 004016	8/12/2016	2	Fountain	In classroom 207	FT-72016-004016-A	< 1	FT-72016-004016-B	< 1
16	CLEVELAND ELEMENTARY SCHOOL	WS- 004018	8/12/2016	2	Fountain	In classroom 212	FT-72016-004018-A	< 1	FT-72016-004018-B	< 1
17	CLEVELAND ELEMENTARY SCHOOL	WS- 004020	8/12/2016	2	Fountain	In classroom 216 Left	FT-72016-004020-A	< 1	FT-72016-004020-B	< 1
18	CLEVELAND ELEMENTARY SCHOOL	WS- 004022	8/12/2016	2	Fountain	In classroom 216 Right	FT-72016-004022-A	< 1	FT-72016-004022-B	< 1
19	CLEVELAND ELEMENTARY SCHOOL	WS- 004024	8/12/2016	2	Fountain	In classroom 218	FT-72016-004024-A	< 1	FT-72016-004024-B	< 1
20	CLEVELAND ELEMENTARY SCHOOL	WS- 004026	8/12/2016	2	Fountain	In classroom 201	FT-72016-004026-A	< 1	FT-72016-004026-B	< 1
21	CLEVELAND ELEMENTARY SCHOOL	WS- 004028	8/12/2016	2	Fountain	In classroom 203	FT-72016-004028-A	< 1	FT-72016-004028-B	< 1
22	CLEVELAND ELEMENTARY SCHOOL	WS- 004029	8/12/2016	3	Cooler	In hallway adjacent to south stairwell High Left	FT-72016-004029-A	< 1	FT-72016-004029-B	< 1
23	CLEVELAND ELEMENTARY SCHOOL	WS- 004030	8/12/2016	3	Cooler	In hallway adjacent to south stairwell Low Right	FT-72016-004030-A	< 1	FT-72016-004030-B	< 1
24	CLEVELAND ELEMENTARY SCHOOL	WS- 004035	8/12/2016	3	Fountain	In classroom 304	FT-72016-004035-A	< 1	FT-72016-004035-B	< 1
25	CLEVELAND ELEMENTARY SCHOOL	WS- 004037	8/12/2016	3	Fountain	In classroom 308	FT-72016-004037-A	< 1	FT-72016-004037-B	< 1
26	CLEVELAND ELEMENTARY SCHOOL	WS- 004039	8/12/2016	3	Fountain	In staff lounge 313	FT-72016-004039-A	< 1	FT-72016-004039-B	< 1
27	CLEVELAND ELEMENTARY SCHOOL	WS- 004041	8/12/2016	3	Fountain	In classroom 302	FT-72016-004041-A	< 1	FT-72016-004041-B	< 1
28	CLEVELAND ELEMENTARY SCHOOL	WS- 004043	8/12/2016	3	Fountain	In classroom 301	FT-72016-004043-A	< 1	FT-72016-004043-B	< 1
29	CLEVELAND ELEMENTARY SCHOOL	WS- 004045	8/12/2016	3	Fountain	In classroom 315	FT-72016-004045-A	< 1	FT-72016-004045-B	< 1
30	CLEVELAND ELEMENTARY SCHOOL	WS- 004047	8/12/2016	1	Fountain	In classroom 103	FT-72016-004047-A	< 1	FT-72016-004047-B	< 1
31	CLEVELAND ELEMENTARY SCHOOL	WS- 004049	8/12/2016	2	Fountain	In classroom 216 Left	FT-72016-004049-A	< 1	FT-72016-004049-B	< 1
32	CLEVELAND ELEMENTARY SCHOOL	WS- 004051	8/12/2016	2	Fountain	In classroom 216 Right	FT-72016-004051-A	< 1	FT-72016-004051-B	< 1