



# CLEVELAND LEAD WATER TEST RESULTS

May 15, 2016



	Building Location	Sample Collected Date	Water Source ID	Device Type	Floor	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)	Remediation	Retest Date	Retest 1st Draw	Retest 2nd Draw
1	CLEVELAND ELEMENTARY SCHOOL	5/5/2016	WS-004051	Fountain	2	In classroom 216 south wall	Right	WT-042916-4068-A	2	WT-042916-4068-B	< 1			
2	CLEVELAND ELEMENTARY SCHOOL	5/5/2016	WS-004050	Classroom	2	In classroom 216 south wall	Right	WT-042916-4067-A	< 1	WT-042916-4067-B	< 1			
3	CLEVELAND ELEMENTARY SCHOOL	5/5/2016	WS-004049	Fountain	2	In classroom 216 south wall	Left	WT-042916-4066-A	3	WT-042916-4066-B	< 1			
4	CLEVELAND ELEMENTARY SCHOOL	5/5/2016	WS-004048	Classroom	2	In classroom 216 south wall	Left	WT-042916-4065-A	< 1	WT-042916-4065-B	< 1			
5	CLEVELAND ELEMENTARY SCHOOL	5/5/2016	WS-004047	Fountain	1	In classroom 103		WT-042916-4064-A	< 1	WT-042916-4064-B	< 1			
6	CLEVELAND ELEMENTARY SCHOOL	5/5/2016	WS-004046	Classroom	1	In classroom 103		WT-042916-4063-A	13	WT-042916-4063-B	< 1			
7	CLEVELAND ELEMENTARY SCHOOL	5/5/2016	WS-004045	Fountain	3	In classroom 315		WT-042916-4062-A	< 1	WT-042916-4062-B	< 1			
8	CLEVELAND ELEMENTARY SCHOOL	5/5/2016	WS-004044	Classroom	3	In classroom 315		WT-042916-4061-A	< 1	WT-042916-4061-B	< 1			
9	CLEVELAND ELEMENTARY SCHOOL	5/5/2016	WS-004043	Fountain	3	In classroom 301		WT-042916-4060-A	< 1	WT-042916-4060-B	< 1			
10	CLEVELAND ELEMENTARY SCHOOL	5/5/2016	WS-004042	Classroom	3	In classroom 301		WT-042916-4059-A	< 1	WT-042916-4059-B	< 1			
11	CLEVELAND ELEMENTARY SCHOOL	5/5/2016	WS-004041	Fountain	3	In classroom 302		WT-042916-4058-A	< 1	WT-042916-4058-B	< 1			
12	CLEVELAND ELEMENTARY SCHOOL	5/5/2016	WS-004040	Classroom	3	In classroom 302		WT-042916-4057-A	< 1	WT-042916-4057-B	< 1			
13	CLEVELAND ELEMENTARY SCHOOL	5/5/2016	WS-004039	Fountain	3	In classroom 313		WT-042916-4056-A	< 1	WT-042916-4056-B	< 1			
14	CLEVELAND ELEMENTARY SCHOOL	5/5/2016	WS-004038	Classroom	3	In classroom 313		WT-042916-4055-A	< 1	WT-042916-4055-B	< 1			
15	CLEVELAND ELEMENTARY SCHOOL	5/5/2016	WS-004037	Fountain	3	In classroom 308		WT-042916-4054-A	< 1	WT-042916-4054-B	< 1			
16	CLEVELAND ELEMENTARY SCHOOL	5/5/2016	WS-004036	Classroom	3	In classroom 308		WT-042916-4053-A	< 1	WT-042916-4053-B	< 1			
17	CLEVELAND ELEMENTARY SCHOOL	5/5/2016	WS-004035	Fountain	3	In classroom 304		WT-042916-4052-A	< 1	WT-042916-4052-B	< 1			
18	CLEVELAND ELEMENTARY SCHOOL	5/5/2016	WS-004034	Classroom	3	In classroom 304		WT-042916-4051-A	< 1	WT-042916-4051-B	< 1			
19	CLEVELAND ELEMENTARY SCHOOL	5/5/2016	WS-004033	Classroom	3	In classroom 307	Left	WT-042916-4050-A	< 1	WT-042916-4050-B	< 1			
20	CLEVELAND ELEMENTARY SCHOOL	5/5/2016	WS-004032	Classroom	3	In classroom 307	Mid	WT-042916-4049-A	< 1	WT-042916-4049-B	< 1			
21	CLEVELAND ELEMENTARY SCHOOL	5/5/2016	WS-004031	Classroom	3	In classroom 307	Right	WT-042916-4048-A	< 1	WT-042916-4048-B	< 1			
22	CLEVELAND ELEMENTARY SCHOOL	5/5/2016	WS-004030	Cooler	3	In hallway adjacent to south stairs	Right Low	WT-042916-4047-A	< 1	WT-042916-4047-B	< 1			
23	CLEVELAND ELEMENTARY SCHOOL	5/5/2016	WS-004029	Cooler	3	In hallway adjacent to south stairs	Left High	WT-042916-4046-A	< 1	WT-042916-4046-B	< 1			
24	CLEVELAND ELEMENTARY SCHOOL	5/5/2016	WS-004028	Fountain	2	In classroom 203		WT-042916-4045-A	4	WT-042916-4045-B	< 1			
25	CLEVELAND ELEMENTARY SCHOOL	5/5/2016	WS-004027	Classroom	2	In classroom 203		WT-042916-4044-A	< 1	WT-042916-4044-B	< 1			
26	CLEVELAND ELEMENTARY SCHOOL	5/5/2016	WS-004026	Fountain	2	In classroom 201		WT-042916-4043-A	< 1	WT-042916-4043-B	< 1			
27	CLEVELAND ELEMENTARY SCHOOL	5/5/2016	WS-004025	Fountain	2	In classroom 201		WT-042916-4042-A	< 1	WT-042916-4042-B	< 1			
28	CLEVELAND ELEMENTARY SCHOOL	5/5/2016	WS-004024	Fountain	2	In classroom 218		WT-042916-4041-A	< 1	WT-042916-4041-B	< 1			
29	CLEVELAND ELEMENTARY SCHOOL	5/5/2016	WS-004023	Classroom	2	In classroom 218		WT-042916-4040-A	< 1	WT-042916-4040-B	< 1			
30	CLEVELAND ELEMENTARY SCHOOL	5/5/2016	WS-004022	Fountain	2	In classroom 216 north wall	Right	WT-042916-4039-A	3	WT-042916-4039-B	< 1			
31	CLEVELAND ELEMENTARY SCHOOL	5/5/2016	WS-004021	Classroom	2	In classroom 216 north wall	Right	WT-042916-4038-A	< 1	WT-042916-4038-B	< 1			
32	CLEVELAND ELEMENTARY SCHOOL	5/5/2016	WS-004020	Fountain	2	In classroom 216 north wall	Left	WT-042916-4037-A	2	WT-042916-4037-B	< 1			
33	CLEVELAND ELEMENTARY SCHOOL	5/5/2016	WS-004019	Classroom	2	In classroom 216 north wall	Left	WT-042916-4036-A	< 1	WT-042916-4036-B	< 1			
34	CLEVELAND ELEMENTARY SCHOOL	5/5/2016	WS-004018	Fountain	2	In classroom 212		WT-042916-4035-A	< 1	WT-042916-4035-B	< 1			
35	CLEVELAND ELEMENTARY SCHOOL	5/5/2016	WS-004017	Classroom	2	In classroom 212		WT-042916-4034-A	< 1	WT-042916-4034-B	< 1			
36	CLEVELAND ELEMENTARY SCHOOL	5/5/2016	WS-004016	Fountain	2	In classroom 207		WT-042916-4033-A	< 1	WT-042916-4033-B	< 1			
37	CLEVELAND ELEMENTARY SCHOOL	5/5/2016	WS-004015	Classroom	2	In classroom 207		WT-042916-4032-A	< 1	WT-042916-4032-B	5			
38	CLEVELAND ELEMENTARY SCHOOL	5/5/2016	WS-004014	Cooler	2	In hallway adjacent to south stairs	Right Low	WT-042916-4031-A	< 1	WT-042916-4031-B	< 1			
39	CLEVELAND ELEMENTARY SCHOOL	5/5/2016	WS-004013	Fountain	1	In classroom 101		WT-042916-4030-A	< 1	WT-042916-4030-B	< 1			
40	CLEVELAND ELEMENTARY SCHOOL	5/5/2016	WS-004012	Classroom	1	In classroom 101		WT-042916-4029-A	< 1	WT-042916-4029-B	< 1			
41	CLEVELAND ELEMENTARY SCHOOL	5/5/2016	WS-004011	Cooler	2	In hallway adjacent to south stairs	Left High	WT-042916-4028-A	< 1	WT-042916-4028-B	< 1			
42	CLEVELAND ELEMENTARY SCHOOL	5/5/2016	WS-004010	Fountain	1	In classroom 120		WT-042916-4027-A	< 1	WT-042916-4027-B	< 1			
43	CLEVELAND ELEMENTARY SCHOOL	5/5/2016	WS-004009	Classroom	1	In classroom 120		WT-042916-4026-A	99	WT-042916-4026-B	15	Filter will be installed and then retested		
44	CLEVELAND ELEMENTARY SCHOOL	5/5/2016	WS-004008	Fountain	1	In classroom 117		WT-042916-4025-A	< 1	WT-042916-4025-B	< 1			
45	CLEVELAND ELEMENTARY SCHOOL	5/5/2016	WS-004007	Classroom	1	In classroom 117		WT-042916-4024-A	4	WT-042916-4024-B	< 1			
46	CLEVELAND ELEMENTARY SCHOOL	5/5/2016	WS-004006	Fountain	1	In classroom 115		WT-042916-4023-A	< 1	WT-042916-4023-B	< 1			
47	CLEVELAND ELEMENTARY SCHOOL	5/5/2016	WS-004005	Classroom	1	In classroom 115		WT-042916-4022-A	< 1	WT-042916-4022-B	< 1			
48	CLEVELAND ELEMENTARY SCHOOL	5/5/2016	WS-004004	Fountain	1	In classroom 111		WT-042916-4021-A	1	WT-042916-4021-B	< 1			
49	CLEVELAND ELEMENTARY SCHOOL	5/5/2016	WS-004003	Classroom	1	In room 106		WT-042916-4020-A	< 1	WT-042916-4020-B	< 1			
50	CLEVELAND ELEMENTARY SCHOOL	5/5/2016	WS-004002	Classroom	1	In room 111		WT-042916-4019-A	< 1	WT-042916-4019-B	< 1			
51	CLEVELAND ELEMENTARY SCHOOL	5/5/2016	WS-004001	Fountain	1	In classroom 106		WT-042916-4018-A	< 1	WT-042916-4018-B	< 1			
52	CLEVELAND ELEMENTARY SCHOOL	5/5/2016	WS-004000	Cooler	1	In hallway adjacent to south stairs	Right Low	WT-042916-4017-A	< 1	WT-042916-4017-B	< 1			
53	CLEVELAND ELEMENTARY SCHOOL	5/5/2016	WS-003999	Cooler	1	In hallway adjacent to south stairs	Left High	WT-042916-4016-A	< 1	WT-042916-4016-B	< 1			
54	CLEVELAND ELEMENTARY SCHOOL	5/5/2016	WS-003998	Classroom	Ground Floor	In room G17		WT-042916-4015-A	< 1	WT-042916-4015-B	< 1			
55	CLEVELAND ELEMENTARY SCHOOL	5/5/2016	WS-003997	Kitchen	Ground Floor	In kitchen east wall	Right	WT-042916-4014-A	< 1	WT-042916-4014-B	< 1			
56	CLEVELAND ELEMENTARY SCHOOL	5/5/2016	WS-003996	Kitchen	Ground Floor	In kitchen east wall	Left	WT-042916-4013-A	< 1	WT-042916-4013-B	< 1			
57	CLEVELAND ELEMENTARY SCHOOL	5/5/2016	WS-003995	Other	Ground Floor	In kitchen (spray nozzle)		WT-042916-4012-A	1	WT-042916-4012-B	< 1			
58	CLEVELAND ELEMENTARY SCHOOL	5/5/2016	WS-003994	Cooler	Ground Floor	In hallway adjacent to G31	Right Low	WT-042916-4011-A	< 1	WT-042916-4011-B	< 1			
59	CLEVELAND ELEMENTARY SCHOOL	5/5/2016	WS-003993	Cooler	Ground Floor	In hallway adjacent to G31	Left High	WT-042916-4010-A	< 1	WT-042916-4010-B	< 1			
60	CLEVELAND ELEMENTARY SCHOOL	5/5/2016	WS-003992	Health Suite	Ground Floor	In G07 in unisex restroom		WT-042916-4009-A	< 1	WT-042916-4009-B	< 1			



# CLEVELAND LEAD WATER TEST RESULTS

May 15, 2016



Building Location	Sample Collected Date	Water Source ID	Device Type	Floor	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)	Remediation	Retest Date	Retest 1st Draw	Retest 2nd Draw
61 CLEVELAND ELEMENTARY SCHOOL	5/5/2016	WS-003991	Utility	Ground Floor	Main water supply in G01 in the sprinkler room left side door	WT-042916-4008- A	13	WT-042916-4008- B	< 1				

Footnotes:

A - First draw sample is collected after the plumbing system has not been used for at least 6 hours.

B - Second draw sample is collected after a 60 second flush at that device after the first draw.