



CLEVELAND ES LEAD WATER TEST RESULTS



Initial Filter Test After Installation

Less than 1 ppb - Device Returned to Service										
	Building Location: Building Name	Water Source ID	Date Analyzed	Floor	Device Type	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	Final Result - 2nd Draw (ppb)
1	CLEVELAND ELEMENTARY SCHOOL	WS- 004036	1/11/2017	3	Combo Faucet	In classroom 308	FT-112016-004036-A	< 1	FT-112016-004036-B	< 1
2	CLEVELAND ELEMENTARY SCHOOL	WS- 004034	1/11/2017	3	Combo Faucet	In classroom 304	FT-112016-004034-A	< 1	FT-112016-004034-B	< 1
3	CLEVELAND ELEMENTARY SCHOOL	WS- 004050	1/11/2017	2	Combo Faucet	In classroom 216 Right	FT-112016-004050-A	< 1	FT-112016-004050-B	< 1
4	CLEVELAND ELEMENTARY SCHOOL	WS- 004023	1/7/2017	2	Combo Faucet	In classroom 218	FT-112016-004023-A	< 1	FT-112016-004023-B	< 1
5	CLEVELAND ELEMENTARY SCHOOL	WS- 004025	1/7/2017	2	Combo Faucet	In classroom 201	FT-112016-004025-A	< 1	FT-112016-004025-B	< 1
6	CLEVELAND ELEMENTARY SCHOOL	WS- 004017	1/7/2017	2	Combo Faucet	In classroom 212	FT-112016-004017-A	< 1	FT-112016-004017-B	< 1
7	CLEVELAND ELEMENTARY SCHOOL	WS- 004272	1/11/2017	1	Bathroom	In classroom 111 in bathroom	FT-112016-004272-A	< 1	FT-112016-004272-B	< 1
8	CLEVELAND ELEMENTARY SCHOOL	WS- 004042	1/11/2017	3	Combo Faucet	In classroom 301	FT-112016-004042-A	< 1	FT-112016-004042-B	< 1
9	CLEVELAND ELEMENTARY SCHOOL	WS- 004019	1/7/2017	2	Combo Faucet	In classroom 216 Left	FT-112016-004019-A	< 1	FT-112016-004019-B	< 1
10	CLEVELAND ELEMENTARY SCHOOL	WS- 004048	1/11/2017	2	Combo Faucet	In classroom 216 Left	FT-112016-004048-A	< 1	FT-112016-004048-B	< 1
11	CLEVELAND ELEMENTARY SCHOOL	WS- 004015	1/7/2017	2	Combo Faucet	In classroom 207	FT-112016-004015-A	< 1	FT-112016-004015-B	< 1
12	CLEVELAND ELEMENTARY SCHOOL	WS- 004044	1/11/2017	3	Combo Faucet	In classroom 315	FT-112016-004044-A	< 1	FT-112016-004044-B	< 1
13	CLEVELAND ELEMENTARY SCHOOL	WS- 004021	1/7/2017	2	Combo Faucet	In classroom 216 Right	FT-112016-004021-A	< 1	FT-112016-004021-B	< 1
14	CLEVELAND ELEMENTARY SCHOOL	WS- 004002	1/7/2017	1	Combo Faucet	In classroom 111	FT-112016-004002-A	< 1	FT-112016-004002-B	< 1
15	CLEVELAND ELEMENTARY SCHOOL	WS- 004040	1/11/2017	3	Combo Faucet	In classroom 302	FT-112016-004040-A	< 1	FT-112016-004040-B	< 1
16	CLEVELAND ELEMENTARY SCHOOL	WS- 004038	1/11/2017	3	Break Room	In staff lounge 313	FT-112016-004038-A	< 1	FT-112016-004038-B	< 1
17	CLEVELAND ELEMENTARY SCHOOL	WS- 004273	1/11/2017	1	Bathroom	In classroom 115 in bathroom	FT-112016-004273-A	< 1	FT-112016-004273-B	< 1
18	CLEVELAND ELEMENTARY SCHOOL	WS- 004005	1/7/2017	1	Combo Faucet	In classroom 115	FT-112016-004005-A	< 1	FT-112016-004005-B	< 1
19	CLEVELAND ELEMENTARY SCHOOL	WS- 004271	1/11/2017	1	Bathroom	In classroom 106 in bathroom	FT-112016-004271-A	< 1	FT-112016-004271-B	< 1
20	CLEVELAND ELEMENTARY SCHOOL	WS- 004003	1/7/2017	1	Combo Faucet	In classroom 106	FT-112016-004003-A	< 1	FT-112016-004003-B	< 1
21	CLEVELAND ELEMENTARY SCHOOL	WS- 004275	1/11/2017	1	Bathroom	In classroom 120 in bathroom	FT-112016-004275-A	< 1	FT-112016-004275-B	< 1
22	CLEVELAND ELEMENTARY SCHOOL	WS- 004270	1/11/2017	1	Bathroom	In classroom 103 in bathroom	FT-112016-004270-A	< 1	FT-112016-004270-B	< 1
23	CLEVELAND ELEMENTARY SCHOOL	WS- 004269	1/11/2017	1	Bathroom	In classroom 101 in bathroom	FT-112016-004269-A	< 1	FT-112016-004269-B	< 1
24	CLEVELAND ELEMENTARY SCHOOL	WS- 004007	1/7/2017	1	Combo Faucet	In classroom 117	FT-112016-004007-A	< 1	FT-112016-004007-B	< 1
25	CLEVELAND ELEMENTARY SCHOOL	WS- 004012	1/7/2017	1	Combo Faucet	In classroom 101	FT-112016-004012-A	< 1	FT-112016-004012-B	< 1
26	CLEVELAND ELEMENTARY SCHOOL	WS- 004046	1/11/2017	1	Combo Faucet	In classroom 103	FT-112016-004046-A	< 1	FT-112016-004046-B	< 1
27	CLEVELAND ELEMENTARY SCHOOL	WS- 004274	1/11/2017	1	Bathroom	In classroom 117 in bathroom	FT-112016-004274-A	< 1	FT-112016-004274-B	< 1

Greater than 1 ppb - Devices Shut Off and Corrective Action Taken										
1	CLEVELAND ELEMENTARY SCHOOL	WS- 004027	1/7/2017	2	Combo Faucet	In classroom 203	FT-112016-004027-A	< 1	FT-112016-004027-B	1.4
2	CLEVELAND ELEMENTARY SCHOOL	WS- 004009	1/7/2017	1	Combo Faucet	In classroom 120	FT-112016-004009-A	1.4	FT-112016-004009-B	< 1

Note :

Filter re-tests are only performed to devices that have sampling results greater than 1 ppb

First Filter Re-Test (After Filter and Plumbing Check with Aerator Replacement)

Less than 1 ppb - Device Returned to Service										
1	CLEVELAND ELEMENTARY SCHOOL	WS- 004027	2/8/2017	2	Combo Faucet	In classroom 203	FT-112016-004027-A	< 1	FT-112016-004027-B	< 1

Greater than 1 ppb - Devices Remain Shut off, Continued Remediation										
1	CLEVELAND ELEMENTARY SCHOOL	WS- 004009	2/8/2017	1	Combo Faucet	In classroom 120	FT-112016-004009-A	3.9	FT-112016-004009-B	< 1

Second Filter Re-Test (After Device Replacement)

Greater than 1 ppb - Devices Remain Shut off, Continued Remediation										
1	CLEVELAND ELEMENTARY SCHOOL	WS- 004009	3/14/2017	1	Combo Faucet	In classroom 120	FT-112016-004009-A	2.8	FT-112016-004009-B	< 1

Note :

Filter re-tests are only performed to devices that have sampling results greater than 1 ppb