



Cleveland ES Lead Water Test Results



FY19 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 003992	4/11/2018	4/11/2019	Ground Floor	Health Suite	In health suite G07 in unisex restroom	WF-04112018-003992	11/21/2018	FT-FY19-112018-003992-A	< 1	FT-FY19-112018-003992-B	< 1
WS- 003993	7/20/2018	7/20/2019	Ground Floor	Cooler	In hallway adjacent to room G31 High Left	WF-07202018-003993	11/21/2018	FT-FY19-112018-003993-A	< 1	FT-FY19-112018-003993-B	< 1
WS- 003994	7/20/2018	7/20/2019	Ground Floor	Cooler	In hallway adjacent to room G32 Low Right	WF-07202018-003994	11/21/2018	FT-FY19-112018-003994-A	< 1	FT-FY19-112018-003994-B	< 1
WS- 003998	11/9/2018	11/9/2019	Ground Floor	Break Room	In conference room G17	WF-11092018-003998	11/21/2018	FT-FY19-112018-003998-A	< 1	FT-FY19-112018-003998-B	< 1
WS- 003999	7/20/2018	7/20/2019	1	Cooler	In hallway adjacent to south stairwell High Left	WF-07202018-003999	11/21/2018	FT-FY19-112018-003999-A	< 1	FT-FY19-112018-003999-B	< 1
WS- 004000	7/20/2018	7/20/2019	1	Cooler	In hallway adjacent to south stairwell Low Right	WF-07202018-004000	11/21/2018	FT-FY19-112018-004000-A	< 1	FT-FY19-112018-004000-B	< 1
WS- 004001	4/11/2018	4/11/2019	1	Combo Fountain	In classroom 106	WF-04112018-004001	11/21/2018	FT-FY19-112018-004001-A	< 1	FT-FY19-112018-004001-B	< 1
WS- 004002	9/19/2018	9/19/2019	1	Combo Faucet	In classroom 111	WF-09192018-004002	11/21/2018	FT-FY19-112018-004002-A	< 1	FT-FY19-112018-004002-B	< 1
WS- 004003	9/19/2018	9/19/2019	1	Combo Faucet	In classroom 106	WF-09192018-004003	11/21/2018	FT-FY19-112018-004003-A	< 1	FT-FY19-112018-004003-B	< 1
WS- 004004	4/11/2018	4/11/2019	1	Combo Fountain	In classroom 111	WF-04112018-004004	11/21/2018	FT-FY19-112018-004004-A	< 1	FT-FY19-112018-004004-B	< 1
WS- 004005	9/19/2018	9/19/2019	1	Combo Faucet	In classroom 115	WF-09192018-004005	11/21/2018	FT-FY19-112018-004005-A	< 1	FT-FY19-112018-004005-B	< 1
WS- 004006	4/11/2018	4/11/2019	1	Combo Fountain	In classroom 115	WF-04112018-004006	11/21/2018	FT-FY19-112018-004006-A	< 1	FT-FY19-112018-004006-B	< 1
WS- 004007	9/19/2018	9/19/2019	1	Combo Faucet	In classroom 117	WF-09192018-004007	11/21/2018	FT-FY19-112018-004007-A	< 1	FT-FY19-112018-004007-B	< 1
WS- 004008	4/11/2018	4/11/2019	1	Combo Fountain	In classroom 117	WF-04112018-004008	11/21/2018	FT-FY19-112018-004008-A	< 1	FT-FY19-112018-004008-B	< 1
WS- 004009	9/19/2018	9/19/2019	1	Combo Faucet	In classroom 120	WF-09192018-004009	11/21/2018	FT-FY19-112018-004009-A	< 1	FT-FY19-112018-004009-B	< 1
WS- 004010	4/11/2018	4/11/2019	1	Combo Fountain	In classroom 120	WF-04112018-004010	11/21/2018	FT-FY19-112018-004010-A	< 1	FT-FY19-112018-004010-B	< 1
WS- 004011	7/20/2018	7/20/2019	2	Cooler	In hallway adjacent to south stairwell High Left	WF-07202018-004011	11/21/2018	FT-FY19-112018-004011-A	< 1	FT-FY19-112018-004011-B	< 1
WS- 004012	9/19/2018	9/19/2019	1	Combo Faucet	In classroom 101	WF-09192018-004012	11/21/2018	FT-FY19-112018-004012-A	< 1	FT-FY19-112018-004012-B	< 1
WS- 004013	4/11/2018	4/11/2019	1	Combo Fountain	In classroom 101	WF-04112018-004013	11/21/2018	FT-FY19-112018-004013-A	< 1	FT-FY19-112018-004013-B	< 1
WS- 004014	7/20/2018	7/20/2019	2	Cooler	In hallway adjacent to south stairwell Low Right	WF-07202018-004014	11/21/2018	FT-FY19-112018-004014-A	< 1	FT-FY19-112018-004014-B	< 1
WS- 004015	9/19/2018	9/19/2019	2	Combo Faucet	In classroom 207	WF-09192018-004015	11/21/2018	FT-FY19-112018-004015-A	< 1	FT-FY19-112018-004015-B	< 1
WS- 004016	4/11/2018	4/11/2019	2	Combo Fountain	In classroom 207	WF-04112018-004016	11/21/2018	FT-FY19-112018-004016-A	< 1	FT-FY19-112018-004016-B	< 1
WS- 004017	9/19/2018	9/19/2019	2	Combo Faucet	In classroom 212	WF-09192018-004017	11/21/2018	FT-FY19-112018-004017-A	< 1	FT-FY19-112018-004017-B	< 1
WS- 004018	4/11/2018	4/11/2019	2	Combo Fountain	In classroom 212	WF-04112018-004018	11/21/2018	FT-FY19-112018-004018-A	< 1	FT-FY19-112018-004018-B	< 1
WS- 004019	9/19/2018	9/19/2019	2	Combo Faucet	In classroom 216 Left	WF-09192018-004019	11/21/2018	FT-FY19-112018-004019-A	< 1	FT-FY19-112018-004019-B	< 1
WS- 004020	4/11/2018	4/11/2019	2	Combo Fountain	In classroom 216 Left	WF-04112018-004020	11/21/2018	FT-FY19-112018-004020-A	< 1	FT-FY19-112018-004020-B	< 1
WS- 004021	9/19/2018	9/19/2019	2	Combo Faucet	In classroom 216 Right	WF-09192018-004021	11/21/2018	FT-FY19-112018-004021-A	1.4	FT-FY19-112018-004021-B	1.3
WS- 004022	4/11/2018	4/11/2019	2	Combo Fountain	In classroom 216 Right	WF-04112018-004022	11/21/2018	FT-FY19-112018-004022-A	1	FT-FY19-112018-004022-B	< 1
WS- 004023	9/19/2018	9/19/2019	2	Combo Faucet	In classroom 218	WF-09192018-004023	11/21/2018	FT-FY19-112018-004023-A	< 1	FT-FY19-112018-004023-B	< 1

WS- 004024	4/11/2018	4/11/2019	2	Combo Fountain	In classroom 218		WF-04112018-004024	11/21/2018	FT-FY19-112018-004024-A	< 1	FT-FY19-112018-004024-B	< 1
WS- 004025	9/19/2018	9/19/2019	2	Combo Faucet	In classroom 201		WF-09192018-004025	11/21/2018	FT-FY19-112018-004025-A	< 1	FT-FY19-112018-004025-B	< 1
WS- 004026	4/11/2018	4/11/2019	2	Combo Fountain	In classroom 201		WF-04112018-004026	11/21/2018	FT-FY19-112018-004026-A	< 1	FT-FY19-112018-004026-B	< 1
WS- 004027	9/19/2018	9/19/2019	2	Combo Faucet	In classroom 203		WF-09192018-004027	11/21/2018	FT-FY19-112018-004027-A	< 1	FT-FY19-112018-004027-B	< 1
WS- 004028	4/11/2018	4/11/2019	2	Combo Fountain	In classroom 203		WF-04112018-004028	11/21/2018	FT-FY19-112018-004028-A	< 1	FT-FY19-112018-004028-B	< 1
WS- 004029	7/20/2018	7/20/2019	3	Cooler	In hallway adjacent to south stairwell	High Left	WF-07202018-004029	11/21/2018	FT-FY19-112018-004029-A	< 1	FT-FY19-112018-004029-B	< 1
WS- 004030	7/20/2018	7/20/2019	3	Cooler	In hallway adjacent to south stairwell	Low Right	WF-07202018-004030	11/21/2018	FT-FY19-112018-004030-A	< 1	FT-FY19-112018-004030-B	< 1
WS- 004034	9/19/2018	9/19/2019	3	Combo Faucet	In classroom 304		WF-09192018-004034	11/21/2018	FT-FY19-112018-004034-A	< 1	FT-FY19-112018-004034-B	< 1
WS- 004035	4/11/2018	4/11/2019	3	Combo Fountain	In classroom 304		WF-04112018-004035	11/21/2018	FT-FY19-112018-004035-A	< 1	FT-FY19-112018-004035-B	< 1
WS- 004036	9/19/2018	9/19/2019	3	Combo Faucet	In classroom 308		WF-09192018-004036	11/21/2018	FT-FY19-112018-004036-A	< 1	FT-FY19-112018-004036-B	< 1
WS- 004037	4/11/2018	4/11/2019	3	Combo Fountain	In classroom 308		WF-04112018-004037	11/21/2018	FT-FY19-112018-004037-A	< 1	FT-FY19-112018-004037-B	< 1
WS- 004038	4/11/2018	4/11/2019	3	Break Room	In staff lounge 313		WF-04112018-004038	11/21/2018	FT-FY19-112018-004038-A	< 1	FT-FY19-112018-004038-B	< 1
WS- 004039	4/11/2018	4/11/2019	3	Combo Fountain	In staff lounge 313		WF-04112018-004039	11/21/2018	FT-FY19-112018-004039-A	< 1	FT-FY19-112018-004039-B	< 1
WS- 004040	9/19/2018	9/19/2019	3	Combo Faucet	In classroom 302		WF-09192018-004040	11/21/2018	FT-FY19-112018-004040-A	< 1	FT-FY19-112018-004040-B	< 1
WS- 004041	4/11/2018	4/11/2019	3	Combo Fountain	In classroom 302		WF-04112018-004041	11/21/2018	FT-FY19-112018-004041-A	< 1	FT-FY19-112018-004041-B	< 1
WS- 004042	9/19/2018	9/19/2019	3	Combo Faucet	In classroom 301		WF-09192018-004042	11/21/2018	FT-FY19-112018-004042-A	< 1	FT-FY19-112018-004042-B	< 1
WS- 004043	4/11/2018	4/11/2019	3	Combo Fountain	In classroom 301		WF-04112018-004043	11/21/2018	FT-FY19-112018-004043-A	< 1	FT-FY19-112018-004043-B	< 1
WS- 004044	9/19/2018	9/19/2019	3	Combo Faucet	In classroom 315		WF-09192018-004044	11/21/2018	FT-FY19-112018-004044-A	< 1	FT-FY19-112018-004044-B	< 1
WS- 004045	4/11/2018	4/11/2019	3	Combo Fountain	In classroom 315		WF-04112018-004045	11/21/2018	FT-FY19-112018-004045-A	< 1	FT-FY19-112018-004045-B	< 1
WS- 004046	9/19/2018	9/19/2019	1	Combo Faucet	In classroom 103		WF-09192018-004046	11/21/2018	FT-FY19-112018-004046-A	< 1	FT-FY19-112018-004046-B	< 1
WS- 004047	4/11/2018	4/11/2019	1	Combo Fountain	In classroom 103		WF-04112018-004047	11/21/2018	FT-FY19-112018-004047-A	< 1	FT-FY19-112018-004047-B	< 1
WS- 004048	9/19/2018	9/19/2019	2	Combo Faucet	In classroom 216	Left	WF-09192018-004048	11/21/2018	FT-FY19-112018-004048-A	< 1	FT-FY19-112018-004048-B	< 1
WS- 004049	4/11/2018	4/11/2019	2	Combo Fountain	In classroom 216	Left	WF-04112018-004049	11/21/2018	FT-FY19-112018-004049-A	< 1	FT-FY19-112018-004049-B	< 1
WS- 004050	9/19/2018	9/19/2019	2	Combo Faucet	In classroom 216	Right	WF-09192018-004050	11/21/2018	FT-FY19-112018-004050-A	< 1	FT-FY19-112018-004050-B	< 1
WS- 004051	4/11/2018	4/11/2019	2	Combo Fountain	In classroom 216	Right	WF-04112018-004051	11/21/2018	FT-FY19-112018-004051-A	< 1	FT-FY19-112018-004051-B	< 1
WS- 004269	9/19/2018	9/19/2019	1	Bathroom	In classroom 101 in bathroom		WF-09192018-004269	11/21/2018	FT-FY19-112018-004269-A	< 1	FT-FY19-112018-004269-B	< 1
WS- 004270	9/19/2018	9/19/2019	1	Bathroom	In classroom 103 in bathroom		WF-09192018-004270	11/21/2018	FT-FY19-112018-004270-A	< 1	FT-FY19-112018-004270-B	< 1
WS- 004271	9/19/2018	9/19/2019	1	Bathroom	In classroom 106 in bathroom		WF-09192018-004271	11/21/2018	FT-FY19-112018-004271-A	< 1	FT-FY19-112018-004271-B	< 1
WS- 004272	9/19/2018	9/19/2019	1	Bathroom	In classroom 111 in bathroom		WF-09192018-004272	11/21/2018	FT-FY19-112018-004272-A	< 1	FT-FY19-112018-004272-B	< 1
WS- 004273	9/19/2018	9/19/2019	1	Bathroom	In classroom 115 in bathroom		WF-09192018-004273	11/21/2018	FT-FY19-112018-004273-A	< 1	FT-FY19-112018-004273-B	< 1
WS- 004274	9/19/2018	9/19/2019	1	Bathroom	In classroom 117 in bathroom		WF-09192018-004274	11/21/2018	FT-FY19-112018-004274-A	< 1	FT-FY19-112018-004274-B	< 1
WS- 004275	9/19/2018	9/19/2019	1	Bathroom	In classroom 120 in bathroom		WF-09192018-004275	11/21/2018	FT-FY19-112018-004275-A	< 1	FT-FY19-112018-004275-B	< 1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation

Record ID	Floor	Device Type	Device Location	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 003997	Ground Floor	Food Prep Sink	In kitchen east wall Right	11/21/2018	FT-FY19-112018-003997-A	< 1	FT-FY19-112018-003997-B	< 1