



Columbia Heights EC Lead in Water Test Results



FY20 Filter Test

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS- 002335	3/18/2019	3/18/2020	1	Health Suite	In health suite A138	WF-03182019-002335	12/30/2019	FT-FY20-122019-002335-A	<1	FT-FY20-122019-002335-B	<1	
WS- 008021	10/16/2019	10/16/2020	1	Classroom Faucet	In classroom E123	WF-10162019-008021	12/30/2019	FT-FY20-122019-008021-A	<1	FT-FY20-122019-008021-B	<1	
WS- 008025	10/16/2019	10/16/2020	1	Classroom Faucet	In classroom E121A first clockwise from entry door	WF-10162019-008025	12/30/2019	FT-FY20-122019-008025-A	<1	FT-FY20-122019-008025-B	<1	
WS- 008026	10/16/2019	10/16/2020	1	Classroom Faucet	In classroom E121A second clockwise from entry door	WF-10162019-008026	12/30/2019	FT-FY20-122019-008026-A	<1	FT-FY20-122019-008026-B	<1	
WS- 008027	10/16/2019	10/16/2020	1	Classroom Faucet	In classroom E121A third clockwise from entry door	WF-10162019-008027	12/30/2019	FT-FY20-122019-008027-A	<1	FT-FY20-122019-008027-B	<1	
WS- 008028	10/16/2019	10/16/2020	1	Classroom Faucet	In classroom E121A fourth clockwise from entry door	WF-10162019-008028	12/30/2019	FT-FY20-122019-008028-A	<1	FT-FY20-122019-008028-B	<1	
WS- 008029	3/18/2019	3/18/2020	1	Cooler	In hallway adjacent to room D113	High Left	WF-03182019-008029	12/30/2019	FT-FY20-122019-008029-A	<1	FT-FY20-122019-008029-B	<1
WS- 008030	3/18/2019	3/18/2020	1	Cooler	In hallway adjacent to room D113	Low Right	WF-03182019-008030	12/30/2019	FT-FY20-122019-008030-A	<1	FT-FY20-122019-008030-B	<1
WS- 008056	9/6/2019	9/6/2020	1	Cooler	In hallway adjacent to room C135	Low Left	WF-09062019-008056	12/30/2019	FT-FY20-122019-008056-A	<1	FT-FY20-122019-008056-B	<1
WS- 008057	9/6/2019	9/6/2020	1	Cooler	In hallway adjacent to room C135	High Right	WF-09062019-008057	12/30/2019	FT-FY20-122019-008057-A	<1	FT-FY20-122019-008057-B	<1
WS- 008059	3/18/2019	3/18/2020	1	Break Room	In break room C117		WF-03182019-008059	12/30/2019	FT-FY20-122019-008059-A	<1	FT-FY20-122019-008059-B	<1
WS- 008060	3/18/2019	3/18/2020	1	Break Room	In workroom C109		WF-03182019-008060	12/30/2019	FT-FY20-122019-008060-A	<1	FT-FY20-122019-008060-B	<1
WS- 008065	3/18/2019	3/18/2020	1	Break Room	In workroom A117		WF-03182019-008065	12/30/2019	FT-FY20-122019-008065-A	<1	FT-FY20-122019-008065-B	<1
WS- 008068	9/6/2019	9/6/2020	1	Cooler	In hallway across from room A146	Low Right	WF-09062019-008068	12/30/2019	FT-FY20-122019-008068-A	<1	FT-FY20-122019-008068-B	<1
WS- 008069	9/6/2019	9/6/2020	1	Cooler	In hallway across from room A146	High Left	WF-09062019-008069	12/30/2019	FT-FY20-122019-008069-A	<1	FT-FY20-122019-008069-B	<1
WS- 008100	3/18/2019	3/18/2020	2	Cooler	In hallway adjacent to room A206	High Left	WF-03182019-008100	12/30/2019	FT-FY20-122019-008100-A	<1	FT-FY20-122019-008100-B	<1
WS- 008101	9/6/2019	9/6/2020	2	Cooler	In hallway adjacent to room A206	Low Right	WF-09062019-008101	12/30/2019	FT-FY20-122019-008101-A	<1	FT-FY20-122019-008101-B	<1
WS- 008102	10/8/2019	10/8/2020	2	Cooler	In hallway adjacent to room A205	High Left	WF-10082019-008102	12/30/2019	FT-FY20-122019-008102-A	<1	FT-FY20-122019-008102-B	<1
WS- 008103	10/8/2019	10/8/2020	2	Cooler	In hallway adjacent to room A205	Low Right	WF-10082019-008103	12/30/2019	FT-FY20-122019-008103-A	<1	FT-FY20-122019-008103-B	<1
WS- 008105	3/18/2019	3/18/2020	2	Cooler	In hallway adjacent to stairwell 2	Low Left	WF-03182019-008105	12/30/2019	FT-FY20-122019-008105-A	<1	FT-FY20-122019-008105-B	<1
WS- 008106	9/6/2019	9/6/2020	2	Cooler	In hallway adjacent to stairwell 2	Low Right	WF-09062019-008106	12/30/2019	FT-FY20-122019-008106-A	<1	FT-FY20-122019-008106-B	<1
WS- 008107	9/6/2019	9/6/2020	2	Cooler	In hallway adjacent to stairwell 2	High Right	WF-09062019-008107	12/30/2019	FT-FY20-122019-008107-A	<1	FT-FY20-122019-008107-B	<1
WS- 008116	3/18/2019	3/18/2020	1	Ice Maker	In kitchen (ice maker)		WF-03182019-008116	12/30/2019	FT-FY20-122019-008116-A	<1	FT-FY20-122019-008116-B	<1
WS- 008157	3/18/2019	3/18/2020	3	Break Room	In break room C304A		WF-03182019-008157	12/30/2019	FT-FY20-122019-008157-A	<1	FT-FY20-122019-008157-B	<1
WS- 008159	10/8/2019	10/8/2020	3	Cooler	In hallway adjacent to the restrooms	High Left	WF-10082019-008159	12/30/2019	FT-FY20-122019-008159-A	<1	FT-FY20-122019-008159-B	<1
WS- 008160	10/8/2019	10/8/2020	3	Cooler	In hallway adjacent to the restrooms	Low Right	WF-10082019-008160	12/30/2019	FT-FY20-122019-008160-A	<1	FT-FY20-122019-008160-B	<1
WS- 008169	3/18/2019	3/18/2020	2	Cooler	In locker room E231	High Left	WF-03182019-008169	12/30/2019	FT-FY20-122019-008169-A	<1	FT-FY20-122019-008169-B	<1
WS- 008170	3/18/2019	3/18/2020	2	Cooler	In locker room E231	Low Right	WF-03182019-008170	12/30/2019	FT-FY20-122019-008170-A	<1	FT-FY20-122019-008170-B	<1
WS- 008171	3/18/2019	3/18/2020	2	Cooler	In girls' locker room E214	High Left	WF-03182019-008171	12/30/2019	FT-FY20-122019-008171-A	<1	FT-FY20-122019-008171-B	<1
WS- 008172	3/18/2019	3/18/2020	2	Cooler	In girls' locker room E214	Low Right	WF-03182019-008172	12/30/2019	FT-FY20-122019-008172-A	<1	FT-FY20-122019-008172-B	<1
WS- 008173	9/6/2019	9/6/2020	2	Cooler	In locker room D211	Left	WF-09062019-008173	12/30/2019	FT-FY20-122019-008173-A	<1	FT-FY20-122019-008173-B	<1
WS- 008174	9/6/2019	9/6/2020	2	Cooler	In locker room D211	Right	WF-09062019-008174	12/30/2019	FT-FY20-122019-008174-A	<1	FT-FY20-122019-008174-B	<1
WS- 008175	3/18/2019	3/18/2020	2	Cooler	In locker room D204	High Left	WF-03182019-008175	12/30/2019	FT-FY20-122019-008175-A	<1	FT-FY20-122019-008175-B	<1
WS- 008176	3/18/2019	3/18/2020	2	Cooler	In locker room D204	Low Right	WF-03182019-008176	12/30/2019	FT-FY20-122019-008176-A	<1	FT-FY20-122019-008176-B	<1
WS- 008186	9/6/2019	9/6/2020	4	Cooler	In hallway adjacent to classroom A424	High Left	WF-09062019-008186	12/30/2019	FT-FY20-122019-008186-A	<1	FT-FY20-122019-008186-B	<1
WS- 008187	9/6/2019	9/6/2020	4	Cooler	In hallway adjacent to classroom A424	Low Right	WF-09062019-008187	12/30/2019	FT-FY20-122019-008187-A	<1	FT-FY20-122019-008187-B	<1

WS-008188	3/18/2019	3/18/2020	4	Break Room	In work room A430		WF-03182019-008188	12/30/2019	FT-FY20-122019-008188-A	<1	FT-FY20-122019-008188-B	<1
WS-008201	3/18/2019	3/18/2020	1	Cooler	In hallway adjacent to choir room E107	High Left	WF-03182019-008201	12/30/2019	FT-FY20-122019-008201-A	<1	FT-FY20-122019-008201-B	<1
WS-008202	3/18/2019	3/18/2020	1	Cooler	In hallway adjacent to choir room E107	Low Right	WF-03182019-008202	12/30/2019	FT-FY20-122019-008202-A	1.3	FT-FY20-122019-008202-B	<1
WS-008205	3/18/2019	3/18/2020	1	Health Suite	In health suite		WF-03182019-008205	12/30/2019	FT-FY20-122019-008205-A	<1	FT-FY20-122019-008205-B	<1
WS-008214	3/18/2019	3/18/2020	3	Cooler	In hallway adjacent to girls' restroom	High Left	WF-03182019-008214	12/30/2019	FT-FY20-122019-008214-A	<1	FT-FY20-122019-008214-B	<1
WS-008215	3/18/2019	3/18/2020	3	Cooler	In hallway adjacent to boys' restroom	Low Right	WF-03182019-008215	12/30/2019	FT-FY20-122019-008215-A	<1	FT-FY20-122019-008215-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location		Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-008110	7/20/2019	7/20/2020	1	Food Prep Sink	In kitchen north wall	Mid	WF-07202019-008110	12/30/2019	FT-FY20-122019-008110-A	<1	FT-FY20-122019-008110-B	<1
WS-008111	7/19/2019	7/19/2020	1	Food Prep Sink	In kitchen north wall	Right	WF-07192019-008111	12/30/2019	FT-FY20-122019-008111-A	<1	FT-FY20-122019-008111-B	<1
WS-008113	7/20/2019	7/20/2020	1	Food Prep Sink	In kitchen east wall	Left	WF-07202019-008113	12/30/2019	FT-FY20-122019-008113-A	<1	FT-FY20-122019-008113-B	<1
WS-008117	7/19/2019	7/19/2020	1	Food Prep Sink	In kitchen on island		WF-07192019-008117	12/30/2019	FT-FY20-122019-008117-A	<1	FT-FY20-122019-008117-B	<1