



Columbia Heights Education Campus Lead in Water Test Results



FY21 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-002171	10/9/2020	10/9/2021	1	Bottle Filler	In hallway across from room C135	WF-10092020-002171	2/19/2021	FT-FY21-022021-002171-A	<1	FT-FY21-022021-002171-B	<1
WS-002172	10/9/2020	10/9/2021	1	Bottle Filler	In hallway across from A146	WF-10092020-002172	2/19/2021	FT-FY21-022021-002172-A	<1	FT-FY21-022021-002172-B	<1
WS-002173	10/9/2020	10/9/2021	1	Bottle Filler	In hallway adjacent to choir room E107	WF-10092020-002173	2/19/2021	FT-FY21-022021-002173-A	<1	FT-FY21-022021-002173-B	<1
WS-002174	10/9/2020	10/9/2021	1	Bottle Filler	In hallway adjacent to room D113	WF-10092020-002174	2/19/2021	FT-FY21-022021-002174-A	<1	FT-FY21-022021-002174-B	<1
WS-002175	10/9/2020	10/9/2021	2	Bottle Filler	In hallway adjacent to stairwell 2	WF-10092020-002175	2/19/2021	FT-FY21-022021-002175-A	<1	FT-FY21-022021-002175-B	<1
WS-002176	10/9/2020	10/9/2021	2	Bottle Filler	In hallway adjacent to stairwell 2	WF-10092020-002176	2/19/2021	FT-FY21-022021-002176-A	<1	FT-FY21-022021-002176-B	<1
WS-002177	10/9/2020	10/9/2021	2	Bottle Filler	In hallway adjacent to room A206	WF-10092020-002177	2/19/2021	FT-FY21-022021-002177-A	<1	FT-FY21-022021-002177-B	<1
WS-002178	10/9/2020	10/9/2021	2	Bottle Filler	In hallway adjacent to room A205	WF-10092020-002178	2/19/2021	FT-FY21-022021-002178-A	<1	FT-FY21-022021-002178-B	<1
WS-002179	10/9/2020	10/9/2021	2	Bottle Filler	In locker room D211	WF-10092020-002179	2/19/2021	FT-FY21-022021-002179-A	<1	FT-FY21-022021-002179-B	<1
WS-002181	10/9/2020	10/9/2021	2	Bottle Filler	In girls' locker room E214	WF-10092020-002181	2/19/2021	FT-FY21-022021-002181-A	<1	FT-FY21-022021-002181-B	<1
WS-002182	10/9/2020	10/9/2021	3	Bottle Filler	In hallway adjacent to girls' locker room	WF-10092020-002182	2/19/2021	FT-FY21-022021-002182-A	<1	FT-FY21-022021-002182-B	<1
WS-002183	10/9/2020	10/9/2021	3	Bottle Filler	In hallway adjacent to room A424	WF-10092020-002183	2/19/2021	FT-FY21-022021-002183-A	<1	FT-FY21-022021-002183-B	<1
WS-002184	10/9/2020	10/9/2021	3	Bottle Filler	In hallway adjacent to restrooms	WF-10092020-002184	2/19/2021	FT-FY21-022021-002184-A	<1	FT-FY21-022021-002184-B	<1
WS-002335	3/9/2020	3/9/2021	1	Health Suite	In health suite A138	WF-03092020-002335	2/19/2021	FT-FY21-022021-002335-A	<1	FT-FY21-022021-002335-B	<1
WS-008021	10/6/2020	10/6/2021	1	Classroom Faucet	In classroom E123	WF-10062020-008021	2/19/2021	FT-FY21-022021-008021-A	<1	FT-FY21-022021-008021-B	<1
WS-008025	10/6/2020	10/6/2021	1	Classroom Faucet	In classroom E121A first clockwise from entry door	WF-10062020-008025	2/19/2021	FT-FY21-022021-008025-A	<1	FT-FY21-022021-008025-B	<1
WS-008026	10/6/2020	10/6/2021	1	Classroom Faucet	In classroom E121A second clockwise from entry door	WF-10062020-008026	2/19/2021	FT-FY21-022021-008026-A	<1	FT-FY21-022021-008026-B	<1
WS-008027	10/6/2020	10/6/2021	1	Classroom Faucet	In classroom E121A third clockwise from entry door	WF-10062020-008027	2/19/2021	FT-FY21-022021-008027-A	<1	FT-FY21-022021-008027-B	<1
WS-008028	10/6/2020	10/6/2021	1	Classroom Faucet	In classroom E121A fourth clockwise from entry door	WF-10062020-008028	2/19/2021	FT-FY21-022021-008028-A	<1	FT-FY21-022021-008028-B	<1
WS-008030	10/9/2020	10/9/2021	1	Cooler	In hallway adjacent to room D113	WF-10092020-008030	2/19/2021	FT-FY21-022021-008030-A	<1	FT-FY21-022021-008030-B	<1
WS-008056	10/9/2020	10/9/2021	1	Cooler	In hallway adjacent to room C135	WF-10092020-008056	2/19/2021	FT-FY21-022021-008056-A	<1	FT-FY21-022021-008056-B	<1
WS-008057	10/9/2020	10/9/2021	1	Cooler	In hallway adjacent to room C135	WF-10092020-008057	2/19/2021	FT-FY21-022021-008057-A	<1	FT-FY21-022021-008057-B	<1
WS-008059	3/9/2020	3/9/2021	1	Break Room	In break room C117	WF-03092020-008059	2/19/2021	FT-FY21-022021-008059-A	<1	FT-FY21-022021-008059-B	<1
WS-008060	3/9/2020	3/9/2021	1	Break Room	In workroom C109	WF-03092020-008060	2/19/2021	FT-FY21-022021-008060-A	<1	FT-FY21-022021-008060-B	<1
WS-008065	3/9/2020	3/9/2021	1	Break Room	In workroom A117	WF-03092020-008065	2/19/2021	FT-FY21-022021-008065-A	<1	FT-FY21-022021-008065-B	<1
WS-008069	10/9/2020	10/9/2021	1	Cooler	In hallway across from room A146	WF-10092020-008069	2/19/2021	FT-FY21-022021-008069-A	<1	FT-FY21-022021-008069-B	<1
WS-008101	10/9/2020	10/9/2021	2	Cooler	In hallway adjacent to room A206	WF-10092020-008101	2/19/2021	FT-FY21-022021-008101-A	<1	FT-FY21-022021-008101-B	<1
WS-008103	10/9/2020	10/9/2021	2	Cooler	In hallway adjacent to room A205	WF-10092020-008103	2/19/2021	FT-FY21-022021-008103-A	<1	FT-FY21-022021-008103-B	<1
WS-008105	10/9/2020	10/9/2021	2	Cooler	In hallway adjacent to stairwell 2	WF-10092020-008105	2/19/2021	FT-FY21-022021-008105-A	<1	FT-FY21-022021-008105-B	<1
WS-008107	10/9/2020	10/9/2021	2	Cooler	In hallway adjacent to stairwell 2	WF-10092020-008107	2/19/2021	FT-FY21-022021-008107-A	<1	FT-FY21-022021-008107-B	<1
WS-008116	3/9/2020	3/9/2021	1	Ice Maker	In kitchen (ice maker)	WF-03092020-008116	2/19/2021	FT-FY21-022021-008116-A	<1	FT-FY21-022021-008116-B	<1
WS-008157	3/9/2020	3/9/2021	3	Break Room	In break room C304A	WF-03092020-008157	2/19/2021	FT-FY21-022021-008157-A	<1	FT-FY21-022021-008157-B	<1
WS-008169	10/9/2020	10/9/2021	2	Cooler	In locker room E231	WF-10092020-008169	2/19/2021	FT-FY21-022021-008169-A	<1	FT-FY21-022021-008169-B	<1

WS- 008171	10/9/2020	10/9/2021	2	Cooler	In girls' locker room E214	High Left	WF-10092020-008171	2/19/2021	FT-FY21-022021-008171-A	<1	FT-FY21-022021-008171-B	<1
WS- 008172	10/9/2020	10/9/2021	2	Cooler	In girls' locker room E214	Low Right	WF-10092020-008172	2/19/2021	FT-FY21-022021-008172-A	<1	FT-FY21-022021-008172-B	<1
WS- 008173	10/9/2020	10/9/2021	2	Cooler	In locker room D211	Left	WF-10092020-008173	2/19/2021	FT-FY21-022021-008173-A	<1	FT-FY21-022021-008173-B	<1
WS- 008174	10/9/2020	10/9/2021	2	Cooler	In locker room D211	Right	WF-10092020-008174	2/19/2021	FT-FY21-022021-008174-A	<1	FT-FY21-022021-008174-B	<1
WS- 008186	10/9/2020	10/9/2021	4	Cooler	In hallway adjacent to classroom A424	High Left	WF-10092020-008186	2/19/2021	FT-FY21-022021-008186-A	<1	FT-FY21-022021-008186-B	<1
WS- 008187	10/9/2020	10/9/2021	4	Cooler	In hallway adjacent to classroom A424	Low Right	WF-10092020-008187	2/19/2021	FT-FY21-022021-008187-A	<1	FT-FY21-022021-008187-B	<1
WS- 008188	3/9/2020	3/9/2021	4	Break Room	In work room A430		WF-03092020-008188	2/19/2021	FT-FY21-022021-008188-A	<1	FT-FY21-022021-008188-B	<1
WS- 008201	10/9/2020	10/9/2021	1	Cooler	In hallway adjacent to choir room E107	High Left	WF-10092020-008201	2/19/2021	FT-FY21-022021-008201-A	<1	FT-FY21-022021-008201-B	<1
WS- 008202	10/9/2020	10/9/2021	1	Cooler	In hallway adjacent to choir room E107	Low Right	WF-10092020-008202	2/19/2021	FT-FY21-022021-008202-A	<1	FT-FY21-022021-008202-B	<1
WS- 008205	3/9/2020	3/9/2021	1	Health Suite	In health suite		WF-03092020-008205	2/19/2021	FT-FY21-022021-008205-A	<1	FT-FY21-022021-008205-B	<1
WS- 008214	10/9/2020	10/9/2021	3	Cooler	In hallway adjacent to girls' restroom	High Left	WF-10092020-008214	2/19/2021	FT-FY21-022021-008214-A	<1	FT-FY21-022021-008214-B	<1
WS- 008215	10/9/2020	10/9/2021	3	Cooler	In hallway adjacent to boys' restroom	Low Right	WF-10092020-008215	2/19/2021	FT-FY21-022021-008215-A	<1	FT-FY21-022021-008215-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS- 008110	1/6/2021	1/6/2022	1	Food Prep Sink	In kitchen north wall	Mid	WF-01062021-008110	2/19/2021	FT-FY21-022021-008110-A	<1	FT-FY21-022021-008110-B	<1
WS- 008111	1/6/2021	1/6/2022	1	Food Prep Sink	In kitchen north wall	Right	WF-01062021-008111	2/19/2021	FT-FY21-022021-008111-A	<1	FT-FY21-022021-008111-B	<1
WS- 008113	1/6/2021	1/6/2022	1	Food Prep Sink	In kitchen east wall	Left	WF-01062021-008113	2/19/2021	FT-FY21-022021-008113-A	<1	FT-FY21-022021-008113-B	<1
WS- 008117	1/6/2021	1/6/2022	1	Food Prep Sink	In kitchen on island		WF-01062021-008117	2/19/2021	FT-FY21-022021-008117-A	<1	FT-FY21-022021-008117-B	<1