



Columbia Heights Education Campus Lead in Water Test Results

FY23 Filter Test

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 002171	12/19/2022	12/19/2023	1	Bottle Filler	In hallway across from room C135	WF-12192022-002171	1/18/2023	FT-FY23-12292022-002171-A	<1	FT-FY23-12292022-002171-B	<1
WS- 002173	2/20/2022	2/20/2023	1	Bottle Filler	In hallway adjacent to choir room E107	WF-02202022-002173	1/18/2023	FT-FY23-12292022-002173-A	<1	FT-FY23-12292022-002173-B	<1
WS- 002174	12/19/2022	12/19/2023	1	Bottle Filler	In hallway adjacent to room D113	WF-12192022-002174	1/18/2023	FT-FY23-12292022-002174-A	<1	FT-FY23-12292022-002174-B	<1
WS- 002175	12/19/2022	12/19/2023	2	Bottle Filler	In hallway adjacent to stairwell 2	WF-12192022-002175	1/18/2023	FT-FY23-12292022-002175-A	<1	FT-FY23-12292022-002175-B	<1
WS- 002176	12/19/2022	12/19/2023	2	Bottle Filler	In hallway adjacent to stairwell 2	WF-12192022-002176	1/18/2023	FT-FY23-12292022-002176-A	<1	FT-FY23-12292022-002176-B	<1
WS- 002177	2/20/2022	2/20/2023	2	Bottle Filler	In hallway adjacent to room A206	WF-02202022-002177	1/18/2023	FT-FY23-12292022-002177-A	<1	FT-FY23-12292022-002177-B	<1
WS- 002178	12/19/2022	12/19/2023	2	Bottle Filler	In hallway adjacent to room A205	WF-12192022-002178	1/18/2023	FT-FY23-12292022-002178-A	<1	FT-FY23-12292022-002178-B	<1
WS- 002179	2/20/2022	2/20/2023	2	Bottle Filler	In locker room D211	WF-02202022-002179	1/18/2023	FT-FY23-12292022-002179-A	<1	FT-FY23-12292022-002179-B	<1
WS- 002180	2/20/2022	2/20/2023	2	Bottle Filler	In locker room E234	WF-02202022-002180	1/18/2023	FT-FY23-12292022-002180-A	<1	FT-FY23-12292022-002180-B	<1
WS- 002181	2/20/2022	2/20/2023	2	Bottle Filler	In girls' locker room E214	WF-02202022-002181	1/18/2023	FT-FY23-12292022-002181-A	<1	FT-FY23-12292022-002181-B	<1
WS- 002182	12/19/2022	12/19/2023	3	Bottle Filler	In hallway adjacent to girls' locker room	WF-12192022-002182	1/18/2023	FT-FY23-12292022-002182-A	<1	FT-FY23-12292022-002182-B	<1
WS- 002183	12/19/2022	12/19/2023	4	Bottle Filler	In hallway adjacent to room A424	WF-12192022-002183	1/18/2023	FT-FY23-12292022-002183-A	<1	FT-FY23-12292022-002183-B	<1
WS- 002184	2/20/2022	2/20/2023	3	Bottle Filler	In hallway adjacent to restrooms	WF-02202022-002184	1/18/2023	FT-FY23-12292022-002184-A	<1	FT-FY23-12292022-002184-B	<1
WS- 002335	2/20/2022	2/20/2023	1	Health Suite	In health suite A138	WF-02202022-002335	1/18/2023	FT-FY23-12292022-002335-A	<1	FT-FY23-12292022-002335-B	<1
WS- 008025	9/19/2022	9/19/2023	1	Classroom Faucet	In classroom E121A first clockwise from entry door	WF-09192022-008025	1/18/2023	FT-FY23-12292022-008025-A	<1	FT-FY23-12292022-008025-B	<1
WS- 008026	9/19/2022	9/19/2023	1	Classroom Faucet	In classroom E121A second clockwise from entry door	WF-09192022-008026	1/18/2023	FT-FY23-12292022-008026-A	<1	FT-FY23-12292022-008026-B	<1
WS- 008027	9/19/2022	9/19/2023	1	Classroom Faucet	In classroom E121A third clockwise from entry door	WF-09192022-008027	1/18/2023	FT-FY23-12292022-008027-A	<1	FT-FY23-12292022-008027-B	<1
WS- 008028	9/19/2022	9/19/2023	1	Classroom Faucet	In classroom E121A fourth clockwise from entry door	WF-09192022-008028	1/18/2023	FT-FY23-12292022-008028-A	<1	FT-FY23-12292022-008028-B	<1
WS- 008059	2/20/2022	2/20/2023	1	Break Room	In break room C117	WF-02202022-008059	1/18/2023	FT-FY23-12292022-008059-A	<1	FT-FY23-12292022-008059-B	<1
WS- 008060	2/20/2022	2/20/2023	1	Break Room	In workroom C109	WF-02202022-008060	1/18/2023	FT-FY23-12292022-008060-A	<1	FT-FY23-12292022-008060-B	<1
WS- 008065	2/20/2022	2/20/2023	1	Break Room	In workroom A117	WF-02202022-008065	1/18/2023	FT-FY23-12292022-008065-A	<1	FT-FY23-12292022-008065-B	<1
WS- 008157	2/20/2022	2/20/2023	3	Break Room	In break room C304A	WF-02202022-008157	1/18/2023	FT-FY23-12292022-008157-A	<1	FT-FY23-12292022-008157-B	<1
WS- 008188	2/20/2022	2/20/2023	4	Break Room	In work room A430	WF-02202022-008188	1/18/2023	FT-FY23-12292022-008188-A	<1	FT-FY23-12292022-008188-B	<1
WS- 008205	2/20/2022	2/20/2023	1	Health Suite	In health suite	WF-02202022-008205	1/18/2023	FT-FY23-12292022-008205-A	<1	FT-FY23-12292022-008205-B	<1
WS- 008215	12/19/2022	12/19/2023	3	Cooler	In hallway adjacent to boys' restroom	WF-12192022-008215	1/18/2023	FT-FY23-12292022-008215-A	<1	FT-FY23-12292022-008215-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS- 008110	12/19/2022	12/19/2023	1	Food Prep Sink	In kitchen north wall	Mid	WF-12192022-008110	1/18/2023	FT-FY23-12292022-008110-A	<1	FT-FY23-12292022-008110-B	<1
WS- 008111	12/19/2022	12/19/2023	1	Food Prep Sink	In kitchen north wall	Right	WF-12192022-008111	1/18/2023	FT-FY23-12292022-008111-A	<1	FT-FY23-12292022-008111-B	<1
WS- 008113	12/19/2022	12/19/2023	1	Food Prep Sink	In kitchen east wall	Left	WF-12192022-008113	1/18/2023	FT-FY23-12292022-008113-A	<1	FT-FY23-12292022-008113-B	<1
WS- 008117	12/19/2022	12/19/2023	1	Food Prep Sink	In kitchen on island		WF-12192022-008117	1/18/2023	FT-FY23-12292022-008117-A	<1	FT-FY23-12292022-008117-B	<1