



Columbia Heights Education Campus Lead in Water Test Results

FY24 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-002171	2/16/2023	2/16/2024	1	Bottle Filler	In hallway across from room C135	WF-02162023-002171	10/16/2023	FT-FY24-09182023-002171-A	<1	FT-FY24-09182023-002171-B	<1
WS-002173	2/16/2023	2/16/2024	1	Bottle Filler	In hallway adjacent to choir room E107	WF-02162023-002173	10/16/2023	FT-FY24-09182023-002173-A	<1	FT-FY24-09182023-002173-B	<1
WS-002175	2/16/2023	2/16/2024	2	Bottle Filler	In hallway adjacent to stairwell 2	WF-02162023-002175	10/16/2023	FT-FY24-09182023-002175-A	<1	FT-FY24-09182023-002175-B	<1
WS-002177	2/16/2023	2/16/2024	2	Bottle Filler	In hallway adjacent to room A206	WF-02162023-002177	10/16/2023	FT-FY24-09182023-002177-A	<1	FT-FY24-09182023-002177-B	<1
WS-002178	2/16/2023	2/16/2024	2	Bottle Filler	In hallway adjacent to room A205	WF-02162023-002178	10/16/2023	FT-FY24-09182023-002178-A	<1	FT-FY24-09182023-002178-B	<1
WS-002179	2/16/2023	2/16/2024	2	Bottle Filler	In locker room D211	WF-02162023-002179	10/16/2023	FT-FY24-09182023-002179-A	<1	FT-FY24-09182023-002179-B	<1
WS-002180	2/16/2023	2/16/2024	2	Bottle Filler	In locker room E234	WF-02162023-002180	10/16/2023	FT-FY24-09182023-002180-A	<1	FT-FY24-09182023-002180-B	<1
WS-002181	2/16/2023	2/16/2024	2	Bottle Filler	In girls' locker room E214	WF-02162023-002181	10/16/2023	FT-FY24-09182023-002181-A	<1	FT-FY24-09182023-002181-B	<1
WS-002183	2/16/2023	2/16/2024	4	Bottle Filler	In hallway adjacent to room A424	WF-02162023-002183	10/16/2023	FT-FY24-09182023-002183-A	<1	FT-FY24-09182023-002183-B	<1
WS-002184	2/16/2023	2/16/2024	3	Bottle Filler	In hallway adjacent to restrooms	WF-02162023-002184	10/16/2023	FT-FY24-09182023-002184-A	<1	FT-FY24-09182023-002184-B	<1
WS-002335	2/16/2023	2/16/2024	1	Health Suite	In health suite A138	WF-02162023-002335	10/16/2023	FT-FY24-09182023-002335-A	1.2	FT-FY24-09182023-002335-B	1.2
WS-008021	9/13/2023	9/13/2024	1	Classroom Faucet	In classroom E123	WF-09132023-008021	10/16/2023	FT-FY24-09182023-008021-A	1.1	FT-FY24-09182023-008021-B	<1
WS-008025	9/13/2023	9/13/2024	1	Classroom Faucet	In classroom E121A first clockwise from entry door	WF-09132023-008025	10/16/2023	FT-FY24-09182023-008025-A	<1	FT-FY24-09182023-008025-B	<1
WS-008026	9/13/2023	9/13/2024	1	Classroom Faucet	In classroom E121A second clockwise from entry door	WF-09132023-008026	10/16/2023	FT-FY24-09182023-008026-A	1.0	FT-FY24-09182023-008026-B	<1
WS-008027	9/13/2023	9/13/2024	1	Classroom Faucet	In classroom E121A third clockwise from entry door	WF-09132023-008027	10/16/2023	FT-FY24-09182023-008027-A	1.1	FT-FY24-09182023-008027-B	1.0
WS-008028	9/13/2023	9/13/2024	1	Classroom Faucet	In classroom E121A fourth clockwise from entry door	WF-09132023-008028	10/16/2023	FT-FY24-09182023-008028-A	1.0	FT-FY24-09182023-008028-B	<1
WS-008030	2/16/2023	2/16/2024	1	Cooler	In hallway adjacent to room D113	WF-02162023-008030	10/16/2023	FT-FY24-09182023-008030-A	<1	FT-FY24-09182023-008030-B	<1
WS-008059	2/16/2023	2/16/2024	1	Break Room	In break room C117	WF-02162023-008059	10/16/2023	FT-FY24-09182023-008059-A	<1	FT-FY24-09182023-008059-B	<1
WS-008065	2/16/2023	2/16/2024	1	Break Room	In workroom A117	WF-02162023-008065	10/16/2023	FT-FY24-09182023-008065-A	<1	FT-FY24-09182023-008065-B	<1
WS-008068	5/31/2023	5/31/2024	1	Cooler	In hallway across from room A146	WF-05312023-008068	10/16/2023	FT-FY24-09182023-008068-A	<1	FT-FY24-09182023-008068-B	<1
WS-008069	5/31/2023	5/31/2024	1	Cooler	In hallway across from room A146	WF-05312023-008069	10/16/2023	FT-FY24-09182023-008069-A	<1	FT-FY24-09182023-008069-B	<1
WS-008100	2/16/2023	2/16/2024	2	Cooler	In hallway adjacent to room A206	WF-02162023-008100	10/16/2023	FT-FY24-09182023-008100-A	<1	FT-FY24-09182023-008100-B	<1
WS-008101	2/16/2023	2/16/2024	2	Cooler	In hallway adjacent to room A206	WF-02162023-008101	10/16/2023	FT-FY24-09182023-008101-A	<1	FT-FY24-09182023-008101-B	<1
WS-008102	2/16/2023	2/16/2024	2	Cooler	In hallway adjacent to room A205	WF-02162023-008102	10/16/2023	FT-FY24-09182023-008102-A	<1	FT-FY24-09182023-008102-B	<1
WS-008103	2/16/2023	2/16/2024	2	Cooler	In hallway adjacent to room A205	WF-02162023-008103	10/16/2023	FT-FY24-09182023-008103-A	<1	FT-FY24-09182023-008103-B	<1
WS-008104	2/16/2023	2/16/2024	2	Cooler	In hallway adjacent to stairwell 2	WF-02162023-008104	10/16/2023	FT-FY24-09182023-008104-A	<1	FT-FY24-09182023-008104-B	<1
WS-008105	2/16/2023	2/16/2024	2	Cooler	In hallway adjacent to stairwell 2	WF-02162023-008105	10/16/2023	FT-FY24-09182023-008105-A	<1	FT-FY24-09182023-008105-B	<1
WS-008159	2/16/2023	2/16/2024	3	Cooler	In hallway adjacent to the restrooms	WF-02162023-008159	10/16/2023	FT-FY24-09182023-008159-A	<1	FT-FY24-09182023-008159-B	<1
WS-008160	2/16/2023	2/16/2024	3	Cooler	In hallway adjacent to the restrooms	WF-02162023-008160	10/16/2023	FT-FY24-09182023-008160-A	<1	FT-FY24-09182023-008160-B	<1
WS-008170	2/16/2023	2/16/2024	2	Cooler	In locker room E234	WF-02162023-008170	10/16/2023	FT-FY24-09182023-008170-A	<1	FT-FY24-09182023-008170-B	<1
WS-008171	2/16/2023	2/16/2024	2	Cooler	In girls' locker room E214	WF-02162023-008171	10/16/2023	FT-FY24-09182023-008171-A	<1	FT-FY24-09182023-008171-B	<1
WS-008172	2/16/2023	2/16/2024	2	Cooler	In girls' locker room E214	WF-02162023-008172	10/16/2023	FT-FY24-09182023-008172-A	<1	FT-FY24-09182023-008172-B	<1
WS-008173	2/16/2023	2/16/2024	2	Cooler	In locker room D211	WF-02162023-008173	10/16/2023	FT-FY24-09182023-008173-A	<1	FT-FY24-09182023-008173-B	<1
WS-008174	2/16/2023	2/16/2024	2	Cooler	In locker room D211	WF-02162023-008174	10/16/2023	FT-FY24-09182023-008174-A	<1	FT-FY24-09182023-008174-B	<1
WS-008187	2/16/2023	2/16/2024	4	Cooler	In hallway adjacent to classroom A424	WF-02162023-008187	10/16/2023	FT-FY24-09182023-008187-A	<1	FT-FY24-09182023-008187-B	<1

WS- 008188	2/16/2023	2/16/2024	4	Break Room	In work room A430		WF-02162023-008188	10/16/2023	FT-FY24-09182023-008188-A	<1	FT-FY24-09182023-008188-B	<1
WS- 008202	2/16/2023	2/16/2024	1	Cooler	In hallway adjacent to choir room E107	Low Right	WF-02162023-008202	10/16/2023	FT-FY24-09182023-008202-A	<1	FT-FY24-09182023-008202-B	<1
WS- 008205	2/16/2023	2/16/2024	1	Health Suite	In health suite		WF-02162023-008205	10/16/2023	FT-FY24-09182023-008205-A	<1	FT-FY24-09182023-008205-B	<1
WS- 008215	12/19/2022	12/19/2023	3	Cooler	In hallway adjacent to boys' restroom	Low Right	WF-12192022-008215	10/16/2023	FT-FY24-09182023-008215-A	<1	FT-FY24-09182023-008215-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location		Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 008110	12/19/2022	12/19/2023	1	Food Prep Sink	In kitchen north wall	Mid	WF-12192022-008110	10/16/2023	FT-FY24-09182023-008110-A	<1	FT-FY24-09182023-008110-B	<1
WS- 008111	12/19/2022	12/19/2023	1	Food Prep Sink	In kitchen north wall	Right	WF-12192022-008111	10/16/2023	FT-FY24-09182023-008111-A	<1	FT-FY24-09182023-008111-B	<1
WS- 008117	12/19/2022	12/19/2023	1	Food Prep Sink	In kitchen on island		WF-12192022-008117	10/16/2023	FT-FY24-09182023-008117-A	<1	FT-FY24-09182023-008117-B	<1