



# Columbia Heights Education Campus Lead in Water Test Results

## FY22 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS-002171	3/1/2021	3/1/2022	1	Bottle Filler	In hallway across from room C135	WF-03012021-002171	11/24/2021	FT-FY22-11122021-002171-A	<1	FT-FY22-11122021-002171-B	<1	
WS-002172	3/1/2021	3/1/2022	1	Bottle Filler	In hallway across from A146	WF-03012021-002172	11/24/2021	FT-FY22-11122021-002172-A	<1	FT-FY22-11122021-002172-B	<1	
WS-002173	3/1/2021	3/1/2022	1	Bottle Filler	In hallway adjacent to choir room E107	WF-03012021-002173	11/24/2021	FT-FY22-11122021-002173-A	<1	FT-FY22-11122021-002173-B	<1	
WS-002174	3/1/2021	3/1/2022	1	Bottle Filler	In hallway adjacent to room D113	WF-03012021-002174	11/24/2021	FT-FY22-11122021-002174-A	<1	FT-FY22-11122021-002174-B	<1	
WS-002175	3/1/2021	3/1/2022	2	Bottle Filler	In hallway adjacent to stairwell 2	WF-03012021-002175	11/24/2021	FT-FY22-11122021-002175-A	<1	FT-FY22-11122021-002175-B	<1	
WS-002176	3/1/2021	3/1/2022	2	Bottle Filler	In hallway adjacent to stairwell 2	WF-03012021-002176	11/24/2021	FT-FY22-11122021-002176-A	<1	FT-FY22-11122021-002176-B	<1	
WS-002177	3/1/2021	3/1/2022	2	Bottle Filler	In hallway adjacent to room A206	WF-03012021-002177	11/24/2021	FT-FY22-11122021-002177-A	<1	FT-FY22-11122021-002177-B	<1	
WS-002178	3/1/2021	3/1/2022	2	Bottle Filler	In hallway adjacent to room A205	WF-03012021-002178	11/24/2021	FT-FY22-11122021-002178-A	<1	FT-FY22-11122021-002178-B	<1	
WS-002179	3/1/2021	3/1/2022	2	Bottle Filler	In locker room D211	WF-03012021-002179	11/24/2021	FT-FY22-11122021-002179-A	<1	FT-FY22-11122021-002179-B	<1	
WS-002180	3/1/2021	3/1/2022	2	Bottle Filler	In locker room E234	WF-03012021-002180	11/24/2021	FT-FY22-11122021-002180-A	<1	FT-FY22-11122021-002180-B	<1	
WS-002181	3/1/2021	3/1/2022	2	Bottle Filler	In girls' locker room E214	WF-03012021-002181	11/24/2021	FT-FY22-11122021-002181-A	<1	FT-FY22-11122021-002181-B	<1	
WS-002182	3/1/2021	3/1/2022	3	Bottle Filler	In hallway adjacent to girls' locker room	WF-03012021-002182	11/24/2021	FT-FY22-11122021-002182-A	<1	FT-FY22-11122021-002182-B	<1	
WS-002183	3/1/2021	3/1/2022	4	Bottle Filler	In hallway adjacent to room A424	WF-03012021-002183	11/24/2021	FT-FY22-11122021-002183-A	<1	FT-FY22-11122021-002183-B	<1	
WS-002184	3/1/2021	3/1/2022	3	Bottle Filler	In hallway adjacent to restrooms	WF-03012021-002184	11/24/2021	FT-FY22-11122021-002184-A	<1	FT-FY22-11122021-002184-B	<1	
WS-002335	3/1/2021	3/1/2022	1	Health Suite	In health suite A138	WF-03012021-002335	11/24/2021	FT-FY22-11122021-002335-A	<1	FT-FY22-11122021-002335-B	<1	
WS-008021	9/28/2021	9/28/2022	1	Classroom Faucet	In classroom E123	WF-09282021-008021	11/24/2021	FT-FY22-11122021-008021-A	<1	FT-FY22-11122021-008021-B	<1	
WS-008025	9/28/2021	9/28/2022	1	Classroom Faucet	In classroom E121A first clockwise from entry door	WF-09282021-008025	11/24/2021	FT-FY22-11122021-008025-A	<1	FT-FY22-11122021-008025-B	<1	
WS-008026	9/28/2021	9/28/2022	1	Classroom Faucet	In classroom E121A second clockwise from entry door	WF-09282021-008026	11/24/2021	FT-FY22-11122021-008026-A	<1	FT-FY22-11122021-008026-B	<1	
WS-008027	9/28/2021	9/28/2022	1	Classroom Faucet	In classroom E121A third clockwise from entry door	WF-09282021-008027	11/24/2021	FT-FY22-11122021-008027-A	<1	FT-FY22-11122021-008027-B	<1	
WS-008028	9/28/2021	9/28/2022	1	Classroom Faucet	In classroom E121A fourth clockwise from entry door	WF-09282021-008028	11/24/2021	FT-FY22-11122021-008028-A	<1	FT-FY22-11122021-008028-B	<1	
WS-008030	3/1/2021	3/1/2022	1	Cooler	In hallway adjacent to room D113	Low Right	WF-03012021-008030	11/24/2021	FT-FY22-11122021-008030-A	<1	FT-FY22-11122021-008030-B	<1
WS-008057	3/1/2021	3/1/2022	1	Cooler	In hallway adjacent to room C135	High Right	WF-03012021-008057	11/24/2021	FT-FY22-11122021-008057-A	<1	FT-FY22-11122021-008057-B	<1
WS-008059	3/1/2021	3/1/2022	1	Break Room	In break room C117	WF-03012021-008059	11/24/2021	FT-FY22-11122021-008059-A	<1	FT-FY22-11122021-008059-B	<1	
WS-008060	3/1/2021	3/1/2022	1	Break Room	In workroom C109	WF-03012021-008060	11/24/2021	FT-FY22-11122021-008060-A	<1	FT-FY22-11122021-008060-B	<1	
WS-008065	3/1/2021	3/1/2022	1	Break Room	In workroom A117	WF-03012021-008065	11/24/2021	FT-FY22-11122021-008065-A	<1	FT-FY22-11122021-008065-B	<1	
WS-008069	3/1/2021	3/1/2022	1	Cooler	In hallway across from room A146	High Left	WF-03012021-008069	11/24/2021	FT-FY22-11122021-008069-A	<1	FT-FY22-11122021-008069-B	<1
WS-008101	3/1/2021	3/1/2022	2	Cooler	In hallway adjacent to room A206	Low Right	WF-03012021-008101	11/24/2021	FT-FY22-11122021-008101-A	<1	FT-FY22-11122021-008101-B	<1
WS-008103	3/1/2021	3/1/2022	2	Cooler	In hallway adjacent to room A205	Low Right	WF-03012021-008103	11/24/2021	FT-FY22-11122021-008103-A	<1	FT-FY22-11122021-008103-B	<1
WS-008105	3/1/2021	3/1/2022	2	Cooler	In hallway adjacent to stairwell 2	Low Left	WF-03012021-008105	11/24/2021	FT-FY22-11122021-008105-A	<1	FT-FY22-11122021-008105-B	<1
WS-008107	3/1/2021	3/1/2022	2	Cooler	In hallway adjacent to stairwell 2	High Right	WF-03012021-008107	11/24/2021	FT-FY22-11122021-008107-A	<1	FT-FY22-11122021-008107-B	<1
WS-008116	3/1/2021	3/1/2022	1	Ice Maker	In kitchen (ice maker)	WF-03012021-008116	11/24/2021	FT-FY22-11122021-008116-A	<1	FT-FY22-11122021-008116-B	<1	
WS-008157	3/1/2021	3/1/2022	3	Break Room	In break room C304A	WF-03012021-008157	11/24/2021	FT-FY22-11122021-008157-A	<1	FT-FY22-11122021-008157-B	<1	
WS-008159	3/1/2021	3/1/2022	3	Cooler	In hallway adjacent to the restrooms	High Left	WF-03012021-008159	11/24/2021	FT-FY22-11122021-008159-A	<1	FT-FY22-11122021-008159-B	<1
WS-008160	3/1/2021	3/1/2022	3	Cooler	In hallway adjacent to the restrooms	Low Right	WF-03012021-008160	11/24/2021	FT-FY22-11122021-008160-A	<1	FT-FY22-11122021-008160-B	<1
WS-008169	3/1/2021	3/1/2022	2	Cooler	In locker room E234	High Left	WF-03012021-008169	11/24/2021	FT-FY22-11122021-008169-A	<1	FT-FY22-11122021-008169-B	<1
WS-008170	3/1/2021	3/1/2022	2	Cooler	In locker room E234	Low Right	WF-03012021-008170	11/24/2021	FT-FY22-11122021-008170-A	<1	FT-FY22-11122021-008170-B	<1
WS-008171	3/1/2021	3/1/2022	2	Cooler	In girls' locker room E214	High Left	WF-03012021-008171	11/24/2021	FT-FY22-11122021-008171-A	<1	FT-FY22-11122021-008171-B	<1

WS-008172	3/1/2021	3/1/2022	2	Cooler	In girls' locker room E214	Low	Right	WF-03012021-008172	11/24/2021	FT-FY22-11122021-008172-A	<1	FT-FY22-11122021-008172-B	<1
WS-008173	3/1/2021	3/1/2022	2	Cooler	In locker room D211		Left	WF-03012021-008173	11/24/2021	FT-FY22-11122021-008173-A	<1	FT-FY22-11122021-008173-B	<1
WS-008174	3/1/2021	3/1/2022	2	Cooler	In locker room D211		Right	WF-03012021-008174	11/24/2021	FT-FY22-11122021-008174-A	<1	FT-FY22-11122021-008174-B	<1
WS-008186	3/1/2021	3/1/2022	4	Cooler	In hallway adjacent to classroom A424	High	Left	WF-03012021-008186	11/24/2021	FT-FY22-11122021-008186-A	<1	FT-FY22-11122021-008186-B	<1
WS-008187	3/1/2021	3/1/2022	4	Cooler	In hallway adjacent to classroom A424	Low	Right	WF-03012021-008187	11/24/2021	FT-FY22-11122021-008187-A	<1	FT-FY22-11122021-008187-B	<1
WS-008188	3/1/2021	3/1/2022	4	Break Room	In work room A430			WF-03012021-008188	11/24/2021	FT-FY22-11122021-008188-A	<1	FT-FY22-11122021-008188-B	<1
WS-008201	3/1/2021	3/1/2022	1	Cooler	In hallway adjacent to choir room E107	High	Left	WF-03012021-008201	11/24/2021	FT-FY22-11122021-008201-A	<1	FT-FY22-11122021-008201-B	<1
WS-008202	3/1/2021	3/1/2022	1	Cooler	In hallway adjacent to choir room E107	Low	Right	WF-03012021-008202	11/24/2021	FT-FY22-11122021-008202-A	<1	FT-FY22-11122021-008202-B	<1
WS-008205	3/1/2021	3/1/2022	1	Health Suite	In health suite			WF-03012021-008205	11/24/2021	FT-FY22-11122021-008205-A	<1	FT-FY22-11122021-008205-B	<1
WS-008215	3/1/2021	3/1/2022	3	Cooler	In hallway adjacent to boys' restroom	Low	Right	WF-03012021-008215	11/24/2021	FT-FY22-11122021-008215-A	<1	FT-FY22-11122021-008215-B	<1

### Food Prep Sink

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS-008110	1/6/2021	1/6/2022	1	Food Prep Sink	In kitchen north wall	Mid	WF-01062021-008110	11/24/2021	FT-FY22-11122021-008110-A	<1	FT-FY22-11122021-008110-B	<1
WS-008111	1/6/2021	1/6/2022	1	Food Prep Sink	In kitchen north wall	Right	WF-01062021-008111	11/24/2021	FT-FY22-11122021-008111-A	<1	FT-FY22-11122021-008111-B	<1
WS-008113	1/6/2021	1/6/2022	1	Food Prep Sink	In kitchen east wall	Left	WF-01062021-008113	11/24/2021	FT-FY22-11122021-008113-A	<1	FT-FY22-11122021-008113-B	<1
WS-008117	1/6/2021	1/6/2022	1	Food Prep Sink	In kitchen on island		WF-01062021-008117	11/24/2021	FT-FY22-11122021-008117-A	<1	FT-FY22-11122021-008117-B	<1