



COLUMBIA HEIGHTS EC LEAD WATER TEST RESULTS



	Building Location: Building Name	RECORD ID	Date Analyzed	Floor	Device Type	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)
1	COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	WS- 002335	8/21/2016	1	Health Suite	In health suite A138	FT-82016-002335-A	< 1	FT-82016-002335-B	< 1
2	COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	WS- 008029	8/21/2016	1	Cooler	In hallway adjacent to room D113 High Left	FT-82016-008029-A	< 1	FT-82016-008029-B	< 1
3	COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	WS- 008030	8/21/2016	1	Cooler	In hallway adjacent to room D113 Low Right	FT-82016-008030-A	< 1	FT-82016-008030-B	< 1
4	COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	WS- 008056	8/21/2016	1	Cooler	In hallway adjacent to room C135 Low Left	FT-82016-008056-A	< 1	FT-82016-008056-B	< 1
5	COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	WS- 008057	8/21/2016	1	Cooler	In hallway adjacent to room C135 High Right	FT-82016-008057-A	3.4	FT-82016-008057-B	< 1
			10/10/2016				Re-test A	< 1	Re-test B	< 1
6	COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	WS- 008068	8/21/2016	1	Cooler	In hallway across from room A146 Low Right	FT-82016-008068-A	< 1	FT-82016-008068-B	< 1
7	COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	WS- 008069	8/21/2016	1	Cooler	In hallway across from room A146 High Left	FT-82016-008069-A	< 1	FT-82016-008069-B	< 1
8	COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	WS- 008100	8/21/2016	2	Cooler	In hallway adjacent to room A206 High Left	FT-82016-008100-A	< 1	FT-82016-008100-B	< 1
9	COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	WS- 008101	8/21/2016	2	Cooler	In hallway adjacent to room A206 Low Right	FT-82016-008101-A	< 1	FT-82016-008101-B	< 1
10	COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	WS- 008102	8/21/2016	2	Cooler	In hallway adjacent to room A205 High Left	FT-82016-008102-A	< 1	FT-82016-008102-B	< 1
11	COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	WS- 008103	8/21/2016	2	Cooler	In hallway adjacent to room A205 Low Right	FT-82016-008103-A	< 1	FT-82016-008103-B	< 1
12	COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	WS- 008104	8/21/2016	2	Cooler	In hallway adjacent to stairwell 2 High Left	FT-82016-008104-A	< 1	FT-82016-008104-B	< 1
13	COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	WS- 008105	8/21/2016	2	Cooler	In hallway adjacent to stairwell 2 Low Left	FT-72016-008105-A	< 1	FT-72016-008105-B	< 1
14	COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	WS- 008106	8/21/2016	2	Cooler	In hallway adjacent to stairwell 2 Low Right	FT-82016-008106-A	< 1	FT-82016-008106-B	< 1
15	COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	WS- 008107	8/21/2016	2	Cooler	In hallway adjacent to stairwell 2 High Right	FT-82016-008107-A	< 1	FT-82016-008107-B	< 1
16	COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	WS- 008113	8/21/2016	1	Food Prep Sink	In kitchen east wall Left	FT-72016-008113-A	< 1	FT-72016-008113-B	< 1
17	COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	WS- 008116	8/21/2016	1	Ice Maker	In kitchen (ice maker)	FT-82016-008116-A	< 1	FT-82016-008116-B	< 1
18	COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	WS- 008159	8/21/2016	3	Cooler	In hallway adjacent to the restrooms High Left	FT-82016-008159-A	< 1	FT-82016-008159-B	< 1
19	COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	WS- 008160	8/21/2016	3	Cooler	In hallway adjacent to the restrooms Right	FT-82016-008160-A	< 1	FT-82016-008160-B	< 1
20	COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	WS- 008169	8/21/2016	2	Cooler	In locker room E231 High Left	FT-82016-008169-A	< 1	FT-82016-008169-B	< 1
21	COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	WS- 008170	8/21/2016	2	Cooler	In locker room E231	FT-82016-008170-A	< 1	FT-82016-008170-B	< 1
22	COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	WS- 008171	8/21/2016	2	Cooler	In girls' locker room E214 High Left	FT-82016-008171-A	< 1	FT-82016-008171-B	< 1
23	COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	WS- 008172	8/21/2016	2	Cooler	In girls' locker room E214 Low Right	FT-82016-008172-A	< 1	FT-82016-008172-B	< 1

24	COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	WS- 008173	8/21/2016	2	Cooler	In locker room D211	Left	FT-82016-008173-A	< 1	FT-82016-008173-B	< 1
25	COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	WS- 008174	8/21/2016	2	Cooler	In locker room D211	Right	FT-82016-008174-A	< 1	FT-82016-008174-B	< 1
26	COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	WS- 008175	8/21/2016	2	Cooler	In locker room D204	High Left	FT-82016-008175-A	< 1	FT-82016-008175-B	< 1
27	COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	WS- 008176	8/21/2016	2	Cooler	In locker room D204	Low Right	FT-82016-008176-A	< 1	FT-82016-008176-B	< 1
28	COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	WS- 008186	8/21/2016	4	Cooler	In hallway adjacent to classroom A424	High Left	FT-82016-008186-A	< 1	FT-82016-008186-B	< 1
29	COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	WS- 008187	8/21/2016	3	Cooler	In hallway adjacent to classroom A424	Low Right	FT-82016-008187-A	< 1	FT-82016-008187-B	< 1
30	COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	WS- 008201	8/21/2016	1	Cooler	In hallway adjacent to choir room E107	High Left	FT-82016-008201-A	< 1	FT-82016-008201-B	< 1
31	COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	WS- 008202	8/21/2016	1	Cooler	In hallway adjacent to choir room E107	Low Right	FT-82016-008202-A	< 1	FT-82016-008202-B	< 1
32	COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	WS- 008205	8/21/2016	1	Health Suite	In health suite		FT-82016-008205-A	< 1	FT-82016-008205-B	< 1
33	COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	WS- 008214	8/21/2016	3	Cooler	In hallway adjacent to girls' restroom	High Left	FT-72016-008214-A	< 1	FT-72016-008214-B	< 1
34	COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	WS- 008215	8/21/2016	3	Cooler	In hallway adjacent to boys' restroom	Low Right	FT-82016-008215-A	< 1	FT-82016-008215-B	< 1