



# COLUMBIA HEIGHTS LEAD WATER TEST RESULTS

May 16th, 2016



|    | Building Location                   | Sample Collected Date | Water Source ID | Device Type | Floor | Device Location                                  | 1st Draw - Sample ID | Final Result - 1st Draw (ug/L) | 2nd Draw - Sample ID | Final Result - 2nd Draw (ug/L) | Remediation                                | Retest Date | Retest 1st Draw | Retest 2nd Draw |
|----|-------------------------------------|-----------------------|-----------------|-------------|-------|--|----------------------|--------------------------------|----------------------|--------------------------------|--|-------------|-----------------|-----------------|
| 1  | COLUMBIA HEIGHTS EDUCATIONAL CAMPUS | 5/7/2016              | WS- 008228      | Classroom   | 3     | In classroom A341                                | WT-042916-8245- A    | 2.2                            | WT-042916-8245- B    | < 1                            |  |             |                 |                 |
| 2  | COLUMBIA HEIGHTS EDUCATIONAL CAMPUS | 5/7/2016              | WS- 008227      | Classroom   | 3     | In classroom A341                                | WT-042916-8244- A    | < 1                            | WT-042916-8244- B    | < 1                            |  |             |                 |                 |
| 3  | COLUMBIA HEIGHTS EDUCATIONAL CAMPUS | 5/7/2016              | WS- 008226      | Classroom   | 3     | In classroom A341                                | WT-042916-8243- A    | < 1                            | WT-042916-8243- B    | < 1                            |  |             |                 |                 |
| 4  | COLUMBIA HEIGHTS EDUCATIONAL CAMPUS | 5/7/2016              | WS- 008225      | Classroom   | 3     | In classroom A341                                | WT-042916-8242- A    | < 1                            | WT-042916-8242- B    | < 1                            |  |             |                 |                 |
| 5  | COLUMBIA HEIGHTS EDUCATIONAL CAMPUS | 5/7/2016              | WS- 008224      | Classroom   | 3     | In classroom A338 Right                          | WT-042916-8241- A    | 25.8                           | WT-042916-8241- B    | 10.2                           |  |             |                 |                 |
| 6  | COLUMBIA HEIGHTS EDUCATIONAL CAMPUS | 5/7/2016              | WS- 008223      | Classroom   | 3     | In classroom A338 Left                           | WT-042916-8240- A    | 1.3                            | WT-042916-8240- B    | < 1                            |  |             |                 |                 |
| 7  | COLUMBIA HEIGHTS EDUCATIONAL CAMPUS | 5/7/2016              | WS- 008222      | Classroom   | 3     | In room A337 LHS6 Left                           | WT-042916-8239- A    | 2.4                            | WT-042916-8239- B    | 8.7                            |  |             |                 |                 |
| 8  | COLUMBIA HEIGHTS EDUCATIONAL CAMPUS | 5/7/2016              | WS- 008221      | Classroom   | 3     | In room A337 LHS5 Left                           | WT-042916-8238- A    | < 1                            | WT-042916-8238- B    | < 1                            |  |             |                 |                 |
| 9  | COLUMBIA HEIGHTS EDUCATIONAL CAMPUS | 5/7/2016              | WS- 008220      | Classroom   | 3     | In room A337 LHS4 Left                           | WT-042916-8237- A    | 3.5                            | WT-042916-8237- B    | 3.3                            |  |             |                 |                 |
| 10 | COLUMBIA HEIGHTS EDUCATIONAL CAMPUS | 5/7/2016              | WS- 008219      | Classroom   | 3     | In classroom A337 LHS4                           | WT-042916-8236- A    | 26.6                           | WT-042916-8236- B    | < 1                            |  |             |                 |                 |
| 11 | COLUMBIA HEIGHTS EDUCATIONAL CAMPUS | 5/7/2016              | WS- 008218      | Classroom   | 3     | In classroom A337 middle                         | WT-042916-8235- A    | 19.8                           | WT-042916-8235- B    | < 1                            |  |             |                 |                 |
| 12 | COLUMBIA HEIGHTS EDUCATIONAL CAMPUS | 5/7/2016              | WS- 008217      | Classroom   | 3     | In classroom A337 LHS2                           | WT-042916-8234- A    | 6.7                            | WT-042916-8234- B    | 44.7                           |  |             |                 |                 |
| 13 | COLUMBIA HEIGHTS EDUCATIONAL CAMPUS | 5/7/2016              | WS- 008216      | Classroom   | 3     | In room A337 LHS1 Left                           | WT-042916-8233- A    | 5.4                            | WT-042916-8233- B    | 6.4                            |  |             |                 |                 |
| 14 | COLUMBIA HEIGHTS EDUCATIONAL CAMPUS | 5/7/2016              | WS- 008215      | Cooler      | 3     | In hallway adjacent to boys restrooms Right Low  | WT-042916-8232- A    | < 1                            | WT-042916-8232- B    | 6.5                            |  |             |                 |                 |
| 15 | COLUMBIA HEIGHTS EDUCATIONAL CAMPUS | 5/7/2016              | WS- 008214      | Cooler      | 3     | In hallway adjacent to girls rest room Left High | WT-042916-8231- A    | < 1                            | WT-042916-8231- B    | 16.5                           | Filter will be installed and then retested |             |                 |                 |
| 16 | COLUMBIA HEIGHTS EDUCATIONAL CAMPUS | 5/11/2016             | WS- 008208      | Other       | 2     | In B208 Concession stand ICE MAKER               | WT-042916-8225- A    | < 1                            | WT-042916-8225- B    | < 1                            |  |             |                 |                 |
| 17 | COLUMBIA HEIGHTS EDUCATIONAL CAMPUS | 5/7/2016              | WS- 008205      | Classroom   | 1     | In health suite                                  | WT-042916-8222- A    | < 1                            | WT-042916-8222- B    | < 1                            |  |             |                 |                 |
| 18 | COLUMBIA HEIGHTS EDUCATIONAL CAMPUS | 5/7/2016              | WS- 008203      | Classroom   | 1     | In room C103                                     | WT-042916-8220- A    | < 1                            | WT-042916-8220- B    | < 1                            |  |             |                 |                 |
| 19 | COLUMBIA HEIGHTS EDUCATIONAL CAMPUS | 5/7/2016              | WS- 008202      | Cooler      | 1     | In hallway adjacent to room E107 Right Low       | WT-042916-8219- A    | < 1                            | WT-042916-8219- B    | < 1                            |  |             |                 |                 |
| 20 | COLUMBIA HEIGHTS EDUCATIONAL CAMPUS | 5/7/2016              | WS- 008201      | Cooler      | 1     | In hallway adjacent to choir E107                | WT-042916-8218- A    | < 1                            | WT-042916-8218- B    | < 1                            |  |             |                 |                 |
| 21 | COLUMBIA HEIGHTS EDUCATIONAL CAMPUS | 5/7/2016              | WS- 008200      | Classroom   | 3     | In art room A316                                 | WT-042916-8217- A    | 2.2                            | WT-042916-8217- B    | 2.1                            |  |             |                 |                 |
| 22 | COLUMBIA HEIGHTS EDUCATIONAL CAMPUS | 5/7/2016              | WS- 008199      | Classroom   | 3     | In classroom A341                                | WT-042916-8216- A    | 1.8                            | WT-042916-8216- B    | < 1                            |  |             |                 |                 |
| 23 | COLUMBIA HEIGHTS EDUCATIONAL CAMPUS | 5/7/2016              | WS- 008198      | Classroom   | 3     | In classroom A341                                | WT-042916-8215- A    | < 1                            | WT-042916-8215- B    | 1.8                            |  |             |                 |                 |
| 24 | COLUMBIA HEIGHTS EDUCATIONAL CAMPUS | 5/7/2016              | WS- 008197      | Classroom   | 4     | In classroom A436 MIDDLE SINK                    | WT-042916-8214- A    | 1.3                            | WT-042916-8214- B    | 2.6                            |  |             |                 |                 |
| 25 | COLUMBIA HEIGHTS EDUCATIONAL CAMPUS | 5/7/2016              | WS- 008196      | Classroom   | 4     | In classroom A436 LHS 6                          | WT-042916-8213- A    | < 1                            | WT-042916-8213- B    | < 1                            |  |             |                 |                 |
| 26 | COLUMBIA HEIGHTS EDUCATIONAL CAMPUS | 5/7/2016              | WS- 008195      | Classroom   | 4     | In classroom A436 LHS 5                          | WT-042916-8212- A    | < 1                            | WT-042916-8212- B    | < 1                            |  |             |                 |                 |
| 27 | COLUMBIA HEIGHTS EDUCATIONAL CAMPUS | 5/7/2016              | WS- 008194      | Classroom   | 4     | In classroom A436 LHS 4                          | WT-042916-8211- A    | 1.2                            | WT-042916-8211- B    | < 1                            |  |             |                 |                 |
| 28 | COLUMBIA HEIGHTS EDUCATIONAL CAMPUS | 5/7/2016              | WS- 008193      | Classroom   | 4     | In classroom A436 LHS 3                          | WT-042916-8210- A    | 1.1                            | WT-042916-8210- B    | < 1                            |  |             |                 |                 |
| 29 | COLUMBIA HEIGHTS EDUCATIONAL CAMPUS | 5/7/2016              | WS- 008192      | Classroom   | 4     | In classroom A436 LHS 2                          | WT-042916-8209- A    | < 1                            | WT-042916-8209- B    | < 1                            |  |             |                 |                 |
| 30 | COLUMBIA HEIGHTS EDUCATIONAL CAMPUS | 5/7/2016              | WS- 008191      | Classroom   | 4     | In classroom A436 LHS 1                          | WT-042916-8208- A    | 1.7                            | WT-042916-8208- B    | < 1                            |  |             |                 |                 |
| 31 | COLUMBIA HEIGHTS EDUCATIONAL CAMPUS | 5/7/2016              | WS- 008190      | Classroom   | 4     | In prep room A435                                | WT-042916-8207- A    | 5.5                            | WT-042916-8207- B    | < 1                            |  |             |                 |                 |
| 32 | COLUMBIA HEIGHTS EDUCATIONAL CAMPUS | 5/7/2016              | WS- 008189      | Classroom   | 4     | In prep room A435                                | WT-042916-8206- A    | 16.5                           | WT-042916-8206- B    | < 1                            |  |             |                 |                 |
| 33 | COLUMBIA HEIGHTS EDUCATIONAL CAMPUS | 5/7/2016              | WS- 008188      | Classroom   | 4     | In work room A430                                | WT-042916-8205- A    | 3.4                            | WT-042916-8205- B    | 1.1                            |  |             |                 |                 |
| 34 | COLUMBIA HEIGHTS EDUCATIONAL CAMPUS | 5/7/2016              | WS- 008187      | Cooler      | 3     | In hallway adjacent to classroom A428 Right Low  | WT-042916-8204- A    | < 1                            | WT-042916-8204- B    | < 1                            |  |             |                 |                 |
| 35 | COLUMBIA HEIGHTS EDUCATIONAL CAMPUS | 5/7/2016              | WS- 008186      | Cooler      | 4     | In hallway adjacent to classroom A428 Left High  | WT-042916-8203- A    | < 1                            | WT-042916-8203- B    | < 1                            |  |             |                 |                 |
| 36 | COLUMBIA HEIGHTS EDUCATIONAL CAMPUS | 5/10/2016             | WS- 008185      | Classroom   | 3     | In classroom 325 instructors sink middle         | WT-042916-8202- A    | 980                            | WT-042916-8202- B    | 12                             | Filter will be installed and then retested |             |                 |                 |



# COLUMBIA HEIGHTS LEAD WATER TEST RESULTS

May 16th, 2016



| Building Location                   | Sample Collected Date | Water Source ID | Device Type | Floor | Device Location                                | 1st Draw - Sample ID | Final Result - 1st Draw (ug/L) | 2nd Draw - Sample ID | Final Result - 2nd Draw (ug/L) | Remediation | Retest Date | Retest 1st Draw | Retest 2nd Draw |
|-------------------------------------|-----------------------|-----------------|-------------|-------|--|----------------------|--------------------------------|----------------------|--------------------------------|-------------|-------------|-----------------|-----------------|
| COLUMBIA HEIGHTS EDUCATIONAL CAMPUS | 5/7/2016              | WS- 008184      | Classroom   | 3     | In classroom C325 LHS7                         | WT-042916-8201- A    | 8.3                            | WT-042916-8201- B    | 17.2                           |             |             |                 |                 |
| COLUMBIA HEIGHTS EDUCATIONAL CAMPUS | 5/7/2016              | WS- 008183      | Classroom   | 3     | In classroom C325                              | WT-042916-8200- A    | 7.2                            | WT-042916-8200- B    | 16.5                           |             |             |                 |                 |
| COLUMBIA HEIGHTS EDUCATIONAL CAMPUS | 5/7/2016              | WS- 008182      | Classroom   | 3     | In classroom C325 LHS 5                        | WT-042916-8199- A    | 1.1                            | WT-042916-8199- B    | 3.1                            |             |             |                 |                 |
| COLUMBIA HEIGHTS EDUCATIONAL CAMPUS | 5/7/2016              | WS- 008181      | Classroom   | 3     | In classroom C325 LHS 4                        | WT-042916-8198- A    | 73.9                           | WT-042916-8198- B    | 6.1                            |             |             |                 |                 |
| COLUMBIA HEIGHTS EDUCATIONAL CAMPUS | 5/7/2016              | WS- 008180      | Classroom   | 3     | In classroom C325 LHS3                         | WT-042916-8197- A    | < 1                            | WT-042916-8197- B    | 2.5                            |             |             |                 |                 |
| COLUMBIA HEIGHTS EDUCATIONAL CAMPUS | 5/7/2016              | WS- 008179      | Classroom   | 3     | In classroom C325 LHS2 Left                    | WT-042916-8196- A    | 143                            | WT-042916-8196- B    | 6.9                            |             |             |                 |                 |
| COLUMBIA HEIGHTS EDUCATIONAL CAMPUS | 5/7/2016              | WS- 008178      | Classroom   | 3     | In classroom C325 LHS1                         | WT-042916-8195- A    | 88.9                           | WT-042916-8195- B    | 3.5                            |             |             |                 |                 |
| COLUMBIA HEIGHTS EDUCATIONAL CAMPUS | 5/7/2016              | WS- 008177      | Classroom   | 3     | In classroom C324                              | WT-042916-8194- A    | 5.1                            | WT-042916-8194- B    | 3.1                            |             |             |                 |                 |
| COLUMBIA HEIGHTS EDUCATIONAL CAMPUS | 5/7/2016              | WS- 008176      | Cooler      | 2     | In room D204 Right Low                         | WT-042916-8193- A    | < 1                            | WT-042916-8193- B    | < 1                            |             |             |                 |                 |
| COLUMBIA HEIGHTS EDUCATIONAL CAMPUS | 5/7/2016              | WS- 008175      | Cooler      | 2     | In locker room D204 Left High                  | WT-042916-8192- A    | < 1                            | WT-042916-8192- B    | < 1                            |             |             |                 |                 |
| COLUMBIA HEIGHTS EDUCATIONAL CAMPUS | 5/7/2016              | WS- 008174      | Cooler      | 2     | In room D211 Right                             | WT-042916-8191- A    | < 1                            | WT-042916-8191- B    | < 1                            |             |             |                 |                 |
| COLUMBIA HEIGHTS EDUCATIONAL CAMPUS | 5/7/2016              | WS- 008173      | Cooler      | 2     | In room D211 Left                              | WT-042916-8190- A    | < 1                            | WT-042916-8190- B    | < 1                            |             |             |                 |                 |
| COLUMBIA HEIGHTS EDUCATIONAL CAMPUS | 5/7/2016              | WS- 008172      | Cooler      | 2     | In room E214 Right Low                         | WT-042916-8189- A    | < 1                            | WT-042916-8189- B    | < 1                            |             |             |                 |                 |
| COLUMBIA HEIGHTS EDUCATIONAL CAMPUS | 5/7/2016              | WS- 008171      | Cooler      | 2     | In room E214 Girls Locker room Left High       | WT-042916-8188- A    | < 1                            | WT-042916-8188- B    | < 1                            |             |             |                 |                 |
| COLUMBIA HEIGHTS EDUCATIONAL CAMPUS | 5/7/2016              | WS- 008170      | Cooler      | 2     | In room E231 locker room                       | WT-042916-8187- A    | < 1                            | WT-042916-8187- B    | < 1                            |             |             |                 |                 |
| COLUMBIA HEIGHTS EDUCATIONAL CAMPUS | 5/7/2016              | WS- 008169      | Cooler      | 2     | In room E231 Left High                         | WT-042916-8186- A    | < 1                            | WT-042916-8186- B    | < 1                            |             |             |                 |                 |
| COLUMBIA HEIGHTS EDUCATIONAL CAMPUS | 5/7/2016              | WS- 008168      | Classroom   | 3     | In classroom C323 middle                       | WT-042916-8185- A    | 3.6                            | WT-042916-8185- B    | 4.2                            |             |             |                 |                 |
| COLUMBIA HEIGHTS EDUCATIONAL CAMPUS | 5/7/2016              | WS- 008167      | Classroom   | 3     | In Classroom C323 LHS 6                        | WT-042916-8184- A    | 3.6                            | WT-042916-8184- B    | 10.8                           |             |             |                 |                 |
| COLUMBIA HEIGHTS EDUCATIONAL CAMPUS | 5/7/2016              | WS- 008166      | Classroom   | 3     | In classroom C323 LHS6                         | WT-042916-8183- A    | 4.8                            | WT-042916-8183- B    | 4.6                            |             |             |                 |                 |
| COLUMBIA HEIGHTS EDUCATIONAL CAMPUS | 5/7/2016              | WS- 008165      | Classroom   | 3     | In classroom C323                              | WT-042916-8182- A    | 2.7                            | WT-042916-8182- B    | 4.4                            |             |             |                 |                 |
| COLUMBIA HEIGHTS EDUCATIONAL CAMPUS | 5/7/2016              | WS- 008164      | Classroom   | 3     | In classroom C323 LHS4 Left                    | WT-042916-8181- A    | 3.9                            | WT-042916-8181- B    | 16.1                           |             |             |                 |                 |
| COLUMBIA HEIGHTS EDUCATIONAL CAMPUS | 5/7/2016              | WS- 008163      | Classroom   | 3     | In classroom C323 LHS3                         | WT-042916-8180- A    | 16                             | WT-042916-8180- B    | 2.8                            |             |             |                 |                 |
| COLUMBIA HEIGHTS EDUCATIONAL CAMPUS | 5/7/2016              | WS- 008162      | Classroom   | 3     | In classroom C323 LHS 2 Left                   | WT-042916-8179- A    | 3.2                            | WT-042916-8179- B    | 34.9                           |             |             |                 |                 |
| COLUMBIA HEIGHTS EDUCATIONAL CAMPUS | 5/7/2016              | WS- 008161      | Classroom   | 3     | In classroom C323 LHS 1                        | WT-042916-8178- A    | 30.6                           | WT-042916-8178- B    | 14.4                           |             |             |                 |                 |
| COLUMBIA HEIGHTS EDUCATIONAL CAMPUS | 5/7/2016              | WS- 008160      | Cooler      | 3     | In hallway adjacent to the bathrooms Right     | WT-042916-8177- A    | < 1                            | WT-042916-8177- B    | < 1                            |             |             |                 |                 |
| COLUMBIA HEIGHTS EDUCATIONAL CAMPUS | 5/7/2016              | WS- 008159      | Cooler      | 3     | In hallway adjacent to the bathrooms Left High | WT-042916-8176- A    | < 1                            | WT-042916-8176- B    | < 1                            |             |             |                 |                 |
| COLUMBIA HEIGHTS EDUCATIONAL CAMPUS | 5/7/2016              | WS- 008158      | Kitchen     | 3     | In classroom C304A Right                       | WT-042916-8175- A    | 95                             | WT-042916-8175- B    | 6.7                            |             |             |                 |                 |
| COLUMBIA HEIGHTS EDUCATIONAL CAMPUS | 5/7/2016              | WS- 008157      | Kitchen     | 3     | In room C304A                                  | WT-042916-8174- A    | < 1                            | WT-042916-8174- B    | < 1                            |             |             |                 |                 |
| COLUMBIA HEIGHTS EDUCATIONAL CAMPUS | 5/7/2016              | WS- 008156      | Classroom   | 2     | In classroom C218                              | WT-042916-8173- A    | 1.8                            | WT-042916-8173- B    | < 1                            |             |             |                 |                 |
| COLUMBIA HEIGHTS EDUCATIONAL CAMPUS | 5/7/2016              | WS- 008154      | Classroom   | 2     | In classroom C229 LHS7 Left                    | WT-042916-8171- A    | 72.7                           | WT-042916-8171- B    | 13                             |             |             |                 |                 |
| COLUMBIA HEIGHTS EDUCATIONAL CAMPUS | 5/7/2016              | WS- 008153      | Classroom   | 2     | In classroom C229 LHS6 Left                    | WT-042916-8170- A    | 67.2                           | WT-042916-8170- B    | 16.3                           |             |             |                 |                 |
| COLUMBIA HEIGHTS EDUCATIONAL CAMPUS | 5/7/2016              | WS- 008152      | Classroom   | 2     | In classroom C229 LHS5 Left                    | WT-042916-8169- A    | 30.8                           | WT-042916-8169- B    | < 1                            |             |             |                 |                 |
| COLUMBIA HEIGHTS EDUCATIONAL CAMPUS | 5/7/2016              | WS- 008151      | Classroom   | 2     | In classroom C229 LHS4 Left                    | WT-042916-8168- A    | 27.8                           | WT-042916-8168- B    | 1.3                            |             |             |                 |                 |
| COLUMBIA HEIGHTS EDUCATIONAL CAMPUS | 5/7/2016              | WS- 008150      | Classroom   | 2     | In classroom C229 LHS3 Left                    | WT-042916-8167- A    | 68.9                           | WT-042916-8167- B    | 1.1                            |             |             |                 |                 |
| COLUMBIA HEIGHTS EDUCATIONAL CAMPUS | 5/7/2016              | WS- 008149      | Classroom   | 2     | In classroom C229 LHS2 Left                    | WT-042916-8166- A    | 127                            | WT-042916-8166- B    | 4.8                            |             |             |                 |                 |
| COLUMBIA HEIGHTS EDUCATIONAL CAMPUS | 5/7/2016              | WS- 008148      | Classroom   | 2     | In classroom C229 LHS1 Left                    | WT-042916-8165- A    | 15.2                           | WT-042916-8165- B    | 7.1                            |             |             |                 |                 |



# COLUMBIA HEIGHTS LEAD WATER TEST RESULTS

May 16th, 2016



| Building Location                   | Sample Collected Date | Water Source ID | Device Type | Floor | Device Location                                 | 1st Draw - Sample ID | Final Result - 1st Draw (ug/L) | 2nd Draw - Sample ID | Final Result - 2nd Draw (ug/L) | Remediation                                | Retest Date | Retest 1st Draw | Retest 2nd Draw |
|-------------------------------------|-----------------------|-----------------|-------------|-------|---|----------------------|--------------------------------|----------------------|--------------------------------|--|-------------|-----------------|-----------------|
| COLUMBIA HEIGHTS EDUCATIONAL CAMPUS | 5/7/2016              | WS- 008147      | Classroom   | 2     | In room C228                                    | WT-042916-8164- A    | 11                             | WT-042916-8164- B    | 10.6                           |  |             |                 |                 |
| COLUMBIA HEIGHTS EDUCATIONAL CAMPUS | 5/7/2016              | WS- 008146      | Classroom   | 2     | In classroom C227 middle sink                   | WT-042916-8163- A    | 58.7                           | WT-042916-8163- B    | 3.1                            |  |             |                 |                 |
| COLUMBIA HEIGHTS EDUCATIONAL CAMPUS | 5/7/2016              | WS- 008145      | Classroom   | 2     | In classroom C227 LHS 7                         | WT-042916-8162- A    | 6.3                            | WT-042916-8162- B    | < 1                            |  |             |                 |                 |
| COLUMBIA HEIGHTS EDUCATIONAL CAMPUS | 5/7/2016              | WS- 008144      | Classroom   | 2     | In classroom C227 LHS 6 Left                    | WT-042916-8161- A    | 179                            | WT-042916-8161- B    | 5.4                            |  |             |                 |                 |
| COLUMBIA HEIGHTS EDUCATIONAL CAMPUS | 5/7/2016              | WS- 008143      | Classroom   | 2     | In classroom C227 LHS5                          | WT-042916-8160- A    | 9.8                            | WT-042916-8160- B    | 11.1                           |  |             |                 |                 |
| COLUMBIA HEIGHTS EDUCATIONAL CAMPUS | 5/7/2016              | WS- 008142      | Classroom   | 2     | In classroom C227 LHS 4 Left                    | WT-042916-8159- A    | 172                            | WT-042916-8159- B    | 8.9                            |  |             |                 |                 |
| COLUMBIA HEIGHTS EDUCATIONAL CAMPUS | 5/7/2016              | WS- 008141      | Classroom   | 2     | In classroom C227 LHS 3 Left                    | WT-042916-8158- A    | 15.3                           | WT-042916-8158- B    | 1.7                            |  |             |                 |                 |
| COLUMBIA HEIGHTS EDUCATIONAL CAMPUS | 5/7/2016              | WS- 008140      | Classroom   | 2     | In classroom C227 LHS 2 Left                    | WT-042916-8157- A    | < 1                            | WT-042916-8157- B    | < 1                            |  |             |                 |                 |
| COLUMBIA HEIGHTS EDUCATIONAL CAMPUS | 5/7/2016              | WS- 008139      | Classroom   | 2     | In classroom C227 LHS 1 Left                    | WT-042916-8156- A    | 3.8                            | WT-042916-8156- B    | 1.2                            |  |             |                 |                 |
| COLUMBIA HEIGHTS EDUCATIONAL CAMPUS | 5/7/2016              | WS- 008117      | Kitchen     | 1     | In kitchen middle sink                          | WT-042916-8134- A    | 2.6                            | WT-042916-8134- B    | < 1                            |  |             |                 |                 |
| COLUMBIA HEIGHTS EDUCATIONAL CAMPUS | 5/7/2016              | WS- 008116      | Kitchen     | 1     | In kitchen ice maker                            | WT-042916-8133- A    | 1.8                            | WT-042916-8133- B    | 1.2                            |  |             |                 |                 |
| COLUMBIA HEIGHTS EDUCATIONAL CAMPUS | 5/7/2016              | WS- 008115      | Kitchen     | 1     | In kitchen grill washer                         | WT-042916-8132- A    | < 1                            | WT-042916-8132- B    | < 1                            |  |             |                 |                 |
| COLUMBIA HEIGHTS EDUCATIONAL CAMPUS | 5/7/2016              | WS- 008114      | Kitchen     | 1     | In kitchen east wall first from left            | WT-042916-8131- A    | < 1                            | WT-042916-8131- B    | < 1                            |  |             |                 |                 |
| COLUMBIA HEIGHTS EDUCATIONAL CAMPUS | 5/7/2016              | WS- 008113      | Kitchen     | 1     | In kitchen east wall second from left Mid       | WT-042916-8130- A    | < 1                            | WT-042916-8130- B    | < 1                            |  |             |                 |                 |
| COLUMBIA HEIGHTS EDUCATIONAL CAMPUS | 5/7/2016              | WS- 008112      | Kitchen     | 1     | In kitchen east wall third from left Right      | WT-042916-8129- A    | 2.5                            | WT-042916-8129- B    | < 1                            |  |             |                 |                 |
| COLUMBIA HEIGHTS EDUCATIONAL CAMPUS | 5/7/2016              | WS- 008111      | Kitchen     | 1     | In kitchen last from left Right                 | WT-042916-8128- A    | < 1                            | WT-042916-8128- B    | < 1                            |  |             |                 |                 |
| COLUMBIA HEIGHTS EDUCATIONAL CAMPUS | 5/7/2016              | WS- 008110      | Kitchen     | 1     | In kitchen north wall second from left Mid      | WT-042916-8127- A    | < 1                            | WT-042916-8127- B    | < 1                            |  |             |                 |                 |
| COLUMBIA HEIGHTS EDUCATIONAL CAMPUS | 5/7/2016              | WS- 008109      | Kitchen     | 1     | In kitchen first from left(shower head) Left    | WT-042916-8126- A    | < 1                            | WT-042916-8126- B    | < 1                            |  |             |                 |                 |
| COLUMBIA HEIGHTS EDUCATIONAL CAMPUS | 5/7/2016              | WS- 008108      | Classroom   | 2     | In room 208A Dining line                        | WT-042916-8125- A    | < 1                            | WT-042916-8125- B    | < 1                            |  |             |                 |                 |
| COLUMBIA HEIGHTS EDUCATIONAL CAMPUS | 5/7/2016              | WS- 008107      | Cooler      | 2     | In hallway adjacent to the stairs Right High    | WT-042916-8124- A    | < 1                            | WT-042916-8124- B    | < 1                            |  |             |                 |                 |
| COLUMBIA HEIGHTS EDUCATIONAL CAMPUS | 5/7/2016              | WS- 008106      | Cooler      | 2     | In hallway adjacent to the stairs Right Low     | WT-042916-8123- A    | < 1                            | WT-042916-8123- B    | < 1                            |  |             |                 |                 |
| COLUMBIA HEIGHTS EDUCATIONAL CAMPUS | 5/7/2016              | WS- 008105      | Cooler      | 2     | In hallway adjacent to the stairwell 2 Left Low | WT-042916-8122- A    | 1.2                            | WT-042916-8122- B    | 145                            | Filter will be installed and then retested |             |                 |                 |
| COLUMBIA HEIGHTS EDUCATIONAL CAMPUS | 5/7/2016              | WS- 008104      | Cooler      | 2     | In hallway adjacent to stairway 2 Left High     | WT-042916-8121- A    | 103                            | WT-042916-8121- B    | 189                            | Filter will be installed and then retested |             |                 |                 |
| COLUMBIA HEIGHTS EDUCATIONAL CAMPUS | 5/7/2016              | WS- 008103      | Cooler      | 2     | In hallway adjacent to classroom A206 Right Low | WT-042916-8120- A    | < 1                            | WT-042916-8120- B    | < 1                            |  |             |                 |                 |
| COLUMBIA HEIGHTS EDUCATIONAL CAMPUS | 5/7/2016              | WS- 008102      | Cooler      | 2     | In hallway adjacent to room A206 Right Low      | WT-042916-8119- A    | < 1                            | WT-042916-8119- B    | < 1                            |  |             |                 |                 |
| COLUMBIA HEIGHTS EDUCATIONAL CAMPUS | 5/7/2016              | WS- 008101      | Cooler      | 2     | In hallway adjacent to classroom A206 Left Low  | WT-042916-8118- A    | < 1                            | WT-042916-8118- B    | < 1                            |  |             |                 |                 |
| COLUMBIA HEIGHTS EDUCATIONAL CAMPUS | 5/7/2016              | WS- 008100      | Cooler      | 2     | In hallway adjacent to A206 Left High           | WT-042916-8117- A    | < 1                            | WT-042916-8117- B    | < 1                            |  |             |                 |                 |
| COLUMBIA HEIGHTS EDUCATIONAL CAMPUS | 5/7/2016              | WS- 008099      | Classroom   | 2     | In room A206 Left                               | WT-042916-8116- A    | 1.2                            | WT-042916-8116- B    | 1.9                            |  |             |                 |                 |
| COLUMBIA HEIGHTS EDUCATIONAL CAMPUS | 5/7/2016              | WS- 008098      | Classroom   | 2     | In room A214 LHS1 Left                          | WT-042916-8115- A    | < 1                            | WT-042916-8115- B    | < 1                            |  |             |                 |                 |
| COLUMBIA HEIGHTS EDUCATIONAL CAMPUS | 5/7/2016              | WS- 008097      | Classroom   | 2     | In room A214 LHS1 Left                          | WT-042916-8114- A    | < 1                            | WT-042916-8114- B    | < 1                            |  |             |                 |                 |
| COLUMBIA HEIGHTS EDUCATIONAL CAMPUS | 5/7/2016              | WS- 008096      | Classroom   | 2     | In classroom A234                               | WT-042916-8113- A    | 3.7                            | WT-042916-8113- B    | < 1                            |  |             |                 |                 |
| COLUMBIA HEIGHTS EDUCATIONAL CAMPUS | 5/7/2016              | WS- 008095      | Classroom   | 2     | In classroom A238 middle                        | WT-042916-8112- A    | 7.1                            | WT-042916-8112- B    | < 1                            |  |             |                 |                 |
| COLUMBIA HEIGHTS EDUCATIONAL CAMPUS | 5/7/2016              | WS- 008094      | Classroom   | 2     | In classroom A238 LHS6 Left                     | WT-042916-8111- A    | 38.2                           | WT-042916-8111- B    | 1.1                            |  |             |                 |                 |
| COLUMBIA HEIGHTS EDUCATIONAL CAMPUS | 5/7/2016              | WS- 008093      | Classroom   | 2     | In classroom A238 LHS 5 Left                    | WT-042916-8110- A    | 90                             | WT-042916-8110- B    | < 1                            |  |             |                 |                 |
| COLUMBIA HEIGHTS EDUCATIONAL CAMPUS | 5/7/2016              | WS- 008092      | Classroom   | 2     | In room A238 LHS4 Left                          | WT-042916-8109- A    | 9.3                            | WT-042916-8109- B    | 1.6                            |  |             |                 |                 |
| COLUMBIA HEIGHTS EDUCATIONAL CAMPUS | 5/7/2016              | WS- 008091      | Classroom   | 2     | In room A238 LHS3 Left                          | WT-042916-8108- A    | 6.2                            | WT-042916-8108- B    | 1.9                            |  |             |                 |                 |



# COLUMBIA HEIGHTS LEAD WATER TEST RESULTS

May 16th, 2016



|     | Building Location                   | Sample Collected Date | Water Source ID | Device Type | Floor | Device Location  | 1st Draw - Sample ID | Final Result - 1st Draw (ug/L) | 2nd Draw - Sample ID | Final Result - 2nd Draw (ug/L) | Remediation | Retest Date | Retest 1st Draw | Retest 2nd Draw |
|-----|-------------------------------------|-----------------------|-----------------|-------------|-------|--|----------------------|--------------------------------|----------------------|--------------------------------|-------------|-------------|-----------------|-----------------|
| 109 | COLUMBIA HEIGHTS EDUCATIONAL CAMPUS | 5/7/2016              | WS- 008090      | Classroom   | 2     | In classroom A238 LHS 2                                    | WT-042916-8107- A    | 107                            | WT-042916-8107- B    | 1.7                            |             |             |                 |                 |
| 110 | COLUMBIA HEIGHTS EDUCATIONAL CAMPUS | 5/7/2016              | WS- 008089      | Classroom   | 2     | In classroom 238 LHS 1 Left                                | WT-042916-8106- A    | 14.4                           | WT-042916-8106- B    | 2.2                            |             |             |                 |                 |
| 111 | COLUMBIA HEIGHTS EDUCATIONAL CAMPUS | 5/7/2016              | WS- 008088      | Classroom   | 2     | In room A239   | WT-042916-8105- A    | < 1                            | WT-042916-8105- B    | < 1                            |             |             |                 |                 |
| 112 | COLUMBIA HEIGHTS EDUCATIONAL CAMPUS | 5/7/2016              | WS- 008087      | Classroom   | 2     | In room A240 Mid   | WT-042916-8104- A    | 4.6                            | WT-042916-8104- B    | < 1                            |             |             |                 |                 |
| 113 | COLUMBIA HEIGHTS EDUCATIONAL CAMPUS | 5/7/2016              | WS- 008086      | Classroom   | 2     | In room A240 Left  | WT-042916-8103- A    | 3.6                            | WT-042916-8103- B    | 2.7                            |             |             |                 |                 |
| 114 | COLUMBIA HEIGHTS EDUCATIONAL CAMPUS | 5/7/2016              | WS- 008085      | Classroom   | 2     | In room A240 LHS5  | WT-042916-8102- A    | < 1                            | WT-042916-8102- B    | < 1                            |             |             |                 |                 |
| 115 | COLUMBIA HEIGHTS EDUCATIONAL CAMPUS | 5/7/2016              | WS- 008084      | Classroom   | 2     | In classroom A240 LHS4 Left                                | WT-042916-8101- A    | 51.2                           | WT-042916-8101- B    | 7.9                            |             |             |                 |                 |
| 116 | COLUMBIA HEIGHTS EDUCATIONAL CAMPUS | 5/7/2016              | WS- 008083      | Classroom   | 2     | In room A240 LHS3 Left                                     | WT-042916-8100- A    | 2.5                            | WT-042916-8100- B    | 1.1                            |             |             |                 |                 |
| 117 | COLUMBIA HEIGHTS EDUCATIONAL CAMPUS | 5/7/2016              | WS- 008082      | Classroom   | 2     | In room A240 LHS2 Left                                     | WT-042916-8099- A    | 1.4                            | WT-042916-8099- B    | < 1                            |             |             |                 |                 |
| 118 | COLUMBIA HEIGHTS EDUCATIONAL CAMPUS | 5/7/2016              | WS- 008081      | Classroom   | 2     | In room A240 LHS1 Left                                     | WT-042916-8098- A    | 2.5                            | WT-042916-8098- B    | 2.9                            |             |             |                 |                 |
| 119 | COLUMBIA HEIGHTS EDUCATIONAL CAMPUS | 5/7/2016              | WS- 008080      | Classroom   | 1     | In classroom A161  | WT-042916-8097- A    | 26.4                           | WT-042916-8097- B    | < 1                            |             |             |                 |                 |
| 120 | COLUMBIA HEIGHTS EDUCATIONAL CAMPUS | 5/7/2016              | WS- 008079      | Classroom   | 1     | In classroom A161  | WT-042916-8096- A    | 14.8                           | WT-042916-8096- B    | < 1                            |             |             |                 |                 |
| 121 | COLUMBIA HEIGHTS EDUCATIONAL CAMPUS | 5/7/2016              | WS- 008078      | Classroom   | 1     | In room A160 Mid   | WT-042916-8095- A    | 1.3                            | WT-042916-8095- B    | 3.7                            |             |             |                 |                 |
| 122 | COLUMBIA HEIGHTS EDUCATIONAL CAMPUS | 5/7/2016              | WS- 008077      | Classroom   | 1     | In room A160 LHS6 Left                                     | WT-042916-8094- A    | 2.4                            | WT-042916-8094- B    | < 1                            |             |             |                 |                 |
| 123 | COLUMBIA HEIGHTS EDUCATIONAL CAMPUS | 5/7/2016              | WS- 008076      | Classroom   | 1     | In classroom A160 LHS 5 Left                               | WT-042916-8093- A    | 33.2                           | WT-042916-8093- B    | 2.5                            |             |             |                 |                 |
| 124 | COLUMBIA HEIGHTS EDUCATIONAL CAMPUS | 5/7/2016              | WS- 008075      | Classroom   | 1     | In classroom A160 LHS4 Left                                | WT-042916-8092- A    | 255                            | WT-042916-8092- B    | 11.4                           |             |             |                 |                 |
| 125 | COLUMBIA HEIGHTS EDUCATIONAL CAMPUS | 5/7/2016              | WS- 008074      | Classroom   | 1     | In classroom A160 LHS3 Left                                | WT-042916-8091- A    | 18.2                           | WT-042916-8091- B    | 5.2                            |             |             |                 |                 |
| 126 | COLUMBIA HEIGHTS EDUCATIONAL CAMPUS | 5/7/2016              | WS- 008073      | Classroom   | 1     | In classroom A160 LHS 2 Left                               | WT-042916-8090- A    | 126                            | WT-042916-8090- B    | 2.2                            |             |             |                 |                 |
| 127 | COLUMBIA HEIGHTS EDUCATIONAL CAMPUS | 5/7/2016              | WS- 008072      | Classroom   | 1     | In classroom A160 LHS1 Left                                | WT-042916-8089- A    | 20.4                           | WT-042916-8089- B    | 1                              |             |             |                 |                 |
| 128 | COLUMBIA HEIGHTS EDUCATIONAL CAMPUS | 5/7/2016              | WS- 008071      | Classroom   | 1     | In room A156 south wall                                    | WT-042916-8088- A    | 2.2                            | WT-042916-8088- B    | < 1                            |             |             |                 |                 |
| 129 | COLUMBIA HEIGHTS EDUCATIONAL CAMPUS | 5/7/2016              | WS- 008070      | Classroom   | 1     | In room A148   | WT-042916-8087- A    | < 1                            | WT-042916-8087- B    | < 1                            |             |             |                 |                 |
| 130 | COLUMBIA HEIGHTS EDUCATIONAL CAMPUS | 5/7/2016              | WS- 008069      | Cooler      | 1     | In hallway across room A146 Left High                      | WT-042916-8086- A    | < 1                            | WT-042916-8086- B    | < 1                            |             |             |                 |                 |
| 131 | COLUMBIA HEIGHTS EDUCATIONAL CAMPUS | 5/7/2016              | WS- 008068      | Cooler      | 1     | In hallway across from room A146 Right Low                 | WT-042916-8085- A    | < 1                            | WT-042916-8085- B    | < 1                            |             |             |                 |                 |
| 132 | COLUMBIA HEIGHTS EDUCATIONAL CAMPUS | 5/7/2016              | WS- 008067      | Classroom   | 1     | In room A122   | WT-042916-8084- A    | < 1                            | WT-042916-8084- B    | < 1                            |             |             |                 |                 |
| 133 | COLUMBIA HEIGHTS EDUCATIONAL CAMPUS | 5/7/2016              | WS- 008066      | Classroom   | 1     | In room 119 west wall                                      | WT-042916-8083- A    | < 1                            | WT-042916-8083- B    | < 1                            |             |             |                 |                 |
| 134 | COLUMBIA HEIGHTS EDUCATIONAL CAMPUS | 5/7/2016              | WS- 008065      | Classroom   | 1     | In classroom A117 workroom Right Low                       | WT-042916-8082- A    | < 1                            | WT-042916-8082- B    | < 1                            |             |             |                 |                 |
| 135 | COLUMBIA HEIGHTS EDUCATIONAL CAMPUS | 5/7/2016              | WS- 008064      | Classroom   | 1     | In room A115 west wall                                     | WT-042916-8081- A    | < 1                            | WT-042916-8081- B    | < 1                            |             |             |                 |                 |
| 136 | COLUMBIA HEIGHTS EDUCATIONAL CAMPUS | 5/7/2016              | WS- 008063      | Classroom   | 1     | In room 107 south east wall                                | WT-042916-8080- A    | < 1                            | WT-042916-8080- B    | < 1                            |             |             |                 |                 |
| 137 | COLUMBIA HEIGHTS EDUCATIONAL CAMPUS | 5/7/2016              | WS- 008062      | Classroom   | 1     | In classroom B127 Dressing room                            | WT-042916-8079- A    | 11.9                           | WT-042916-8079- B    | < 1                            |             |             |                 |                 |
| 138 | COLUMBIA HEIGHTS EDUCATIONAL CAMPUS | 5/7/2016              | WS- 008061      | Classroom   | 1     | In classroom dressing room                                 | WT-042916-8078- A    | 2.7                            | WT-042916-8078- B    | < 1                            |             |             |                 |                 |
| 139 | COLUMBIA HEIGHTS EDUCATIONAL CAMPUS | 5/7/2016              | WS- 008060      | Classroom   | 1     | In classroom C109 workroom                                 | WT-042916-8077- A    | 5.3                            | WT-042916-8077- B    | < 1                            |             |             |                 |                 |
| 140 | COLUMBIA HEIGHTS EDUCATIONAL CAMPUS | 5/7/2016              | WS- 008059      | Classroom   | 1     | In classroom C117 Breakroom                                | WT-042916-8076- A    | < 1                            | WT-042916-8076- B    | < 1                            |             |             |                 |                 |
| 141 | COLUMBIA HEIGHTS EDUCATIONAL CAMPUS | 5/7/2016              | WS- 008058      | Classroom   | 1     | In classroom 112 duplication center                        | WT-042916-8075- A    | < 1                            | WT-042916-8075- B    | 2.8                            |             |             |                 |                 |
| 142 | COLUMBIA HEIGHTS EDUCATIONAL CAMPUS | 5/7/2016              | WS- 008057      | Cooler      | 1     | In hallway adjacent to janitor closet room C135 Right High | WT-042916-8074- A    | < 1                            | WT-042916-8074- B    | < 1                            |             |             |                 |                 |
| 143 | COLUMBIA HEIGHTS EDUCATIONAL CAMPUS | 5/7/2016              | WS- 008056      | Cooler      | 1     | In hallway adjacent to janitor closet room C135 Left Low   | WT-042916-8073- A    | < 1                            | WT-042916-8073- B    | < 1                            |             |             |                 |                 |
| 144 | COLUMBIA HEIGHTS EDUCATIONAL CAMPUS | 5/7/2016              | WS- 008055      | Classroom   | 1     | In classroom 146   | WT-042916-8072- A    | 2                              | WT-042916-8072- B    | < 1                            |             |             |                 |                 |



# COLUMBIA HEIGHTS LEAD WATER TEST RESULTS

May 16th, 2016



|     | Building Location                   | Sample Collected Date | Water Source ID | Device Type | Floor    | Device Location          | 1st Draw - Sample ID | Final Result - 1st Draw (ug/L) | 2nd Draw - Sample ID | Final Result - 2nd Draw (ug/L) | Remediation | Retest Date  | Retest 1st Draw | Retest 2nd Draw |
|-----|-------------------------------------|-----------------------|-----------------|-------------|----------|--------------------------|----------------------|--------------------------------|----------------------|--------------------------------|-------------|--|-----------------|-----------------|
| 145 | COLUMBIA HEIGHTS EDUCATIONAL CAMPUS | 5/7/2016              | WS- 008054      | Classroom   | 1        | In classroom C141 middle | Mid                  | WT-042916-8071- A              | 15.4                 | WT-042916-8071- B              | 3.5         |  |                 |                 |
| 146 | COLUMBIA HEIGHTS EDUCATIONAL CAMPUS | 5/7/2016              | WS- 008053      | Classroom   | 1        | In classroom C141 LHS 7  | Left                 | WT-042916-8070- A              | 21                   | WT-042916-8070- B              | 81.6        |  |                 |                 |
| 147 | COLUMBIA HEIGHTS EDUCATIONAL CAMPUS | 5/7/2016              | WS- 008052      | Classroom   | 1        | In classroom C141 LHS 6  | Left                 | WT-042916-8069- A              | 112                  | WT-042916-8069- B              | < 1         |  |                 |                 |
| 148 | COLUMBIA HEIGHTS EDUCATIONAL CAMPUS | 5/7/2016              | WS- 008051      | Classroom   | 1        | In classroom C141 LHS 5  | Left                 | WT-042916-8068- A              | 129                  | WT-042916-8068- B              | 2.3         |  |                 |                 |
| 149 | COLUMBIA HEIGHTS EDUCATIONAL CAMPUS | 5/7/2016              | WS- 008050      | Classroom   | 1        | In classroom C141 LHS 4  | Left                 | WT-042916-8067- A              | 14                   | WT-042916-8067- B              | 2.5         |  |                 |                 |
| 150 | COLUMBIA HEIGHTS EDUCATIONAL CAMPUS | 5/7/2016              | WS- 008049      | Classroom   | 1        | In classroom C141 LHS 3  | Left                 | WT-042916-8066- A              | 133                  | WT-042916-8066- B              | 8.8         |  |                 |                 |
| 151 | COLUMBIA HEIGHTS EDUCATIONAL CAMPUS | 5/7/2016              | WS- 008048      | Classroom   | 1        | In classroom C141 LHS 2  | Left                 | WT-042916-8065- A              | 13.9                 | WT-042916-8065- B              | 1.5         |  |                 |                 |
| 152 | COLUMBIA HEIGHTS EDUCATIONAL CAMPUS | 5/7/2016              | WS- 008047      | Classroom   | 1        | In classroom C141 LHS 1  | Left                 | WT-042916-8064- A              | 2.4                  | WT-042916-8064- B              | < 1         |  |                 |                 |
| 153 | COLUMBIA HEIGHTS EDUCATIONAL CAMPUS | 5/7/2016              | WS- 008046      | Classroom   | 1        | In classroom C140        |                      | WT-042916-8063- A              | 5.3                  | WT-042916-8063- B              | 1.2         |  |                 |                 |
| 154 | COLUMBIA HEIGHTS EDUCATIONAL CAMPUS | 5/7/2016              | WS- 008045      | Classroom   | 1        | In classroom C139 middle |                      | WT-042916-8062- A              | 236                  | WT-042916-8062- B              | 57.6        |  |                 |                 |
| 155 | COLUMBIA HEIGHTS EDUCATIONAL CAMPUS | 5/7/2016              | WS- 008044      | Classroom   | 1        | In classroom C139 LHS 7  | Left                 | WT-042916-8061- A              | 1.8                  | WT-042916-8061- B              | < 1         |  |                 |                 |
| 156 | COLUMBIA HEIGHTS EDUCATIONAL CAMPUS | 5/7/2016              | WS- 008043      | Classroom   | 1        | In classroom C139 LHS 6  |                      | WT-042916-8060- A              | 17.6                 | WT-042916-8060- B              | 2.5         |  |                 |                 |
| 157 | COLUMBIA HEIGHTS EDUCATIONAL CAMPUS | 5/7/2016              | WS- 008042      | Classroom   | 1        | In classroom C139 LHS 5  |                      | WT-042916-8059- A              | 31.5                 | WT-042916-8059- B              | 13.2        |  |                 |                 |
| 158 | COLUMBIA HEIGHTS EDUCATIONAL CAMPUS | 5/7/2016              | WS- 008041      | Classroom   | 1        | In classroom C139 LHS4   | Left                 | WT-042916-8058- A              | 132                  | WT-042916-8058- B              | 2.7         |  |                 |                 |
| 159 | COLUMBIA HEIGHTS EDUCATIONAL CAMPUS | 5/7/2016              | WS- 008040      | Classroom   | 1        | In classroom C139 LHS 3  |                      | WT-042916-8057- A              | 190                  | WT-042916-8057- B              | 11.3        |  |                 |                 |
| 160 | COLUMBIA HEIGHTS EDUCATIONAL CAMPUS | 5/7/2016              | WS- 008039      | Classroom   | 1        | In classroom C139 LHS2   |                      | WT-042916-8056- A              | 102                  | WT-042916-8056- B              | 19.3        |  |                 |                 |
| 161 | COLUMBIA HEIGHTS EDUCATIONAL CAMPUS | 5/7/2016              | WS- 008038      | Classroom   | 1        | In classroom C139 LHS 1  |                      | WT-042916-8055- A              | 16.9                 | WT-042916-8055- B              | 22.2        |  |                 |                 |
| 162 | COLUMBIA HEIGHTS EDUCATIONAL CAMPUS | 5/7/2016              | WS- 008037      | Classroom   | 1        | In classroom D105        |                      | WT-042916-8054- A              | < 1                  | WT-042916-8054- B              | < 1         |  |                 |                 |
| 163 | COLUMBIA HEIGHTS EDUCATIONAL CAMPUS | 5/7/2016              | WS- 008036      | Classroom   | 1        | In classroom D110 LHS 4  |                      | WT-042916-8053- A              | 161                  | WT-042916-8053- B              | 3.4         |  |                 |                 |
| 164 | COLUMBIA HEIGHTS EDUCATIONAL CAMPUS | 5/7/2016              | WS- 008035      | Classroom   | 1        | In classroom D110 LHS 3  |                      | WT-042916-8052- A              | 164                  | WT-042916-8052- B              | 5.8         |  |                 |                 |
| 165 | COLUMBIA HEIGHTS EDUCATIONAL CAMPUS | 5/7/2016              | WS- 008034      | Classroom   | 1        | In classroom D110 left 2 | Left                 | WT-042916-8051- A              | 1                    | WT-042916-8051- B              | < 1         |  |                 |                 |
| 166 | COLUMBIA HEIGHTS EDUCATIONAL CAMPUS | 5/7/2016              | WS- 008033      | Classroom   | 1        | In classroom D110 lhs 1  |                      | WT-042916-8050- A              | < 1                  | WT-042916-8050- B              | < 1         |  |                 |                 |
| 167 | COLUMBIA HEIGHTS EDUCATIONAL CAMPUS | 5/7/2016              | WS- 008032      | Classroom   | 1        | In classroom D113        |                      | WT-042916-8049- A              | < 1                  | WT-042916-8049- B              | < 1         |  |                 |                 |
| 168 | COLUMBIA HEIGHTS EDUCATIONAL CAMPUS | 5/7/2016              | WS- 008031      | Classroom   | 1        | In classroom D113        |                      | WT-042916-8048- A              | 1.2                  | WT-042916-8048- B              | < 1         |  |                 |                 |
| 169 | COLUMBIA HEIGHTS EDUCATIONAL CAMPUS | 5/7/2016              | WS- 008030      | Cooler      | 1        | In hallway next to D113  | Right Low            | WT-042916-8047- A              | 1.3                  | WT-042916-8047- B              | 2.7         |  |                 |                 |
| 170 | COLUMBIA HEIGHTS EDUCATIONAL CAMPUS | 5/7/2016              | WS- 008029      | Cooler      | 1        | In hallway next to D113  | Left High            | WT-042916-8046- A              | < 1                  | WT-042916-8046- B              | 2.8         |  |                 |                 |
| 171 | COLUMBIA HEIGHTS EDUCATIONAL CAMPUS | 5/7/2016              | WS- 008028      | Classroom   | 1        | In classroom 121A        | Left                 | WT-042916-8045- A              | < 1                  | WT-042916-8045- B              | < 1         |  |                 |                 |
| 172 | COLUMBIA HEIGHTS EDUCATIONAL CAMPUS | 5/7/2016              | WS- 008027      | Classroom   | 1        | In classroom 121A        | Right Low            | WT-042916-8044- A              | < 1                  | WT-042916-8044- B              | < 1         |  |                 |                 |
| 173 | COLUMBIA HEIGHTS EDUCATIONAL CAMPUS | 5/7/2016              | WS- 008026      | Classroom   | 1        | In classroom 121A        |                      | WT-042916-8043- A              | < 1                  | WT-042916-8043- B              | < 1         |  |                 |                 |
| 174 | COLUMBIA HEIGHTS EDUCATIONAL CAMPUS | 5/7/2016              | WS- 008025      | Classroom   | 1        | In classroom 121A        |                      | WT-042916-8042- A              | < 1                  | WT-042916-8042- B              | < 1         |  |                 |                 |
| 175 | COLUMBIA HEIGHTS EDUCATIONAL CAMPUS | 5/7/2016              | WS- 008021      | Classroom   | 1        | In class 123             |                      | WT-042916-8038- A              | < 1                  | WT-042916-8038- B              | < 1         |  |                 |                 |
| 176 | COLUMBIA HEIGHTS EDUCATIONAL CAMPUS | 5/7/2016              | WS- 008020      | Classroom   | 1        | In classroom 111         |                      | WT-042916-8037- A              | < 1                  | WT-042916-8037- B              | < 1         |  |                 |                 |
| 177 | COLUMBIA HEIGHTS EDUCATIONAL CAMPUS | 5/7/2016              | WS- 008019      | Utility     | Basement | In pump room             |                      | WT-042916-8036- A              | 73.8                 | WT-042916-8036- B              | 25.7        | Non-drinking water source turned off until further analysis complete |                 |                 |

Footnotes:

- A - First draw sample is collected after the plumbing system has not been used for at least 6 hours.
- B - Second draw sample is collected after a 60 second flush at that device after the first draw.