



# COLUMBIA HEIGHTS EC LEAD WATER TEST RESULTS



## Initial Filter Test After Installation

	Building Location: Building Name	RECORD ID	Date Analyzed	Floor	Device Type	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	Final Result - 2nd Draw (ppb)
1	COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	WS- 008060	12/12/2016	1	Break Room	In workroom C109	FT-102016-008060-A	< 1	FT-102016-008060-B	< 1
2	COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	WS- 008065	12/12/2016	1	Break Room	In workroom A117	FT-102016-008065-A	< 1	FT-102016-008065-B	< 1
3	COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	WS- 008059	12/12/2016	1	Break Room	In break room C117	FT-102016-008059-A	< 1	FT-102016-008059-B	< 1
4	COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	WS- 008157	12/12/2016	3	Break Room	In break room C304A	FT-102016-008157-A	< 1	FT-102016-008157-B	< 1
5	COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	WS- 008188	12/12/2016	4	Break Room	In work room A430	FT-102016-008188-A	< 1	FT-102016-008188-B	< 1
6	COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	WS- 008027	12/12/2016	1	Classroom Faucet	In classroom E121A third clockwise from entry door	FT-122016-008027-A	< 1	FT-122016-008027-B	< 1
7	COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	WS- 008026	12/12/2016	1	Classroom Faucet	In classroom E121A second clockwise from entry door	FT-122016-008026-A	< 1	FT-122016-008026-B	< 1
8	COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	WS- 008028	12/9/2016	1	Classroom Faucet	In classroom E121A fourth clockwise from entry door	FT-122016-008028-A	< 1	FT-122016-008028-B	< 1
9	COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	WS- 008025	12/12/2016	1	Classroom Faucet	In classroom E121A first clockwise from entry door	FT-122016-008025-A	< 1	FT-122016-008025-B	< 1
10	COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	WS- 008021	12/12/2016	1	Classroom Faucet	In classroom E123	FT-122016-008021-A	< 1	FT-122016-008021-B	< 1

Note :  
Filter re-tests are only performed to devices that have sampling results greater than 1 ppb