



# Columbia Heights RC Lead in Water Test Results

## FY21 Filter Test

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS- 003772	4/2/2020	4/2/2021	4	Cooler	In hallway adjacent to roof access 413 High	WF-04022020-003772	3/2/2021	FT-FY21-022021-003772-A	<1	FT-FY21-022021-003772-B	<1	
WS- 003773	4/2/2020	4/2/2021	4	Cooler	In hallway adjacent to roof access 413 Low	WF-04022020-003773	3/2/2021	FT-FY21-022021-003773-A	<1	FT-FY21-022021-003773-B	<1	
WS- 010070	4/2/2020	4/2/2021	1	Cooler	In hallway adjacent to room 115 High	WF-04022020-010070	3/2/2021	FT-FY21-022021-010070-A	<1	FT-FY21-022021-010070-B	<1	
WS- 010071	4/2/2020	4/2/2021	1	Cooler	In hallway adjacent to room 115 Low Right	WF-04022020-010071	3/2/2021	FT-FY21-022021-010071-A	<1	FT-FY21-022021-010071-B	<1	
WS- 010072	4/2/2020	4/2/2021	2	Cooler	In hallway adjacent to gym High	WF-04022020-010072	3/2/2021	FT-FY21-022021-010072-A	<1	FT-FY21-022021-010072-B	<1	
WS- 010073	4/2/2020	4/2/2021	2	Cooler	In hallway adjacent to gym Low	WF-04022020-010073	3/2/2021	FT-FY21-022021-010073-A	<1	FT-FY21-022021-010073-B	<1	
WS- 010075	4/2/2020	4/2/2021	3	Cooler	In hallway adjacent to room 305 High	WF-04022020-010075	3/2/2021	FT-FY21-022021-010075-A	<1	FT-FY21-022021-010075-B	<1	
WS- 010076	4/2/2020	4/2/2021	3	Cooler	In hallway adjacent to room 305 Low	WF-04022020-010076	3/2/2021	FT-FY21-022021-010076-A	<1	FT-FY21-022021-010076-B	<1	

## Food Prep Sink

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS- 003784	1/5/2021	1/5/2022	2	Food Prep Sink	In kitchen 202	WF-01052021-003784	3/2/2021	FT-FY21-022021-003784-A	<1	FT-FY21-022021-003784-B	<1	