



Columbia Heights Recreation Center Lead in Water Test Results

FY23 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 003772	3/16/2022	3/16/2023	4	Cooler	In hallway adjacent to roof access 413 High	WF-03162022-003772	1/27/2023	FT-FY23-01092023-003772-A	<1	FT-FY23-01092023-003772-B	<1
WS- 003773	3/16/2022	3/16/2023	4	Cooler	In hallway adjacent to roof access 413 Low	WF-03162022-003773	1/27/2023	FT-FY23-01092023-003773-A	<1	FT-FY23-01092023-003773-B	<1
WS- 003784	12/22/2022	12/22/2023	2	Food Prep Sink	In kitchen 202	WF-12222022-003784	1/27/2023	FT-FY23-01092023-003784-A	<1	FT-FY23-01092023-003784-B	<1
WS- 010070	3/16/2022	3/16/2023	1	Cooler	In hallway adjacent to room 115 High	WF-03162022-010070	1/27/2023	FT-FY23-01092023-010070-A	<1	FT-FY23-01092023-010070-B	<1
WS- 010071	3/16/2022	3/16/2023	1	Cooler	In hallway adjacent to room 115 Low Right	WF-03162022-010071	1/27/2023	FT-FY23-01092023-010071-A	<1	FT-FY23-01092023-010071-B	<1
WS- 010072	3/16/2022	3/16/2023	2	Cooler	In hallway adjacent to gym High	WF-03162022-010072	1/27/2023	FT-FY23-01092023-010072-A	<1	FT-FY23-01092023-010072-B	<1
WS- 010073	3/16/2022	3/16/2023	2	Cooler	In hallway adjacent to gym Low	WF-03162022-010073	1/27/2023	FT-FY23-01092023-010073-A	<1	FT-FY23-01092023-010073-B	<1
WS- 010075	3/16/2022	3/16/2023	3	Cooler	In hallway adjacent to room 305 High	WF-03162022-010075	1/27/2023	FT-FY23-01092023-010075-A	<1	FT-FY23-01092023-010075-B	<1
WS- 010076	3/16/2022	3/16/2023	3	Cooler	In hallway adjacent to room 305 Low	WF-03162022-010076	1/27/2023	FT-FY23-01092023-010076-A	<1	FT-FY23-01092023-010076-B	<1
WS- 010086	12/6/2022	12/6/2023	4	Bottle Filler	In hallway adjacent to 419 kitchen	WF-12062022-010086	1/27/2023	FT-FY23-01092023-010086-A	<1	FT-FY23-01092023-010086-B	<1
WS- 010087	12/6/2022	12/6/2023	4	Cooler	In hallway adjacent to 419 kitchen	WF-12062022-010087	1/27/2023	FT-FY23-01092023-010087-A	<1	FT-FY23-01092023-010087-B	<1