



Columbia Heights Rec Center Lead Water Test Results



FY18 Filter Test

Less than 5 ppb - Devices Requiring No Remediation

RECORD ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location		WATER FILTERS Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-003773	6/14/17	6/14/18	4	Cooler	In hallway adjacent to roof access 413	Low	WF-62017-003773	1/12/18	FT-FY18-062017-003773-A	<1	FT-FY18-062017-003773-B	<1
WS-010072	6/14/17	6/14/18	2	Cooler	In hallway adjacent to gym	High	WF-62017-010072	1/12/18	FT-FY18-062017-010072-A	<1	FT-FY18-062017-010072-B	<1
WS-010075	6/14/17	6/14/18	3	Cooler	In hallway adjacent to room 305	High	WF-62017-010075	1/12/18	FT-FY18-062017-010075-A	<1	FT-FY18-062017-010075-B	<1

Food Prep Sink

Less than 5 ppb - Devices Requiring No Remediation

RECORD ID	Floor	Device Type	Device Location	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-003784	1	Food Prep Sink	In kitchen 202	1/12/18	FT-FY18-062017-003784-A	<1	FT-FY18-062017-003784-B	<1