



Columbia Heights Recreation Center Lead in Water Test Results

FY24 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 003772	2/27/2024	2/27/2025	4	Cooler	In hallway adjacent to roof access 413 High	WF-02272024-003772	3/18/2024	FT-FY24-03052024-003772-A	<1	FT-FY24-03052024-003772-B	<1
WS- 003773	2/27/2024	2/27/2025	4	Cooler	In hallway adjacent to roof access 413 Low	WF-02272024-003773	3/18/2024	FT-FY24-03052024-003773-A	<1	FT-FY24-03052024-003773-B	<1
WS- 003784	11/21/2023	11/21/2024	2	Food Prep Sink	In kitchen 202	WF-11212023-003784	3/18/2024	FT-FY24-03052024-003784-A	<1	FT-FY24-03052024-003784-B	<1
WS- 010070	2/27/2024	2/27/2025	1	Cooler	In hallway adjacent to room 115 High	WF-02272024-010070	3/18/2024	FT-FY24-03052024-010070-A	<1	FT-FY24-03052024-010070-B	<1
WS- 010071	2/27/2024	2/27/2025	1	Cooler	In hallway adjacent to room 115 Low Right	WF-02272024-010071	3/18/2024	FT-FY24-03052024-010071-A	<1	FT-FY24-03052024-010071-B	<1
WS- 010072	2/27/2024	2/27/2025	2	Cooler	In hallway adjacent to gym High	WF-02272024-010072	3/18/2024	FT-FY24-03052024-010072-A	<1	FT-FY24-03052024-010072-B	<1
WS- 010073	2/27/2024	2/27/2025	2	Cooler	In hallway adjacent to gym Low	WF-02272024-010073	3/18/2024	FT-FY24-03052024-010073-A	<1	FT-FY24-03052024-010073-B	<1
WS- 010074	2/5/2024	2/5/2025	4	Break Room	In kitchen 419	WF-02052024-010074	3/18/2024	FT-FY24-03052024-010074-A	<1	FT-FY24-03052024-010074-B	<1
WS- 010075	2/27/2024	2/27/2025	3	Cooler	In hallway adjacent to room 305 High	WF-02272024-010075	3/18/2024	FT-FY24-03052024-010075-A	<1	FT-FY24-03052024-010075-B	<1
WS- 010076	2/27/2024	2/27/2025	3	Cooler	In hallway adjacent to room 305 Low	WF-02272024-010076	3/18/2024	FT-FY24-03052024-010076-A	<1	FT-FY24-03052024-010076-B	<1
WS- 010086	2/27/2024	2/27/2025	4	Bottle Filler	In boxing gym 420 adjacent to kitchen 419	WF-02272024-010086	3/18/2024	FT-FY24-03052024-010086-A	<1	FT-FY24-03052024-010086-B	<1
WS- 010087	2/27/2024	2/27/2025	4	Cooler	In boxing gym 420 adjacent to kitchen 419	WF-02272024-010087	3/18/2024	FT-FY24-03052024-010087-A	<1	FT-FY24-03052024-010087-B	<1