



Columbia Heights CC Lead Water Test Results



FY19 Filter Test

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location		Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 003772	4/28/2018	4/28/2019	4	Cooler	In hallway adjacent to roof access 413	High	WF-04282018-003772	2/5/2019	FT-FY19-012019-003772-A	<1	FT-FY19-012019-003772-B	<1
WS- 003773	4/28/2018	4/28/2019	4	Cooler	In hallway adjacent to roof access 413	Low	WF-04282018-003773	2/5/2019	FT-FY19-012019-003773-A	<1	FT-FY19-012019-003773-B	<1
WS- 010070	4/28/2018	4/28/2019	1	Cooler	In hallway adjacent to room 115	High	WF-04282018-010070	2/5/2019	FT-FY19-012019-010070-A	<1	FT-FY19-012019-010070-B	<1
WS- 010071	4/28/2018	4/28/2019	1	Cooler	In hallway adjacent to room 115	Low Right	WF-04282018-010071	2/5/2019	FT-FY19-012019-010071-A	<1	FT-FY19-012019-010071-B	<1
WS- 010072	4/28/2018	4/28/2019	2	Cooler	In hallway adjacent to gym	High	WF-04282018-010072	2/5/2019	FT-FY19-012019-010072-A	<1	FT-FY19-012019-010072-B	<1
WS- 010073	4/28/2018	4/28/2019	2	Cooler	In hallway adjacent to gym	Low	WF-04282018-010073	2/5/2019	FT-FY19-012019-010073-A	<1	FT-FY19-012019-010073-B	<1
WS- 010075	4/28/2018	4/28/2019	3	Cooler	In hallway adjacent to room 305	High	WF-04282018-010075	2/5/2019	FT-FY19-012019-010075-A	<1	FT-FY19-012019-010075-B	<1
WS- 010076	4/28/2018	4/28/2019	3	Cooler	In hallway adjacent to room 305	Low	WF-04282018-010076	2/5/2019	FT-FY19-012019-010076-A	<1	FT-FY19-012019-010076-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location		Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 003784	4/28/2018	4/28/2019	2	Food Prep Sink	In kitchen 202		WF-04282018-003784	2/5/2019	FT-FY19-012019-003784-A	<1	FT-FY19-012019-003784-B	<1