



COLUMBIA HEIGHTS REC LEAD WATER TEST RESULTS



	Building Location: Building Name	RECORD ID	Date Analyzed	Floor	Device Type	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)
1	COLUMBIA HEIGHTS RECREATION CENTER	WS- 003772	9/20/2016	4	Cooler	In hallway adjacent to roof access 413 High	FT-82016-003772-A	< 1	FT-82016-003772-B	< 1
2	COLUMBIA HEIGHTS RECREATION CENTER	WS- 003773	9/20/2016	4	Cooler	In hallway adjacent to roof access 413 Low	FT-82016-003773-A	< 1	FT-82016-003773-B	< 1
3	COLUMBIA HEIGHTS RECREATION CENTER	WS- 003784	9/20/2016	2	Food Prep Sink	In kitchen 202	FT-82016-003784-A	< 1	FT-82016-003784-B	< 1
4	COLUMBIA HEIGHTS RECREATION CENTER	WS- 010070	9/21/2016	1	Cooler	In hallway adjacent to room 115 High	FT-82016-010070-A	< 1	FT-82016-010070-B	< 1
5	COLUMBIA HEIGHTS RECREATION CENTER	WS- 010071	9/21/2016	1	Cooler	In hallway adjacent to room 115 Low	FT-82016-010071-A	< 1	FT-82016-010071-B	< 1
6	COLUMBIA HEIGHTS RECREATION CENTER	WS- 010072	9/21/2016	2	Cooler	In hallway adjacent to gym High	FT-82016-010072-A	< 1	FT-82016-010072-B	< 1
7	COLUMBIA HEIGHTS RECREATION CENTER	WS- 010073	9/21/2016	2	Cooler	In hallway adjacent to gym Low	FT-82016-010073-A	< 1	FT-82016-010073-B	< 1
8	COLUMBIA HEIGHTS RECREATION CENTER	WS- 010075	9/21/2016	3	Cooler	In hallway adjacent to room 305 High	FT-82016-010075-A	< 1	FT-82016-010075-B	< 1
9	COLUMBIA HEIGHTS RECREATION CENTER	WS- 010076	9/21/2016	3	Cooler	In hallway adjacent to room 305 Low	FT-82016-010076-A	< 1	FT-82016-010076-B	< 1