



# Columbia Heights EC Lead Water Test Results



## FY19 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS-002335	3/27/2018	3/27/2019	1	Health Suite	In health suite A138	WF-03272018-002335	12/20/2018	FT-FY19-122018-002335-A	<1	FT-FY19-122018-002335-B	<1	
WS-008021	10/22/2018	10/22/2019	1	Classroom Faucet	In classroom E123	WF-10222018-008021	12/20/2018	FT-FY19-122018-008021-A	<1	FT-FY19-122018-008021-B	<1	
WS-008025	10/22/2018	10/22/2019	1	Classroom Faucet	In classroom E121A first clockwise from entry door	WF-10222018-008025	12/20/2018	FT-FY19-122018-008025-A	<1	FT-FY19-122018-008025-B	<1	
WS-008026	10/22/2018	10/22/2019	1	Classroom Faucet	In classroom E121A second clockwise from entry door	WF-10222018-008026	12/20/2018	FT-FY19-122018-008026-A	<1	FT-FY19-122018-008026-B	<1	
WS-008027	10/22/2018	10/22/2019	1	Classroom Faucet	In classroom E121A third clockwise from entry door	WF-10222018-008027	12/20/2018	FT-FY19-122018-008027-A	2.1	FT-FY19-122018-008027-B	<1	
WS-008029	3/27/2018	3/27/2019	1	Cooler	In hallway adjacent to room D113	High Left	WF-03272018-008029	12/20/2018	FT-FY19-122018-008029-A	<1	FT-FY19-122018-008029-B	<1
WS-008030	3/27/2018	3/27/2019	1	Cooler	In hallway adjacent to room D113	Low Right	WF-03272018-008030	12/20/2018	FT-FY19-122018-008030-A	<1	FT-FY19-122018-008030-B	<1
WS-008056	9/28/2018	9/28/2019	1	Cooler	In hallway adjacent to room C135	Low Left	WF-09282018-008056	12/20/2018	FT-FY19-122018-008056-A	<1	FT-FY19-122018-008056-B	<1
WS-008057	9/28/2018	9/28/2019	1	Cooler	In hallway adjacent to room C135	High Right	WF-09282018-008057	12/20/2018	FT-FY19-122018-008057-A	<1	FT-FY19-122018-008057-B	<1
WS-008059	3/27/2018	3/27/2019	1	Break Room	In break room C117		WF-03272018-008059	12/20/2018	FT-FY19-122018-008059-A	<1	FT-FY19-122018-008059-B	<1
WS-008060	3/27/2018	3/27/2019	1	Break Room	In workroom C109		WF-03272018-008060	12/20/2018	FT-FY19-122018-008060-A	<1	FT-FY19-122018-008060-B	<1
WS-008065	3/27/2018	3/27/2019	1	Break Room	In workroom A117		WF-03272018-008065	12/20/2018	FT-FY19-122018-008065-A	<1	FT-FY19-122018-008065-B	<1
WS-008068	9/28/2018	9/28/2019	1	Cooler	In hallway across from room A146	Low Right	WF-09282018-008068	12/20/2018	FT-FY19-122018-008068-A	<1	FT-FY19-122018-008068-B	<1
WS-008069	9/28/2018	9/28/2019	1	Cooler	In hallway across from room A146	High Left	WF-09282018-008069	12/20/2018	FT-FY19-122018-008069-A	<1	FT-FY19-122018-008069-B	<1
WS-008100	3/27/2018	3/27/2019	2	Cooler	In hallway adjacent to room A206	High Left	WF-03272018-008100	12/20/2018	FT-FY19-122018-008100-A	<1	FT-FY19-122018-008100-B	<1
WS-008101	3/27/2018	3/27/2019	2	Cooler	In hallway adjacent to room A206	Low Right	WF-03272018-008101	12/20/2018	FT-FY19-122018-008101-A	<1	FT-FY19-122018-008101-B	<1
WS-008102	3/27/2018	3/27/2019	2	Cooler	In hallway adjacent to room A205	High Left	WF-03272018-008102	12/20/2018	FT-FY19-122018-008102-A	<1	FT-FY19-122018-008102-B	<1
WS-008103	3/27/2018	3/27/2019	2	Cooler	In hallway adjacent to room A205	Low Right	WF-03272018-008103	12/20/2018	FT-FY19-122018-008103-A	<1	FT-FY19-122018-008103-B	<1
WS-008105	3/27/2018	3/27/2019	2	Cooler	In hallway adjacent to stairwell 2	Low Left	WF-03272018-008105	12/20/2018	FT-FY19-122018-008105-A	<1	FT-FY19-122018-008105-B	<1
WS-008106	3/27/2018	3/27/2019	2	Cooler	In hallway adjacent to stairwell 2	Low Right	WF-03272018-008106	12/20/2018	FT-FY19-122018-008106-A	<1	FT-FY19-122018-008106-B	<1
WS-008107	3/27/2018	3/27/2019	2	Cooler	In hallway adjacent to stairwell 2	High Right	WF-03272018-008107	12/20/2018	FT-FY19-122018-008107-A	<1	FT-FY19-122018-008107-B	<1
WS-008116	3/27/2018	3/27/2019	1	Ice Maker	In kitchen (ice maker)		WF-03272018-008116	12/20/2018	FT-FY19-122018-008116-A	<1	FT-FY19-122018-008116-B	<1
WS-008157	3/27/2018	3/27/2019	3	Break Room	In break room C304A		WF-03272018-008157	12/20/2018	FT-FY19-122018-008157-A	<1	FT-FY19-122018-008157-B	<1
WS-008159	9/28/2018	9/28/2019	3	Cooler	In hallway adjacent to the restrooms	High Left	WF-09282018-008159	12/20/2018	FT-FY19-122018-008159-A	<1	FT-FY19-122018-008159-B	<1
WS-008160	9/28/2018	9/28/2019	3	Cooler	In hallway adjacent to the restrooms	Low Right	WF-09282018-008160	12/20/2018	FT-FY19-122018-008160-A	<1	FT-FY19-122018-008160-B	<1
WS-008169	3/27/2018	3/27/2019	2	Cooler	In locker room E231	High Left	WF-03272018-008169	12/20/2018	FT-FY19-122018-008169-A	<1	FT-FY19-122018-008169-B	<1
WS-008170	3/27/2018	3/27/2019	2	Cooler	In locker room E231	Low Right	WF-03272018-008170	12/20/2018	FT-FY19-122018-008170-A	<1	FT-FY19-122018-008170-B	<1
WS-008171	3/27/2018	3/27/2019	2	Cooler	In girls' locker room E214	High Left	WF-03272018-008171	12/20/2018	FT-FY19-122018-008171-A	<1	FT-FY19-122018-008171-B	<1
WS-008172	3/27/2018	3/27/2019	2	Cooler	In girls' locker room E214	Low Right	WF-03272018-008172	12/20/2018	FT-FY19-122018-008172-A	<1	FT-FY19-122018-008172-B	<1
WS-008175	3/27/2018	3/27/2019	2	Cooler	In locker room D204	High Left	WF-03272018-008175	12/20/2018	FT-FY19-122018-008175-A	<1	FT-FY19-122018-008175-B	<1
WS-008176	3/27/2018	3/27/2019	2	Cooler	In locker room D204	Low Right	WF-03272018-008176	12/20/2018	FT-FY19-122018-008176-A	<1	FT-FY19-122018-008176-B	<1
WS-008186	9/28/2018	9/28/2019	4	Cooler	In hallway adjacent to classroom A424	High Left	WF-09282018-008186	12/20/2018	FT-FY19-122018-008186-A	<1	FT-FY19-122018-008186-B	<1
WS-008187	9/28/2018	9/28/2019	4	Cooler	In hallway adjacent to classroom A424	Low Right	WF-09282018-008187	12/20/2018	FT-FY19-122018-008187-A	<1	FT-FY19-122018-008187-B	<1
WS-008188	3/27/2018	3/27/2019	4	Break Room	In work room A430		WF-03272018-008188	12/20/2018	FT-FY19-122018-008188-A	<1	FT-FY19-122018-008188-B	<1

WS- 008201	3/27/2018	3/27/2019	1	Cooler	In hallway adjacent to choir room E107	High	Left	WF-03272018-008201	12/20/2018	FT-FY19-122018-008201-A	<1	FT-FY19-122018-008201-B	<1
WS- 008202	3/27/2018	3/27/2019	1	Cooler	In hallway adjacent to choir room E107	Low	Right	WF-03272018-008202	12/20/2018	FT-FY19-122018-008202-A	<1	FT-FY19-122018-008202-B	<1
WS- 008205	3/27/2018	3/27/2019	1	Health Suite	In health suite			WF-03272018-008205	12/20/2018	FT-FY19-122018-008205-A	<1	FT-FY19-122018-008205-B	<1
WS- 008214	3/27/2018	3/27/2019	3	Cooler	In hallway adjacent to girls' restroom	High	Left	WF-03272018-008214	12/20/2018	FT-FY19-122018-008214-A	<1	FT-FY19-122018-008214-B	<1
WS- 008215	3/27/2018	3/27/2019	3	Cooler	In hallway adjacent to boys' restroom	Low	Right	WF-03272018-008215	12/20/2018	FT-FY19-122018-008215-A	<1	FT-FY19-122018-008215-B	<1

### Food Prep Sink

Less than 5ppb - Devices requiring no remediation												
Record ID	Floor	Device Type	Device Location				Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS- 008113	1	Food Prep Sink	In kitchen east wall				Left	12/20/2018	FT-FY19-122018-008113-A	<1	FT-FY19-122018-008113-B	<1

### FY19 Filter Test

Greater than 5ppb - Devices requiring remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 008028	10/22/2018	10/22/2019	1	Classroom Faucet	In classroom E121A fourth clockwise from entry door	WF-10222018-008028	12/20/2018	FT-FY19-122018-008028-A	5.2	FT-FY19-122018-008028-B	<1