



Columbia Heights EC Lead Water Test Results



FY18 Filter Test

Less than 5 ppb - Devices Requiring No Remediation											
RECORD ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	WATER FILTERS Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-008025	11/15/2017	11/15/2018	1	Classroom	In classroom E121A first clockwise from entry	WF-112017-008025	11/29/2017	FT-FY18-112017-008025-A	<1	FT-FY18-112017-008025-B	<1
WS-008027	11/15/2017	11/15/2018	1	Classroom	In classroom E121A third clockwise from entry	WF-112017-008027	11/29/2017	FT-FY18-112017-008027-A	<1	FT-FY18-112017-008027-B	<1
WS-008030	5/16/2017	5/16/2018	1	Cooler	In hallway adjacent to room D113	WF-52017-008030	11/29/2017	FT-FY18--52017-008030-A	<1	FT-FY18--52017-008030-B	<1
WS-008056	5/16/2017	5/16/2018	1	Cooler	In hallway adjacent to room C135	WF-52017-008056	11/29/2017	FT-FY18--52017-008056-A	<1	FT-FY18--52017-008056-B	<1
WS-008057	5/16/2017	5/16/2018	1	Cooler	In hallway adjacent to room C135	WF-52017-008057	11/29/2017	FT-FY18--52017-008057-A	<1	FT-FY18--52017-008057-B	<1
WS-008060	5/16/2017	5/16/2018	1	Break Room	In workroom C109	WF-52017-008060	11/29/2017	FT-FY18--52017-008060-A	<1	FT-FY18--52017-008060-B	<1
WS-008100	5/16/2017	5/16/2018	2	Cooler	In hallway adjacent to room A206	WF-52017-008100	11/29/2017	FT-FY18--52017-008100-A	<1	FT-FY18--52017-008100-B	<1
WS-008116	5/24/2017	5/24/2018	1	Ice Maker	In kitchen (ice maker)	WF-52017-008116	11/29/2017	FT-FY18--52017-008116-A	<1	FT-FY18--52017-008116-B	<1
WS-008157	5/16/2017	5/16/2018	3	Break Room	In break room C304A	WF-52017-008157	11/29/2017	FT-FY18--52017-008157-A	<1	FT-FY18--52017-008157-B	<1
WS-008159	5/16/2017	5/16/2018	3	Cooler	In hallway adjacent to the restrooms	WF-52017-008159	11/29/2017	FT-FY18--52017-008159-A	<1	FT-FY18--52017-008159-B	<1
WS-008172	5/16/2017	5/16/2018	2	Cooler	In girls' locker room E214	WF-52017-008172	11/29/2017	FT-FY18--52017-008172-A	<1	FT-FY18--52017-008172-B	<1
WS-008174	5/16/2017	5/16/2018	2	Cooler	In locker room D211	WF-52017-008174	11/29/2017	FT-FY18--52017-008174-A	<1	FT-FY18--52017-008174-B	<1
WS-008188	5/16/2017	5/16/2018	4	Break Room	In work room A430	WF-52017-008188	11/29/2017	FT-FY18--52017-008188-A	<1	FT-FY18--52017-008188-B	<1
WS-008202	5/16/2017	5/16/2018	1	Cooler	In hallway adjacent to choir room E107	WF-52017-008202	11/29/2017	FT-FY18--52017-008202-A	<1	FT-FY18--52017-008202-B	<1
WS-008205	5/24/2017	5/24/2018	1	Health Suite	In health suite	WF-62017-008205	11/29/2017	FT-FY18--62017-008205-A	<1	FT-FY18--62017-008205-B	<1

Food Prep Sink

Less than 5 ppb - Devices Requiring No Remediation											
RECORD ID	Floor	Device Type	Device Location	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)			
WS-008113	1	Food Prep Sink	In kitchen east wall	11/29/2017	FT-FY18-102017-008113-A	<1	FT-FY18-102017-008113-B	<1			