



# COLUMBIA HEIGHTS LEAD WATER TEST RESULTS

May 16th, 2016



	Building Location	Sample Collected Date	Water Source ID	Device Type	Floor	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)	Remediation	Retest Date	Retest 1st Draw	Retest 2nd Draw	
1	COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	5/7/2016	WS- 008228	Classroom	3	In classroom A341	WT-042916-8245- A	2.2	WT-042916-8245- B	< 1					
2	COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	5/7/2016	WS- 008227	Classroom	3	In classroom A341	WT-042916-8244- A	< 1	WT-042916-8244- B	< 1					
3	COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	5/7/2016	WS- 008226	Classroom	3	In classroom A341	WT-042916-8243- A	< 1	WT-042916-8243- B	< 1					
4	COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	5/7/2016	WS- 008225	Classroom	3	In classroom A341	WT-042916-8242- A	< 1	WT-042916-8242- B	< 1					
5	COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	5/7/2016	WS- 008224	Classroom	3	In classroom A338 Right	WT-042916-8241- A	25.8	WT-042916-8241- B	10.2	labeled "not for drinking"				
6	COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	5/7/2016	WS- 008223	Classroom	3	In classroom A338 Left	WT-042916-8240- A	1.3	WT-042916-8240- B	< 1					
7	COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	5/7/2016	WS- 008222	Classroom	3	In room A337 LHS6 Left	WT-042916-8239- A	2.4	WT-042916-8239- B	8.7					
8	COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	5/7/2016	WS- 008221	Classroom	3	In room A337 LHS5 Left	WT-042916-8238- A	< 1	WT-042916-8238- B	< 1					
9	COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	5/7/2016	WS- 008220	Classroom	3	In room A337 LHS4 Left	WT-042916-8237- A	3.5	WT-042916-8237- B	3.3					
10	COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	5/7/2016	WS- 008219	Classroom	3	In classroom A337 LHS4	WT-042916-8236- A	26.6	WT-042916-8236- B	< 1	labeled "not for drinking"				
11	COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	5/7/2016	WS- 008218	Classroom	3	In classroom A337 middle	WT-042916-8235- A	19.8	WT-042916-8235- B	< 1	labeled "not for drinking"				
12	COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	5/7/2016	WS- 008217	Classroom	3	In classroom A337 LHS2	WT-042916-8234- A	6.7	WT-042916-8234- B	44.7	labeled "not for drinking"				
13	COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	5/7/2016	WS- 008216	Classroom	3	In room A337 LHS1 Left	WT-042916-8233- A	5.4	WT-042916-8233- B	6.4					
14	COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	5/7/2016	WS- 008215	Cooler	3	In hallway adjacent to boys restrooms Right Low	WT-042916-8232- A	< 1	WT-042916-8232- B	6.5					
15	COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	5/7/2016	WS- 008214	Cooler	3	In hallway adjacent to girls rest room Left High	WT-042916-8231- A	< 1	WT-042916-8231- B	16.5	Filtered	6/15/2016	<1	<1	
16	COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	5/11/2016	WS- 008208	Other	2	In B208 Concession stand ICE MAKER	WT-042916-8225- A	< 1	WT-042916-8225- B	< 1					
17	COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	5/7/2016	WS- 008205	Classroom	1	In health suite	WT-042916-8222- A	< 1	WT-042916-8222- B	< 1					
18	COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	5/7/2016	WS- 008203	Classroom	1	In room C103	WT-042916-8220- A	< 1	WT-042916-8220- B	< 1					
19	COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	5/7/2016	WS- 008202	Cooler	1	In hallway adjacent to room E107 Right Low	WT-042916-8219- A	< 1	WT-042916-8219- B	< 1					
20	COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	5/7/2016	WS- 008201	Cooler	1	In hallway adjacent to choir E107	WT-042916-8218- A	< 1	WT-042916-8218- B	< 1					
21	COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	5/7/2016	WS- 008200	Classroom	3	In art room A316	WT-042916-8217- A	2.2	WT-042916-8217- B	2.1					
22	COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	5/7/2016	WS- 008199	Classroom	3	In classroom A341	WT-042916-8216- A	1.8	WT-042916-8216- B	< 1					
23	COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	5/7/2016	WS- 008198	Classroom	3	In classroom A341	WT-042916-8215- A	< 1	WT-042916-8215- B	1.8					
24	COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	5/7/2016	WS- 008197	Classroom	4	In classroom A436 MIDDLE SINK	WT-042916-8214- A	1.3	WT-042916-8214- B	2.6					
25	COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	5/7/2016	WS- 008196	Classroom	4	In classroom A436 LHS 6	WT-042916-8213- A	< 1	WT-042916-8213- B	< 1					
26	COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	5/7/2016	WS- 008195	Classroom	4	In classroom A436 LHS 5	WT-042916-8212- A	< 1	WT-042916-8212- B	< 1					
27	COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	5/7/2016	WS- 008194	Classroom	4	In classroom A436 LHS 4	WT-042916-8211- A	1.2	WT-042916-8211- B	< 1					
28	COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	5/7/2016	WS- 008193	Classroom	4	In classroom A436 LHS 3	WT-042916-8210- A	1.1	WT-042916-8210- B	< 1					
29	COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	5/7/2016	WS- 008192	Classroom	4	In classroom A436 LHS 2	WT-042916-8209- A	< 1	WT-042916-8209- B	< 1					
30	COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	5/7/2016	WS- 008191	Classroom	4	In classroom A436 LHS 1	WT-042916-8208- A	1.7	WT-042916-8208- B	< 1					
31	COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	5/7/2016	WS- 008190	Classroom	4	In prep room A435	WT-042916-8207- A	5.5	WT-042916-8207- B	< 1					
32	COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	5/7/2016	WS- 008189	Classroom	4	In prep room A435	WT-042916-8206- A	16.5	WT-042916-8206- B	< 1	labeled "not for drinking"				
33	COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	5/7/2016	WS- 008188	Classroom	4	In work room A430	WT-042916-8205- A	3.4	WT-042916-8205- B	1.1					
34	COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	5/7/2016	WS- 008187	Cooler	3	In hallway adjacent to classroom A428 Right Low	WT-042916-8204- A	< 1	WT-042916-8204- B	< 1					
35	COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	5/7/2016	WS- 008186	Cooler	4	In hallway adjacent to classroom A428 Left High	WT-042916-8203- A	< 1	WT-042916-8203- B	< 1					
36	COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	5/10/2016	WS- 008185	Classroom	3	In classroom 325 instructors.sink middle	WT-042916-8202- A	980	WT-042916-8202- B	12	labeled "not for drinking"				



# COLUMBIA HEIGHTS LEAD WATER TEST RESULTS

May 16th, 2016



Building Location	Sample Collected Date	Water Source ID	Device Type	Floor	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)	Remediation	Retest Date	Retest 1st Draw	Retest 2nd Draw
COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	5/7/2016	WS- 008184	Classroom	3	In classroom C325 LHS7	WT-042916-8201- A	8.3	WT-042916-8201- B	17.2	labeled "not for drinking"			
COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	5/7/2016	WS- 008183	Classroom	3	In classroom C325	WT-042916-8200- A	7.2	WT-042916-8200- B	16.5	labeled "not for drinking"			
COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	5/7/2016	WS- 008182	Classroom	3	In classroom C325 LHS 5	WT-042916-8199- A	1.1	WT-042916-8199- B	3.1				
COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	5/7/2016	WS- 008181	Classroom	3	In classroom C325 LHS 4	WT-042916-8198- A	73.9	WT-042916-8198- B	6.1	labeled "not for drinking"			
COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	5/7/2016	WS- 008180	Classroom	3	In classroom C325 LHS3	WT-042916-8197- A	< 1	WT-042916-8197- B	2.5				
COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	5/7/2016	WS- 008179	Classroom	3	In classroom C325 LHS2 Left	WT-042916-8196- A	143	WT-042916-8196- B	6.9	labeled "not for drinking"			
COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	5/7/2016	WS- 008178	Classroom	3	In classroom C325 LHS1	WT-042916-8195- A	88.9	WT-042916-8195- B	3.5	labeled "not for drinking"			
COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	5/7/2016	WS- 008177	Classroom	3	In classroom C324	WT-042916-8194- A	5.1	WT-042916-8194- B	3.1				
COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	5/7/2016	WS- 008176	Cooler	2	In room D204 Right Low	WT-042916-8193- A	< 1	WT-042916-8193- B	< 1				
COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	5/7/2016	WS- 008175	Cooler	2	In locker room D204 Left High	WT-042916-8192- A	< 1	WT-042916-8192- B	< 1				
COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	5/7/2016	WS- 008174	Cooler	2	In room D211 Right	WT-042916-8191- A	< 1	WT-042916-8191- B	< 1				
COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	5/7/2016	WS- 008173	Cooler	2	In room D211 Left	WT-042916-8190- A	< 1	WT-042916-8190- B	< 1				
COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	5/7/2016	WS- 008172	Cooler	2	In room E214 Right Low	WT-042916-8189- A	< 1	WT-042916-8189- B	< 1				
COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	5/7/2016	WS- 008171	Cooler	2	In room E214 Girls Locker room Left High	WT-042916-8188- A	< 1	WT-042916-8188- B	< 1				
COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	5/7/2016	WS- 008170	Cooler	2	In room E231 locker room	WT-042916-8187- A	< 1	WT-042916-8187- B	< 1				
COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	5/7/2016	WS- 008169	Cooler	2	In room E231 Left High	WT-042916-8186- A	< 1	WT-042916-8186- B	< 1				
COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	5/7/2016	WS- 008168	Classroom	3	In classroom C323 middle	WT-042916-8185- A	3.6	WT-042916-8185- B	4.2				
COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	5/7/2016	WS- 008167	Classroom	3	In Classroom C323 LHS 6	WT-042916-8184- A	3.6	WT-042916-8184- B	10.8				
COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	5/7/2016	WS- 008166	Classroom	3	In classroom C323 LHS6	WT-042916-8183- A	4.8	WT-042916-8183- B	4.6				
COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	5/7/2016	WS- 008165	Classroom	3	In classroom C323	WT-042916-8182- A	2.7	WT-042916-8182- B	4.4				
COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	5/7/2016	WS- 008164	Classroom	3	In classroom C323 LHS4 Left	WT-042916-8181- A	3.9	WT-042916-8181- B	16.1	labeled "not for drinking"			
COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	5/7/2016	WS- 008163	Classroom	3	In classroom C323 LHS3	WT-042916-8180- A	16	WT-042916-8180- B	2.8	labeled "not for drinking"			
COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	5/7/2016	WS- 008162	Classroom	3	In classroom C323 LHS 2 Left	WT-042916-8179- A	3.2	WT-042916-8179- B	34.9	labeled "not for drinking"			
COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	5/7/2016	WS- 008161	Classroom	3	In classroom C323 LHS 1	WT-042916-8178- A	30.6	WT-042916-8178- B	14.4	labeled "not for drinking"			
COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	5/7/2016	WS- 008160	Cooler	3	In hallway adjacent to the bathrooms Right	WT-042916-8177- A	< 1	WT-042916-8177- B	< 1				
COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	5/7/2016	WS- 008159	Cooler	3	In hallway adjacent to the bathrooms Left High	WT-042916-8176- A	< 1	WT-042916-8176- B	< 1				
COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	5/7/2016	WS- 008158	Kitchen	3	In classroom C304A Right	WT-042916-8175- A	95	WT-042916-8175- B	6.7	Device removed	6/15/2016	1600	2.6
COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	5/7/2016	WS- 008157	Kitchen	3	In room C304A	WT-042916-8174- A	< 1	WT-042916-8174- B	< 1				
COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	5/7/2016	WS- 008156	Classroom	2	In classroom C218	WT-042916-8173- A	1.8	WT-042916-8173- B	< 1				
COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	5/7/2016	WS- 008154	Classroom	2	In classroom C229 LHS7 Left	WT-042916-8171- A	72.7	WT-042916-8171- B	13	labeled "not for drinking"			
COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	5/7/2016	WS- 008153	Classroom	2	In classroom C229 LHS6 Left	WT-042916-8170- A	67.2	WT-042916-8170- B	16.3	labeled "not for drinking"			
COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	5/7/2016	WS- 008152	Classroom	2	In classroom C229 LHS5 Left	WT-042916-8169- A	30.8	WT-042916-8169- B	< 1	labeled "not for drinking"			
COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	5/7/2016	WS- 008151	Classroom	2	In classroom C229 LHS4 Left	WT-042916-8168- A	27.8	WT-042916-8168- B	1.3	labeled "not for drinking"			
COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	5/7/2016	WS- 008150	Classroom	2	In classroom C229 LHS3 Left	WT-042916-8167- A	68.9	WT-042916-8167- B	1.1	labeled "not for drinking"			
COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	5/7/2016	WS- 008149	Classroom	2	In classroom C229 LHS2 Left	WT-042916-8166- A	127	WT-042916-8166- B	4.8	labeled "not for drinking"			
COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	5/7/2016	WS- 008148	Classroom	2	In classroom C229 LHS1 Left	WT-042916-8165- A	15.2	WT-042916-8165- B	7.1	labeled "not for drinking"			



# COLUMBIA HEIGHTS LEAD WATER TEST RESULTS

May 16th, 2016



Building Location	Sample Collected Date	Water Source ID	Device Type	Floor	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)	Remediation	Retest Date	Retest 1st Draw	Retest 2nd Draw	
COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	5/7/2016	WS- 008147	Classroom	2	In room C228	WT-042916-8164- A	11	WT-042916-8164- B	10.6					
COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	5/7/2016	WS- 008146	Classroom	2	In classroom C227 middle sink	WT-042916-8163- A	58.7	WT-042916-8163- B	3.1	labeled "not for drinking"				
COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	5/7/2016	WS- 008145	Classroom	2	In classroom C227 LHS 7	WT-042916-8162- A	6.3	WT-042916-8162- B	< 1					
COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	5/7/2016	WS- 008144	Classroom	2	In classroom C227 LHS 6	Left	WT-042916-8161- A	179	WT-042916-8161- B	5.4	labeled "not for drinking"			
COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	5/7/2016	WS- 008143	Classroom	2	In classroom C227 LHS5	WT-042916-8160- A	9.8	WT-042916-8160- B	11.1					
COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	5/7/2016	WS- 008142	Classroom	2	In classroom C227 LHS 4	Left	WT-042916-8159- A	172	WT-042916-8159- B	8.9	labeled "not for drinking"			
COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	5/7/2016	WS- 008141	Classroom	2	In classroom C227 LHS 3	Left	WT-042916-8158- A	15.3	WT-042916-8158- B	1.7	labeled "not for drinking"			
COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	5/7/2016	WS- 008140	Classroom	2	In classroom C227 LHS 2	Left	WT-042916-8157- A	< 1	WT-042916-8157- B	< 1				
COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	5/7/2016	WS- 008139	Classroom	2	In classroom C227 LHS 1	Left	WT-042916-8156- A	3.8	WT-042916-8156- B	1.2				
COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	5/7/2016	WS- 008117	Kitchen	1	In kitchen middle sink	WT-042916-8134- A	2.6	WT-042916-8134- B	< 1					
COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	5/7/2016	WS- 008116	Kitchen	1	In kitchen ice maker	WT-042916-8133- A	1.8	WT-042916-8133- B	1.2					
COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	5/7/2016	WS- 008115	Kitchen	1	In kitchen grill washer	WT-042916-8132- A	< 1	WT-042916-8132- B	< 1					
COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	5/7/2016	WS- 008114	Kitchen	1	In kitchen east wall first from left	WT-042916-8131- A	< 1	WT-042916-8131- B	< 1					
COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	5/7/2016	WS- 008113	Kitchen	1	In kitchen east wall second from left	Mid	WT-042916-8130- A	< 1	WT-042916-8130- B	< 1				
COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	5/7/2016	WS- 008112	Kitchen	1	In kitchen east wall third from left	Right	WT-042916-8129- A	2.5	WT-042916-8129- B	< 1				
COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	5/7/2016	WS- 008111	Kitchen	1	In kitchen last from left	Right	WT-042916-8128- A	< 1	WT-042916-8128- B	< 1				
COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	5/7/2016	WS- 008110	Kitchen	1	In kitchen north wall second from left	Mid	WT-042916-8127- A	< 1	WT-042916-8127- B	< 1				
COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	5/7/2016	WS- 008109	Kitchen	1	In kitchen first from left(shower head)	Left	WT-042916-8126- A	< 1	WT-042916-8126- B	< 1				
COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	5/7/2016	WS- 008108	Classroom	2	In room 208A Dining line	WT-042916-8125- A	< 1	WT-042916-8125- B	< 1					
COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	5/7/2016	WS- 008107	Cooler	2	In hallway adjacent to the stairs	Right High	WT-042916-8124- A	< 1	WT-042916-8124- B	< 1				
COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	5/7/2016	WS- 008106	Cooler	2	In hallway adjacent to the stairs	Right Low	WT-042916-8123- A	< 1	WT-042916-8123- B	< 1				
COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	5/7/2016	WS- 008105	Cooler	2	In hallway adjacent to the stairwell 2	Left Low	WT-042916-8122- A	1.2	WT-042916-8122- B	145	Filtered	6/15/2016	1.3	<1
COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	5/7/2016	WS- 008104	Cooler	2	In hallway adjacent to stairway 2	Left High	WT-042916-8121- A	103	WT-042916-8121- B	189	Filtered	6/15/2016	1.5	<1
COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	5/7/2016	WS- 008103	Cooler	2	In hallway adjacent to classroom A206	Right Low	WT-042916-8120- A	< 1	WT-042916-8120- B	< 1				
COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	5/7/2016	WS- 008102	Cooler	2	In hallway adjacent to room A206	Right Low	WT-042916-8119- A	< 1	WT-042916-8119- B	< 1				
COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	5/7/2016	WS- 008101	Cooler	2	In hallway adjacent to classroom A206	Left Low	WT-042916-8118- A	< 1	WT-042916-8118- B	< 1				
COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	5/7/2016	WS- 008100	Cooler	2	In hallway adjacent to A206	Left High	WT-042916-8117- A	< 1	WT-042916-8117- B	< 1				
COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	5/7/2016	WS- 008099	Classroom	2	In room A206	Left	WT-042916-8116- A	1.2	WT-042916-8116- B	1.9				
COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	5/7/2016	WS- 008098	Classroom	2	In room A214 LHS1	Left	WT-042916-8115- A	< 1	WT-042916-8115- B	< 1				
COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	5/7/2016	WS- 008097	Classroom	2	In room A214 LHS1	Left	WT-042916-8114- A	< 1	WT-042916-8114- B	< 1				
COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	5/7/2016	WS- 008096	Classroom	2	In classroom A234	WT-042916-8113- A	3.7	WT-042916-8113- B	< 1					
COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	5/7/2016	WS- 008095	Classroom	2	In classroom A238 middle	WT-042916-8112- A	7.1	WT-042916-8112- B	< 1					
COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	5/7/2016	WS- 008094	Classroom	2	In classroom A238 LHS6	Left	WT-042916-8111- A	38.2	WT-042916-8111- B	1.1	labeled "not for drinking"			
COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	5/7/2016	WS- 008093	Classroom	2	In classroom A238 LHS 5	Left	WT-042916-8110- A	90	WT-042916-8110- B	< 1	labeled "not for drinking"			
COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	5/7/2016	WS- 008092	Classroom	2	In room A238 LHS4	Left	WT-042916-8109- A	9.3	WT-042916-8109- B	1.6				
COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	5/7/2016	WS- 008091	Classroom	2	In room A238 LHS3	Left	WT-042916-8108- A	6.2	WT-042916-8108- B	1.9				



# COLUMBIA HEIGHTS LEAD WATER TEST RESULTS

May 16th, 2016



Building Location	Sample Collected Date	Water Source ID	Device Type	Floor	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)	Remediation	Retest Date	Retest 1st Draw	Retest 2nd Draw
COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	5/7/2016	WS- 008090	Classroom	2	In classroom A238 LHS 2	WT-042916-8107- A	107	WT-042916-8107- B	1.7	labeled "not for drinking"			
COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	5/7/2016	WS- 008089	Classroom	2	In classroom 238 LHS 1 Left	WT-042916-8106- A	14.4	WT-042916-8106- B	2.2				
COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	5/7/2016	WS- 008088	Classroom	2	In room A239	WT-042916-8105- A	< 1	WT-042916-8105- B	< 1				
COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	5/7/2016	WS- 008087	Classroom	2	In room A240 Mid	WT-042916-8104- A	4.6	WT-042916-8104- B	< 1				
COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	5/7/2016	WS- 008086	Classroom	2	In room A240 Left	WT-042916-8103- A	3.6	WT-042916-8103- B	2.7				
COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	5/7/2016	WS- 008085	Classroom	2	In room A240 LHS5	WT-042916-8102- A	< 1	WT-042916-8102- B	< 1				
COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	5/7/2016	WS- 008084	Classroom	2	In classroom A240 LHS4 Left	WT-042916-8101- A	51.2	WT-042916-8101- B	7.9	labeled "not for drinking"			
COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	5/7/2016	WS- 008083	Classroom	2	In room A240 LHS3 Left	WT-042916-8100- A	2.5	WT-042916-8100- B	1.1				
COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	5/7/2016	WS- 008082	Classroom	2	In room A240 LHS2 Left	WT-042916-8099- A	1.4	WT-042916-8099- B	< 1				
COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	5/7/2016	WS- 008081	Classroom	2	In room A240 LHS1 Left	WT-042916-8098- A	2.5	WT-042916-8098- B	2.9				
COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	5/7/2016	WS- 008080	Classroom	1	In classroom A161	WT-042916-8097- A	26.4	WT-042916-8097- B	< 1	labeled "not for drinking"			
COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	5/7/2016	WS- 008079	Classroom	1	In classroom A161	WT-042916-8096- A	14.8	WT-042916-8096- B	< 1				
COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	5/7/2016	WS- 008078	Classroom	1	In room A160 Mid	WT-042916-8095- A	1.3	WT-042916-8095- B	3.7				
COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	5/7/2016	WS- 008077	Classroom	1	In room A160 LHS6 Left	WT-042916-8094- A	2.4	WT-042916-8094- B	< 1				
COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	5/7/2016	WS- 008076	Classroom	1	In classroom A160 LHS 5 Left	WT-042916-8093- A	33.2	WT-042916-8093- B	2.5	labeled "not for drinking"			
COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	5/7/2016	WS- 008075	Classroom	1	In classroom A160 LHS4 Left	WT-042916-8092- A	255	WT-042916-8092- B	11.4	labeled "not for drinking"			
COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	5/7/2016	WS- 008074	Classroom	1	In classroom A160 LHS3 Left	WT-042916-8091- A	18.2	WT-042916-8091- B	5.2	labeled "not for drinking"			
COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	5/7/2016	WS- 008073	Classroom	1	In classroom A160 LHS 2 Left	WT-042916-8090- A	126	WT-042916-8090- B	2.2	labeled "not for drinking"			
COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	5/7/2016	WS- 008072	Classroom	1	In classroom A160 LHS1 Left	WT-042916-8089- A	20.4	WT-042916-8089- B	1	labeled "not for drinking"			
COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	5/7/2016	WS- 008071	Classroom	1	In room A156 south wall	WT-042916-8088- A	2.2	WT-042916-8088- B	< 1				
COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	5/7/2016	WS- 008070	Classroom	1	In room A148	WT-042916-8087- A	< 1	WT-042916-8087- B	< 1				
COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	5/7/2016	WS- 008069	Cooler	1	In hallway across room A146 Left High	WT-042916-8086- A	< 1	WT-042916-8086- B	< 1				
COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	5/7/2016	WS- 008068	Cooler	1	In hallway across from room A146 Right Low	WT-042916-8085- A	< 1	WT-042916-8085- B	< 1				
COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	5/7/2016	WS- 008067	Classroom	1	In room A122	WT-042916-8084- A	< 1	WT-042916-8084- B	< 1				
COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	5/7/2016	WS- 008066	Classroom	1	In room 119 west wall	WT-042916-8083- A	< 1	WT-042916-8083- B	< 1				
COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	5/7/2016	WS- 008065	Classroom	1	In classroom A117 workroom Right Low	WT-042916-8082- A	< 1	WT-042916-8082- B	< 1				
COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	5/7/2016	WS- 008064	Classroom	1	In room A115 west wall	WT-042916-8081- A	< 1	WT-042916-8081- B	< 1				
COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	5/7/2016	WS- 008063	Classroom	1	In room 107 south east wall	WT-042916-8080- A	< 1	WT-042916-8080- B	< 1				
COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	5/7/2016	WS- 008062	Classroom	1	In classroom B127 Dressing room	WT-042916-8079- A	11.9	WT-042916-8079- B	< 1				
COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	5/7/2016	WS- 008061	Classroom	1	In classroom dressing room	WT-042916-8078- A	2.7	WT-042916-8078- B	< 1				
COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	5/7/2016	WS- 008060	Classroom	1	In classroom C109 workroom	WT-042916-8077- A	5.3	WT-042916-8077- B	< 1				
COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	5/7/2016	WS- 008059	Classroom	1	In classroom C117 Breakroom	WT-042916-8076- A	< 1	WT-042916-8076- B	< 1				
COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	5/7/2016	WS- 008058	Classroom	1	In classroom 112 duplication center	WT-042916-8075- A	< 1	WT-042916-8075- B	2.8				
COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	5/7/2016	WS- 008057	Cooler	1	In hallway adjacent to janitor closet room C135 Right High	WT-042916-8074- A	< 1	WT-042916-8074- B	< 1				
COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	5/7/2016	WS- 008056	Cooler	1	In hallway adjacent to janitor closet room C135 Left Low	WT-042916-8073- A	< 1	WT-042916-8073- B	< 1				
COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	5/7/2016	WS- 008055	Classroom	1	In classroom 146	WT-042916-8072- A	2	WT-042916-8072- B	< 1				



# COLUMBIA HEIGHTS LEAD WATER TEST RESULTS

May 16th, 2016



Building Location	Sample Collected Date	Water Source ID	Device Type	Floor	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)	Remediation	Retest Date	Retest 1st Draw	Retest 2nd Draw
COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	5/7/2016	WS- 008054	Classroom	1	In classroom C141 middle	Mid	WT-042916-8071- A	15.4	WT-042916-8071- B	3.5			
COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	5/7/2016	WS- 008053	Classroom	1	In classroom C141 LHS 7	Left	WT-042916-8070- A	21	WT-042916-8070- B	81.6			
COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	5/7/2016	WS- 008052	Classroom	1	In classroom C141 LHS 6	Left	WT-042916-8069- A	112	WT-042916-8069- B	< 1			
COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	5/7/2016	WS- 008051	Classroom	1	In classroom C141 LHS 5	Left	WT-042916-8068- A	129	WT-042916-8068- B	2.3			
COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	5/7/2016	WS- 008050	Classroom	1	In classroom C141 LHS 4	Left	WT-042916-8067- A	14	WT-042916-8067- B	2.5			
COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	5/7/2016	WS- 008049	Classroom	1	In classroom C141 LHS 3	Left	WT-042916-8066- A	133	WT-042916-8066- B	8.8			
COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	5/7/2016	WS- 008048	Classroom	1	In classroom C141 LHS 2	Left	WT-042916-8065- A	13.9	WT-042916-8065- B	1.5			
COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	5/7/2016	WS- 008047	Classroom	1	In classroom C141 LHS 1	Left	WT-042916-8064- A	2.4	WT-042916-8064- B	< 1			
COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	5/7/2016	WS- 008046	Classroom	1	In classroom C140		WT-042916-8063- A	5.3	WT-042916-8063- B	1.2			
COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	5/7/2016	WS- 008045	Classroom	1	In classroom C139 middle		WT-042916-8062- A	236	WT-042916-8062- B	57.6			
COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	5/7/2016	WS- 008044	Classroom	1	In classroom C139 LHS 7	Left	WT-042916-8061- A	1.8	WT-042916-8061- B	< 1			
COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	5/7/2016	WS- 008043	Classroom	1	In classroom C139 LHS 6		WT-042916-8060- A	17.6	WT-042916-8060- B	2.5			
COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	5/7/2016	WS- 008042	Classroom	1	In classroom C139 LHS 5		WT-042916-8059- A	31.5	WT-042916-8059- B	13.2			
COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	5/7/2016	WS- 008041	Classroom	1	In classroom C139 LHS4	Left	WT-042916-8058- A	132	WT-042916-8058- B	2.7			
COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	5/7/2016	WS- 008040	Classroom	1	In classroom C139 LHS 3		WT-042916-8057- A	190	WT-042916-8057- B	11.3			
COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	5/7/2016	WS- 008039	Classroom	1	In classroom C139 LHS2		WT-042916-8056- A	102	WT-042916-8056- B	19.3			
COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	5/7/2016	WS- 008038	Classroom	1	In classroom C139 LHS 1		WT-042916-8055- A	16.9	WT-042916-8055- B	22.2			
COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	5/7/2016	WS- 008037	Classroom	1	In classroom D105		WT-042916-8054- A	< 1	WT-042916-8054- B	< 1			
COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	5/7/2016	WS- 008036	Classroom	1	In classroom D110 LHS 4		WT-042916-8053- A	161	WT-042916-8053- B	3.4	6/15/2016	<1	<1
COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	5/7/2016	WS- 008035	Classroom	1	In classroom D110 LHS 3		WT-042916-8052- A	164	WT-042916-8052- B	5.8	6/15/2016	1.8	<1
COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	5/7/2016	WS- 008034	Classroom	1	In classroom D110 left 2	Left	WT-042916-8051- A	1	WT-042916-8051- B	< 1			
COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	5/7/2016	WS- 008033	Classroom	1	In classroom D110 lhs 1		WT-042916-8050- A	< 1	WT-042916-8050- B	< 1			
COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	5/7/2016	WS- 008032	Classroom	1	In classroom D113		WT-042916-8049- A	< 1	WT-042916-8049- B	< 1			
COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	5/7/2016	WS- 008031	Classroom	1	In classroom D113		WT-042916-8048- A	1.2	WT-042916-8048- B	< 1			
COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	5/7/2016	WS- 008030	Cooler	1	In hallway next to D113	Right Low	WT-042916-8047- A	1.3	WT-042916-8047- B	2.7			
COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	5/7/2016	WS- 008029	Cooler	1	In hallway next to D113	Left High	WT-042916-8046- A	< 1	WT-042916-8046- B	2.8			
COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	5/7/2016	WS- 008028	Classroom	1	In classroom 121A	Left	WT-042916-8045- A	< 1	WT-042916-8045- B	< 1			
COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	5/7/2016	WS- 008027	Classroom	1	In classroom 121A	Right Low	WT-042916-8044- A	< 1	WT-042916-8044- B	< 1			
COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	5/7/2016	WS- 008026	Classroom	1	In classroom 121A		WT-042916-8043- A	< 1	WT-042916-8043- B	< 1			
COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	5/7/2016	WS- 008025	Classroom	1	In classroom 121A		WT-042916-8042- A	< 1	WT-042916-8042- B	< 1			
COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	5/7/2016	WS- 008021	Classroom	1	In class 123		WT-042916-8038- A	< 1	WT-042916-8038- B	< 1			
COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	5/7/2016	WS- 008020	Classroom	1	In classroom 111		WT-042916-8037- A	< 1	WT-042916-8037- B	< 1			
COLUMBIA HEIGHTS EDUCATIONAL CAMPUS	5/7/2016	WS- 008019	Utility	Basement	In pump room		WT-042916-8036- A	73.8	WT-042916-8036- B	25.7			

Footnotes:

- A - First draw sample is collected after the plumbing system has not been used for at least 6 hours.
- B - Second draw sample is collected after a 60 second flush at that device after the first draw.