



COOLIDGE HS LEAD WATER TEST RESULTS



	Building Location: Building Name	RECORD ID	Date Analyzed	Floor	Device Type	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)
1	COOLIDGE HIGH SCHOOL	WS- 012199	8/23/2016	Ground Floor	Food Prep Sink	In kitchen Right	FT-82016-012199-A	< 1	FT-82016-012199-B	< 1
2	COOLIDGE HIGH SCHOOL	WS- 012200	8/23/2016	Ground Floor	Cooler	In cafeteria	FT-72016-012200-A	< 1	FT-72016-012200-B	< 1
3	COOLIDGE HIGH SCHOOL	WS- 012202	8/23/2016	Ground Floor	Cooler	In hallway adjacent to armory	FT-82016-012202-A	< 1	FT-82016-012202-B	< 1
4	COOLIDGE HIGH SCHOOL	WS- 012203	8/23/2016	Ground Floor	Cooler	In boys' gym adjacent to armory	FT-82016-012203-A	< 1	FT-82016-012203-B	< 1
5	COOLIDGE HIGH SCHOOL	WS- 012204	8/23/2016	Basement	Cooler	In hallway adjacent to weight room B105	FT-82016-012204-A	< 1	FT-82016-012204-B	< 1
6	COOLIDGE HIGH SCHOOL	WS- 012205	8/23/2016	Basement	Cooler	In gym adjacent to boys' locker room	FT-82016-012205-A	< 1	FT-82016-012205-B	< 1
7	COOLIDGE HIGH SCHOOL	WS- 012206	8/23/2016	Basement	Cooler	In boys' varsity basketball locker room	FT-82016-012206-A	< 1	FT-82016-012206-B	< 1
8	COOLIDGE HIGH SCHOOL	WS- 012207	8/23/2016	Basement	Cooler	In gym adjacent to stairwell 3	FT-82016-012207-A	< 1	FT-82016-012207-B	< 1
9	COOLIDGE HIGH SCHOOL	WS- 012208	8/23/2016	Basement	Cooler	In boys' locker room	FT-82016-012208-A	< 1	FT-82016-012208-B	< 1
10	COOLIDGE HIGH SCHOOL	WS- 012209	8/23/2016	Basement	Cooler	In hallway adjacent to girls' locker room	FT-82016-012209-A	< 1	FT-82016-012209-B	< 1
11	COOLIDGE HIGH SCHOOL	WS- 012210	8/23/2016	Basement	Cooler	In girls' locker room (new building)	FT-82016-012210-A	< 1	FT-82016-012210-B	< 1
12	COOLIDGE HIGH SCHOOL	WS- 012211	8/23/2016	Basement	Cooler	In girls' basketball locker room	FT-82016-012211-A	< 1	FT-82016-012211-B	< 1
13	COOLIDGE HIGH SCHOOL	WS- 012212	8/23/2016	Basement	Cooler	In gym adjacent to stairwell 2	FT-82016-012212-A	< 1	FT-82016-012212-B	< 1
14	COOLIDGE HIGH SCHOOL	WS- 012213	8/23/2016	Ground Floor	Cooler	In the Frank R. William activity center adjacent to door 172	FT-82016-012213-A	< 1	FT-82016-012213-B	< 1
15	COOLIDGE HIGH SCHOOL	WS- 012214	8/23/2016	Ground Floor	Cooler	In the Frank R. William activity center adjacent to door 173 Left	FT-82016-012214-A	< 1	FT-82016-012214-B	< 1
16	COOLIDGE HIGH SCHOOL	WS- 012215	8/23/2016	Ground Floor	Fountain	In the Frank R. William activity center adjacent to door 173 Right	FT-82016-012215-A	< 1	FT-82016-012215-B	< 1
17	COOLIDGE HIGH SCHOOL	WS- 012216	8/23/2016	Ground Floor	Cooler	In the Frank R. William activity center adjacent to door 174 Left	FT-82016-012216-A	< 1	FT-82016-012216-B	< 1
18	COOLIDGE HIGH SCHOOL	WS- 012217	8/23/2016	Ground Floor	Fountain	In the Frank R. William activity center adjacent to door 174 Right	FT-82016-012217-A	< 1	FT-82016-012217-B	< 1
19	COOLIDGE HIGH SCHOOL	WS- 012218	8/23/2016	1	Cooler	In hallway adjacent to stairwell 4	FT-82016-012218-A	< 1	FT-82016-012218-B	< 1
20	COOLIDGE HIGH SCHOOL	WS- 012219	8/23/2016	1	Cooler	In hallway adjacent to stairwell 6	FT-82016-012219-A	< 1	FT-82016-012219-B	< 1
21	COOLIDGE HIGH SCHOOL	WS- 012221	8/23/2016	1	Cooler	In hallway adjacent to stairwell 3	FT-82016-012221-A	< 1	FT-82016-012221-B	< 1
22	COOLIDGE HIGH SCHOOL	WS- 012224	8/23/2016	1	Health Suite	In exam room 2672 in health suite	FT-82016-012224-A	< 1	FT-82016-012224-B	< 1
23	COOLIDGE HIGH SCHOOL	WS- 012225	8/23/2016	1	Health Suite	In exam room 2674 in health suite	FT-82016-012225-A	< 1	FT-82016-012225-B	< 1
24	COOLIDGE HIGH SCHOOL	WS- 012226	8/23/2016	1	Health Suite	In exam room 2676 in health suite	FT-82016-012226-A	< 1	FT-82016-012226-B	< 1
25	COOLIDGE HIGH SCHOOL	WS- 012227	8/23/2016	1	Health Suite	In break room 2678 in health suite	FT-82016-012227-A	< 1	FT-82016-012227-B	< 1
26	COOLIDGE HIGH SCHOOL	WS- 012228	8/23/2016	1	Health Suite	In lab room 2673 in health suite	FT-82016-012228-A	< 1	FT-82016-012228-B	< 1
27	COOLIDGE HIGH SCHOOL	WS- 012248	8/23/2016	2	Cooler	In hallway adjacent to stairwell 3	FT-82016-012248-A	< 1	FT-82016-012248-B	< 1
28	COOLIDGE HIGH SCHOOL	WS- 012249	8/23/2016	2	Cooler	In hallway adjacent to stairwell 4	FT-82016-012249-A	< 1	FT-82016-012249-B	< 1
29	COOLIDGE HIGH SCHOOL	WS- 012250	8/23/2016	2	Cooler	In hallway adjacent to stairwell 6	FT-82016-012250-A	< 1	FT-82016-012250-B	< 1
30	COOLIDGE HIGH SCHOOL	WS- 012251	8/23/2016	2	Cooler	In hallway adjacent to stairwell 5	FT-82016-012251-A	< 1	FT-82016-012251-B	< 1
31	COOLIDGE HIGH SCHOOL	WS- 012252	8/23/2016	3	Cooler	In hallway adjacent to stairwell 3	FT-82016-012252-A	< 1	FT-82016-012252-B	< 1
32	COOLIDGE HIGH SCHOOL	WS- 012253	8/23/2016	3	Cooler	In hallway adjacent to stairwell 4	FT-82016-012253-A	< 1	FT-82016-012253-B	< 1
33	COOLIDGE HIGH SCHOOL	WS- 012254	8/23/2016	3	Cooler	In hallway adjacent to stairwell 6	FT-82016-012254-A	< 1	FT-82016-012254-B	< 1
34	COOLIDGE HIGH SCHOOL	WS- 012255	8/23/2016	3	Cooler	In hallway adjacent to stairwell 5	FT-82016-012255-A	< 1	FT-82016-012255-B	< 1