



Coolidge High School Lead in Water Test Results

FY22 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS-015151	4/19/2021	4/19/2022	1	Break Room	In room D102 adjacent to D102E (daycare)	WF-04192021-015151	3/17/2022	FT-FY22-02212022-015151-A	<1	FT-FY22-02212022-015151-B	<1	
WS-015161	4/19/2021	4/19/2022	1	Health Suite	In room 149K	WF-04192021-015161	3/17/2022	FT-FY22-02212022-015161-A	<1	FT-FY22-02212022-015161-B	<1	
WS-015162	4/19/2021	4/19/2022	1	Health Suite	In room 149L	WF-04192021-015162	3/17/2022	FT-FY22-02212022-015162-A	<1	FT-FY22-02212022-015162-B	<1	
WS-015163	4/19/2021	4/19/2022	1	Health Suite	In room 149J	WF-04192021-015163	3/17/2022	FT-FY22-02212022-015163-A	<1	FT-FY22-02212022-015163-B	<1	
WS-015164	4/19/2021	4/19/2022	1	Health Suite	In room 149G	WF-04192021-015164	3/17/2022	FT-FY22-02212022-015164-A	<1	FT-FY22-02212022-015164-B	<1	
WS-015165	4/19/2021	4/19/2022	1	Health Suite	In room 149F	WF-04192021-015165	3/17/2022	FT-FY22-02212022-015165-A	<1	FT-FY22-02212022-015165-B	<1	
WS-015166	4/19/2021	4/19/2022	1	Health Suite	In room 149A adjacent to dentist chair	Left	WF-04192021-015166	3/17/2022	FT-FY22-02212022-015166-A	<1	FT-FY22-02212022-015166-B	<1
WS-015167	4/19/2021	4/19/2022	1	Health Suite	In room 149A in lab	Right	WF-04192021-015167	3/17/2022	FT-FY22-02212022-015167-A	<1	FT-FY22-02212022-015167-B	<1
WS-015168	4/19/2021	4/19/2022	1	Cooler	In hallway adjacent to 138 dining (west side)	High Left	WF-04192021-015168	3/17/2022	FT-FY22-02212022-015168-A	<1	FT-FY22-02212022-015168-B	<1
WS-015169	4/19/2021	4/19/2022	1	Cooler	In hallway adjacent to 138 dining (west side)	Low Right	WF-04192021-015169	3/17/2022	FT-FY22-02212022-015169-A	<1	FT-FY22-02212022-015169-B	<1
WS-015188	4/19/2021	4/19/2022	1	Break Room	In room 106	WF-04192021-015188	3/17/2022	FT-FY22-02212022-015188-A	<1	FT-FY22-02212022-015188-B	<1	
WS-015189	4/19/2021	4/19/2022	1	Cooler	In hallway adjacent to 115 mechanical	High Left	WF-04192021-015189	3/17/2022	FT-FY22-02212022-015189-A	<1	FT-FY22-02212022-015189-B	<1
WS-015190	4/19/2021	4/19/2022	1	Cooler	In hallway adjacent to 115 mechanical	Low Right	WF-04192021-015190	3/17/2022	FT-FY22-02212022-015190-A	<1	FT-FY22-02212022-015190-B	<1
WS-015196	4/19/2021	4/19/2022	1	Classroom Faucet	In room 118 first clock wise from entry	WF-04192021-015196	3/17/2022	FT-FY22-02212022-015196-A	<1	FT-FY22-02212022-015196-B	<1	
WS-015199	4/19/2021	4/19/2022	1	Cooler	In room 121	WF-04192021-015199	3/17/2022	FT-FY22-02212022-015199-A	<1	FT-FY22-02212022-015199-B	<1	
WS-015217	4/19/2021	4/19/2022	2	Break Room	In room 221	WF-04192021-015217	3/17/2022	FT-FY22-02212022-015217-A	<1	FT-FY22-02212022-015217-B	<1	
WS-015218	4/19/2021	4/19/2022	2	Break Room	In room 223	WF-04192021-015218	3/17/2022	FT-FY22-02212022-015218-A	<1	FT-FY22-02212022-015218-B	<1	
WS-015219	4/19/2021	4/19/2022	2	Break Room	In room 225	WF-04192021-015219	3/17/2022	FT-FY22-02212022-015219-A	<1	FT-FY22-02212022-015219-B	<1	
WS-015238	4/19/2021	4/19/2022	2	Cooler	In hallway adjacent to 209	High Left	WF-04192021-015238	3/17/2022	FT-FY22-02212022-015238-A	<1	FT-FY22-02212022-015238-B	<1
WS-015239	4/19/2021	4/19/2022	2	Cooler	In hallway adjacent to 209	Low Right	WF-04192021-015239	3/17/2022	FT-FY22-02212022-015239-A	<1	FT-FY22-02212022-015239-B	<1
WS-015242	4/19/2021	4/19/2022	2	Break Room	In room 216	WF-04192021-015242	3/17/2022	FT-FY22-02212022-015242-A	<1	FT-FY22-02212022-015242-B	<1	
WS-015282	4/19/2021	4/19/2022	3	Break Room	In room 312	WF-04192021-015282	3/17/2022	FT-FY22-02212022-015282-A	<1	FT-FY22-02212022-015282-B	<1	
WS-015283	4/19/2021	4/19/2022	3	Cooler	In hallway across from 322	High Left	WF-04192021-015283	3/17/2022	FT-FY22-02212022-015283-A	<1	FT-FY22-02212022-015283-B	<1
WS-015284	4/19/2021	4/19/2022	3	Cooler	In hallway across from 322	Low Right	WF-04192021-015284	3/17/2022	FT-FY22-02212022-015284-A	<1	FT-FY22-02212022-015284-B	<1
WS-015293	4/19/2021	4/19/2022	4	Break Room	In room 406	WF-04192021-015293	3/17/2022	FT-FY22-02212022-015293-A	<1	FT-FY22-02212022-015293-B	<1	
WS-015294	4/19/2021	4/19/2022	4	Cooler	In hallway across from 414	High Left	WF-04192021-015294	3/17/2022	FT-FY22-02212022-015294-A	<1	FT-FY22-02212022-015294-B	<1
WS-015295	4/19/2021	4/19/2022	4	Cooler	In hallway across from 414	Low Right	WF-04192021-015295	3/17/2022	FT-FY22-02212022-015295-A	<1	FT-FY22-02212022-015295-B	<1
WS-015307	4/19/2021	4/19/2022	Basement	Cooler	In gymnasium on northwest corner	High Left	WF-04192021-015307	3/17/2022	FT-FY22-02212022-015307-A	<1	FT-FY22-02212022-015307-B	<1
WS-015308	4/19/2021	4/19/2022	Basement	Cooler	In gymnasium on northwest corner	Low Right	WF-04192021-015308	3/17/2022	FT-FY22-02212022-015308-A	<1	FT-FY22-02212022-015308-B	<1
WS-015309	4/19/2021	4/19/2022	Basement	Bottle Filler	In gym across from stairwell 3	WF-04192021-015309	3/17/2022	FT-FY22-02212022-015309-A	<1	FT-FY22-02212022-015309-B	<1	
WS-015310	4/19/2021	4/19/2022	Basement	Cooler	In gym across from stairwell 3	High Left	WF-04192021-015310	3/17/2022	FT-FY22-02212022-015310-A	<1	FT-FY22-02212022-015310-B	<1
WS-015311	4/19/2021	4/19/2022	Basement	Cooler	In gym across from stairwell 3	Low Right	WF-04192021-015311	3/17/2022	FT-FY22-02212022-015311-A	<1	FT-FY22-02212022-015311-B	<1
WS-015315	4/19/2021	4/19/2022	Basement	Bottle Filler	In gym adjacent to boys locker room 116	WF-04192021-015315	3/17/2022	FT-FY22-02212022-015315-A	<1	FT-FY22-02212022-015315-B	<1	
WS-015316	4/19/2021	4/19/2022	Basement	Cooler	In gym adjacent to boys locker room 116	High Left	WF-04192021-015316	3/17/2022	FT-FY22-02212022-015316-A	<1	FT-FY22-02212022-015316-B	<1
WS-015317	4/19/2021	4/19/2022	Basement	Cooler	In gym adjacent to boys locker room 116	Low Right	WF-04192021-015317	3/17/2022	FT-FY22-02212022-015317-A	<1	FT-FY22-02212022-015317-B	<1

WS-015318	4/19/2021	4/19/2022	1	Bottle Filler	In gym overlook adjacent to 107 storage		WF-04192021-015318	3/17/2022	FT-FY22-02212022-015318-A	<1	FT-FY22-02212022-015318-B	<1
WS-015319	4/19/2021	4/19/2022	1	Cooler	In gym overlook adjacent to 107 storage	High Left	WF-04192021-015319	3/17/2022	FT-FY22-02212022-015319-A	<1	FT-FY22-02212022-015319-B	<1
WS-015320	4/19/2021	4/19/2022	1	Cooler	In gym overlook adjacent to 107 storage	Low Right	WF-04192021-015320	3/17/2022	FT-FY22-02212022-015320-A	<1	FT-FY22-02212022-015320-B	<1
WS-015321	5/12/2021	5/12/2022	1	Bottle Filler	In gym overlook adjacent to 111 storage		WF-05122021-015321	3/17/2022	FT-FY22-02212022-015321-A	4.4	FT-FY22-02212022-015321-B	1.2
WS-015322	5/12/2021	5/12/2022	1	Cooler	In gym overlook adjacent to 111 storage	High Left	WF-05122021-015322	3/17/2022	FT-FY22-02212022-015322-A	<1	FT-FY22-02212022-015322-B	<1
WS-015323	5/12/2021	5/12/2022	1	Cooler	In gym overlook adjacent to 111 storage	Low Right	WF-05122021-015323	3/17/2022	FT-FY22-02212022-015323-A	<1	FT-FY22-02212022-015323-B	<1
WS-015324	5/12/2021	5/12/2022	1	Bottle Filler	In gym overlook adjacent to room 110		WF-05122021-015324	3/17/2022	FT-FY22-02212022-015324-A	<1	FT-FY22-02212022-015324-B	<1
WS-015325	5/12/2021	5/12/2022	1	Cooler	In gym overlook adjacent to room 110	High Left	WF-05122021-015325	3/17/2022	FT-FY22-02212022-015325-A	<1	FT-FY22-02212022-015325-B	<1
WS-015326	5/12/2021	5/12/2022	1	Cooler	In gym overlook adjacent to room 110	Low Right	WF-05122021-015326	3/17/2022	FT-FY22-02212022-015326-A	<1	FT-FY22-02212022-015326-B	<1
WS-015327	4/19/2021	4/19/2022	1	Bottle Filler	In gym overlook adjacent to room 106		WF-04192021-015327	3/17/2022	FT-FY22-02212022-015327-A	<1	FT-FY22-02212022-015327-B	<1
WS-015328	4/19/2021	4/19/2022	1	Cooler	In gym overlook adjacent to room 106	High Left	WF-04192021-015328	3/17/2022	FT-FY22-02212022-015328-A	<1	FT-FY22-02212022-015328-B	<1
WS-015329	4/19/2021	4/19/2022	1	Cooler	In gym overlook adjacent to room 106	Low Right	WF-04192021-015329	3/17/2022	FT-FY22-02212022-015329-A	<1	FT-FY22-02212022-015329-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-015182	1/24/2022	1/24/2023	1	Food Prep Sink	In kitchen tenth clockwise from entry	WF-01242022-015182	3/17/2022	FT-FY22-02212022-015182-A	<1	FT-FY22-02212022-015182-B	<1
WS-015278	1/24/2022	1/24/2023	3	Food Prep Sink	In room 301	WF-01242022-015278	3/17/2022	FT-FY22-02212022-015278-A	<1	FT-FY22-02212022-015278-B	<1