



# Coolidge High School Lead in Water Test Results

## FY21 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS-015161	7/14/2020	7/14/2021	1	Health Suite	In room 149K	WF-07142020-015161	5/10/2021	FT-FY21-032021-015161-A	<1	FT-FY21-032021-015161-B	<1	
WS-015162	5/19/2020	5/19/2021	1	Health Suite	In room 149L	WF-05192020-015162	5/10/2021	FT-FY21-032021-015162-A	<1	FT-FY21-032021-015162-B	<1	
WS-015163	5/19/2020	5/19/2021	1	Health Suite	In room 149J	WF-05192020-015163	5/10/2021	FT-FY21-032021-015163-A	<1	FT-FY21-032021-015163-B	<1	
WS-015164	5/19/2020	5/19/2021	1	Health Suite	In room 149G	WF-05192020-015164	5/10/2021	FT-FY21-032021-015164-A	<1	FT-FY21-032021-015164-B	<1	
WS-015165	5/19/2020	5/19/2021	1	Health Suite	In room 149F	WF-05192020-015165	5/10/2021	FT-FY21-032021-015165-A	<1	FT-FY21-032021-015165-B	<1	
WS-015166	5/19/2020	5/19/2021	1	Health Suite	In room 149A adjacent to dentist chair	Left	WF-05192020-015166	5/10/2021	FT-FY21-032021-015166-A	<1	FT-FY21-032021-015166-B	<1
WS-015167	5/19/2020	5/19/2021	1	Health Suite	In room 149A in lab	Right	WF-05192020-015167	5/10/2021	FT-FY21-032021-015167-A	<1	FT-FY21-032021-015167-B	<1
WS-015168	5/19/2020	5/19/2021	1	Cooler	In hallway adjacent to 138 dining (west side)	High Left	WF-05192020-015168	5/10/2021	FT-FY21-032021-015168-A	<1	FT-FY21-032021-015168-B	<1
WS-015169	5/19/2020	5/19/2021	1	Cooler	In hallway adjacent to 138 dining (west side)	Low Right	WF-05192020-015169	5/10/2021	FT-FY21-032021-015169-A	<1	FT-FY21-032021-015169-B	<1
WS-015170	5/19/2020	5/19/2021	1	Bottle Filler	In room 138 dining		WF-05192020-015170	5/10/2021	FT-FY21-032021-015170-A	<1	FT-FY21-032021-015170-B	<1
WS-015171	5/19/2020	5/19/2021	1	Cooler	In room 138 dining	High Left	WF-05192020-015171	5/10/2021	FT-FY21-032021-015171-A	<1	FT-FY21-032021-015171-B	<1
WS-015172	5/19/2020	5/19/2021	1	Cooler	In room 138 dining	Low Right	WF-05192020-015172	5/10/2021	FT-FY21-032021-015172-A	<1	FT-FY21-032021-015172-B	<1
WS-015188	5/19/2020	5/19/2021	1	Break Room	In room 106		WF-05192020-015188	5/10/2021	FT-FY21-032021-015188-A	<1	FT-FY21-032021-015188-B	<1
WS-015189	5/19/2020	5/19/2021	1	Cooler	In hallway adjacent to 115 mechanical	High Left	WF-05192020-015189	5/10/2021	FT-FY21-032021-015189-A	<1	FT-FY21-032021-015189-B	<1
WS-015190	5/19/2020	5/19/2021	1	Cooler	In hallway adjacent to 115 mechanical	Low Right	WF-05192020-015190	5/10/2021	FT-FY21-032021-015190-A	<1	FT-FY21-032021-015190-B	<1
WS-015196	5/19/2020	5/19/2021	1	Classroom Faucet	In room 118 first clock wise from entry		WF-05192020-015196	5/10/2021	FT-FY21-032021-015196-A	<1	FT-FY21-032021-015196-B	<1
WS-015199	5/19/2020	5/19/2021	1	Cooler	In room 121		WF-05192020-015199	5/10/2021	FT-FY21-032021-015199-A	<1	FT-FY21-032021-015199-B	<1
WS-015200	5/19/2020	5/19/2021	1	Cooler	In room 122		WF-05192020-015200	5/10/2021	FT-FY21-032021-015200-A	<1	FT-FY21-032021-015200-B	<1
WS-015217	5/19/2020	5/19/2021	2	Break Room	In room 221		WF-05192020-015217	5/10/2021	FT-FY21-032021-015217-A	<1	FT-FY21-032021-015217-B	<1
WS-015218	5/19/2020	5/19/2021	2	Break Room	In room 223		WF-05192020-015218	5/10/2021	FT-FY21-032021-015218-A	<1	FT-FY21-032021-015218-B	<1
WS-015219	5/19/2020	5/19/2021	2	Break Room	In room 225		WF-05192020-015219	5/10/2021	FT-FY21-032021-015219-A	<1	FT-FY21-032021-015219-B	<1
WS-015238	5/19/2020	5/19/2021	2	Cooler	In hallway adjacent to 209	High Left	WF-05192020-015238	5/10/2021	FT-FY21-032021-015238-A	<1	FT-FY21-032021-015238-B	<1
WS-015239	5/19/2020	5/19/2021	2	Cooler	In hallway adjacent to 209	Low Right	WF-05192020-015239	5/10/2021	FT-FY21-032021-015239-A	<1	FT-FY21-032021-015239-B	<1
WS-015242	5/19/2020	5/19/2021	2	Break Room	In room 216		WF-05192020-015242	5/10/2021	FT-FY21-032021-015242-A	<1	FT-FY21-032021-015242-B	<1
WS-015278	2/1/2021	2/1/2022	3	Food Prep Sink	In room 301		WF-02012021-015278	5/10/2021	FT-FY21-032021-015278-A	<1	FT-FY21-032021-015278-B	<1
WS-015282	5/19/2020	5/19/2021	3	Break Room	In room 312		WF-05192020-015282	5/10/2021	FT-FY21-032021-015282-A	<1	FT-FY21-032021-015282-B	<1
WS-015283	5/19/2020	5/19/2021	3	Cooler	In hallway across from 322	High Left	WF-05192020-015283	5/10/2021	FT-FY21-032021-015283-A	<1	FT-FY21-032021-015283-B	<1
WS-015284	5/19/2020	5/19/2021	3	Cooler	In hallway across from 322	Low Right	WF-05192020-015284	5/10/2021	FT-FY21-032021-015284-A	<1	FT-FY21-032021-015284-B	<1
WS-015293	5/19/2020	5/19/2021	4	Break Room	In room 406		WF-05192020-015293	5/10/2021	FT-FY21-032021-015293-A	<1	FT-FY21-032021-015293-B	<1
WS-015294	5/19/2020	5/19/2021	4	Cooler	In hallway across from 414	High Left	WF-05192020-015294	5/10/2021	FT-FY21-032021-015294-A	<1	FT-FY21-032021-015294-B	<1
WS-015295	5/19/2020	5/19/2021	4	Cooler	In hallway across from 414	Low Right	WF-05192020-015295	5/10/2021	FT-FY21-032021-015295-A	<1	FT-FY21-032021-015295-B	<1
WS-015301	5/19/2020	5/19/2021	Basement	Cooler	In gymnasium on southwest corner	High Left	WF-05192020-015301	5/10/2021	FT-FY21-032021-015301-A	<1	FT-FY21-032021-015301-B	<1
WS-015302	5/19/2020	5/19/2021	Basement	Cooler	In gymnasium on southwest corner	Low Right	WF-05192020-015302	5/10/2021	FT-FY21-032021-015302-A	<1	FT-FY21-032021-015302-B	<1
WS-015303	5/19/2020	5/19/2021	Basement	Cooler	In girls locker room 011	High Left	WF-05192020-015303	5/10/2021	FT-FY21-032021-015303-A	<1	FT-FY21-032021-015303-B	<1

WS-015304	5/19/2020	5/19/2021	Basement	Cooler	In girls locker room 011	Low	Right	WF-05192020-015304	5/10/2021	FT-FY21-032021-015304-A	<1	FT-FY21-032021-015304-B	<1
WS-015306	5/19/2020	5/19/2021	Basement	Bottle Filler	In gymnasium on northwest corner			WF-05192020-015306	5/10/2021	FT-FY21-032021-015306-A	<1	FT-FY21-032021-015306-B	<1
WS-015307	5/19/2020	5/19/2021	Basement	Cooler	In gymnasium on northwest corner	High	Left	WF-05192020-015307	5/10/2021	FT-FY21-032021-015307-A	<1	FT-FY21-032021-015307-B	<1
WS-015308	5/19/2020	5/19/2021	Basement	Cooler	In gymnasium on northwest corner	Low	Right	WF-05192020-015308	5/10/2021	FT-FY21-032021-015308-A	<1	FT-FY21-032021-015308-B	<1
WS-015309	7/14/2020	7/14/2021	Basement	Bottle Filler	In gym across from stairwell 3			WF-07142020-015309	5/10/2021	FT-FY21-032021-015309-A	<1	FT-FY21-032021-015309-B	<1
WS-015310	7/14/2020	7/14/2021	Basement	Cooler	In gym across from stairwell 3	High	Left	WF-07142020-015310	5/10/2021	FT-FY21-032021-015310-A	<1	FT-FY21-032021-015310-B	<1
WS-015311	7/14/2020	7/14/2021	Basement	Cooler	In gym across from stairwell 3	Low	Right	WF-07142020-015311	5/10/2021	FT-FY21-032021-015311-A	<1	FT-FY21-032021-015311-B	<1
WS-015312	7/14/2020	7/14/2021	Basement	Cooler	Inside team room 124A			WF-07142020-015312	5/10/2021	FT-FY21-032021-015312-A	<1	FT-FY21-032021-015312-B	<1
WS-015315	7/14/2020	7/14/2021	Basement	Bottle Filler	In gym adjacent to boys locker room 116			WF-07142020-015315	5/10/2021	FT-FY21-032021-015315-A	<1	FT-FY21-032021-015315-B	<1
WS-015316	7/14/2020	7/14/2021	Basement	Cooler	In gym adjacent to boys locker room 116	High	Left	WF-07142020-015316	5/10/2021	FT-FY21-032021-015316-A	<1	FT-FY21-032021-015316-B	<1
WS-015317	7/14/2020	7/14/2021	Basement	Cooler	In gym adjacent to boys locker room 116	Low	Right	WF-07142020-015317	5/10/2021	FT-FY21-032021-015317-A	<1	FT-FY21-032021-015317-B	<1
WS-015318	7/14/2020	7/14/2021	1	Bottle Filler	In gym overlook adjacent to 107 storage			WF-07142020-015318	5/10/2021	FT-FY21-032021-015318-A	<1	FT-FY21-032021-015318-B	<1
WS-015319	7/14/2020	7/14/2021	1	Cooler	In gym overlook adjacent to 107 storage	High	Left	WF-07142020-015319	5/10/2021	FT-FY21-032021-015319-A	<1	FT-FY21-032021-015319-B	<1
WS-015320	7/15/2020	7/15/2021	1	Cooler	In gym overlook adjacent to 107 storage	Low	Right	WF-07152020-015320	5/10/2021	FT-FY21-032021-015320-A	<1	FT-FY21-032021-015320-B	<1
WS-015321	7/15/2020	7/15/2021	1	Bottle Filler	In gym overlook adjacent to 111 storage			WF-07152020-015321	5/10/2021	FT-FY21-032021-015321-A	1.9	FT-FY21-032021-015321-B	<1
WS-015322	7/15/2020	7/15/2021	1	Cooler	In gym overlook adjacent to 111 storage	High	Left	WF-07152020-015322	5/10/2021	FT-FY21-032021-015322-A	<1	FT-FY21-032021-015322-B	<1
WS-015328	7/14/2020	7/14/2021	1	Cooler	In gym overlook adjacent to room 106	High	Left	WF-07142020-015328	5/10/2021	FT-FY21-032021-015328-A	2.8	FT-FY21-032021-015328-B	<1
WS-015329	7/14/2020	7/14/2021	1	Cooler	In gym overlook adjacent to room 106	Low	Right	WF-07142020-015329	5/10/2021	FT-FY21-032021-015329-A	3.8	FT-FY21-032021-015329-B	2.0

### Food Prep Sink

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-015182	2/1/2021	2/1/2022	1	Food Prep Sink	In kitchen tenth clockwise from entry	WF-02012021-015182	5/10/2021	FT-FY21-032021-015182-A	<1	FT-FY21-032021-015182-B	<1
WS-015223	2/1/2021	2/1/2022	2	Food Prep Sink	In room 237	WF-02012021-015223	5/10/2021	FT-FY21-032021-015223-A	<1	FT-FY21-032021-015223-B	<1

### FY21 Filter Test

Greater than 5ppb - Devices requiring remediation													
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)		
WS-015323	7/15/2020	7/15/2021	1	Cooler	In gym overlook adjacent to 111 storage	Low	Right	WF-07152020-015323	5/10/2021	FT-FY21-032021-015323-A	6.8	FT-FY21-032021-015323-B	<1
WS-015324	7/15/2020	7/15/2021	1	Bottle Filler	In gym overlook adjacent to room 110			WF-07152020-015324	5/10/2021	FT-FY21-032021-015324-A	12.0	FT-FY21-032021-015324-B	19.0
WS-015325	7/15/2020	7/15/2021	1	Cooler	In gym overlook adjacent to room 110	High	Left	WF-07152020-015325	5/10/2021	FT-FY21-032021-015325-A	2.7	FT-FY21-032021-015325-B	8.8
WS-015326	7/14/2020	7/14/2021	1	Cooler	In gym overlook adjacent to room 110	Low	Right	WF-07142020-015326	5/10/2021	FT-FY21-032021-015326-A	3.1	FT-FY21-032021-015326-B	7.4