



Coolidge High School Lead in Water Test Results

FY24 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-015151	4/3/2023	4/3/2024	1	Break Room	In room D102 adjacent to D102E (daycare)	WF-04032023-015151	11/21/2023	FT-FY24-10102023-015151-A	<1	FT-FY24-10102023-015151-B	<1
WS-015161	4/3/2023	4/3/2024	1	Health Suite	In room 149K	WF-04032023-015161	11/21/2023	FT-FY24-10102023-015161-A	1.1	FT-FY24-10102023-015161-B	<1
WS-015162	4/3/2023	4/3/2024	1	Health Suite	In room 149L	WF-04032023-015162	11/21/2023	FT-FY24-10102023-015162-A	<1	FT-FY24-10102023-015162-B	<1
WS-015163	4/3/2023	4/3/2024	1	Health Suite	In room 149J	WF-04032023-015163	11/21/2023	FT-FY24-10102023-015163-A	<1	FT-FY24-10102023-015163-B	<1
WS-015164	4/3/2023	4/3/2024	1	Health Suite	In room 149G	WF-04032023-015164	11/21/2023	FT-FY24-10102023-015164-A	<1	FT-FY24-10102023-015164-B	<1
WS-015166	4/3/2023	4/3/2024	1	Health Suite	In room 149A adjacent to dentist chair	Left WF-04032023-015166	11/21/2023	FT-FY24-10102023-015166-A	<1	FT-FY24-10102023-015166-B	<1
WS-015167	4/3/2023	4/3/2024	1	Health Suite	In room 149A in lab	Right WF-04032023-015167	11/21/2023	FT-FY24-10102023-015167-A	<1	FT-FY24-10102023-015167-B	<1
WS-015170	4/3/2023	4/3/2024	1	Bottle Filler	In room 138 dining	WF-04032023-015170	11/21/2023	FT-FY24-10102023-015170-A	<1	FT-FY24-10102023-015170-B	<1
WS-015171	4/3/2023	4/3/2024	1	Cooler	In room 138 dining	High Left WF-04032023-015171	11/21/2023	FT-FY24-10102023-015171-A	<1	FT-FY24-10102023-015171-B	<1
WS-015172	4/3/2023	4/3/2024	1	Cooler	In room 138 dining	Low Right WF-04032023-015172	11/21/2023	FT-FY24-10102023-015172-A	<1	FT-FY24-10102023-015172-B	<1
WS-015188	4/3/2023	4/3/2024	1	Break Room	In room 106	WF-04032023-015188	11/21/2023	FT-FY24-10102023-015188-A	<1	FT-FY24-10102023-015188-B	<1
WS-015189	4/3/2023	4/3/2024	1	Cooler	In hallway adjacent to 115 mechanical	High Left WF-04032023-015189	11/21/2023	FT-FY24-10102023-015189-A	<1	FT-FY24-10102023-015189-B	<1
WS-015190	4/3/2023	4/3/2024	1	Cooler	In hallway adjacent to 115 mechanical	Low Right WF-04032023-015190	11/21/2023	FT-FY24-10102023-015190-A	<1	FT-FY24-10102023-015190-B	<1
WS-015196	4/3/2023	4/3/2024	1	Classroom Faucet	In room 118 first clock wise from entry	WF-04032023-015196	11/21/2023	FT-FY24-10102023-015196-A	<1	FT-FY24-10102023-015196-B	<1
WS-015217	4/3/2023	4/3/2024	2	Break Room	In room 221	WF-04032023-015217	11/21/2023	FT-FY24-10102023-015217-A	<1	FT-FY24-10102023-015217-B	<1
WS-015218	4/3/2023	4/3/2024	2	Break Room	In room 223	WF-04032023-015218	11/21/2023	FT-FY24-10102023-015218-A	<1	FT-FY24-10102023-015218-B	<1
WS-015219	4/3/2023	4/3/2024	2	Break Room	In room 225	WF-04032023-015219	11/21/2023	FT-FY24-10102023-015219-A	<1	FT-FY24-10102023-015219-B	<1
WS-015242	4/3/2023	4/3/2024	2	Break Room	In room 216	WF-04032023-015242	11/21/2023	FT-FY24-10102023-015242-A	<1	FT-FY24-10102023-015242-B	<1
WS-015265	4/3/2023	4/3/2024	3	Cooler	In room 341	WF-04032023-015265	11/21/2023	FT-FY24-10102023-015265-A	<1	FT-FY24-10102023-015265-B	<1
WS-015282	4/3/2023	4/3/2024	3	Break Room	In room 312	WF-04032023-015282	11/21/2023	FT-FY24-10102023-015282-A	<1	FT-FY24-10102023-015282-B	<1
WS-015283	4/3/2023	4/3/2024	3	Cooler	In hallway across from 322	High Left WF-04032023-015283	11/21/2023	FT-FY24-10102023-015283-A	<1	FT-FY24-10102023-015283-B	<1
WS-015284	4/3/2023	4/3/2024	3	Cooler	In hallway across from 322	Low Right WF-04032023-015284	11/21/2023	FT-FY24-10102023-015284-A	<1	FT-FY24-10102023-015284-B	<1
WS-015293	4/3/2023	4/3/2024	4	Break Room	In room 406	WF-04032023-015293	11/21/2023	FT-FY24-10102023-015293-A	<1	FT-FY24-10102023-015293-B	<1
WS-015294	4/3/2023	4/3/2024	4	Cooler	In hallway across from 414	High Left WF-04032023-015294	11/21/2023	FT-FY24-10102023-015294-A	<1	FT-FY24-10102023-015294-B	<1
WS-015295	4/3/2023	4/3/2024	4	Cooler	In hallway across from 414	Low Right WF-04032023-015295	11/21/2023	FT-FY24-10102023-015295-A	<1	FT-FY24-10102023-015295-B	<1
WS-015300	4/3/2023	4/3/2024	Basement	Bottle Filler	In gymnasium on southwest corner	WF-04032023-015300	11/21/2023	FT-FY24-10102023-015300-A	<1	FT-FY24-10102023-015300-B	<1
WS-015301	4/3/2023	4/3/2024	Basement	Cooler	In gymnasium on southwest corner	High Left WF-04032023-015301	11/21/2023	FT-FY24-10102023-015301-A	<1	FT-FY24-10102023-015301-B	<1
WS-015302	4/3/2023	4/3/2024	Basement	Cooler	In gymnasium on southwest corner	Low Right WF-04032023-015302	11/21/2023	FT-FY24-10102023-015302-A	<1	FT-FY24-10102023-015302-B	<1
WS-015303	4/3/2023	4/3/2024	Basement	Cooler	In girls locker room 011	High Left WF-04032023-015303	11/21/2023	FT-FY24-10102023-015303-A	<1	FT-FY24-10102023-015303-B	<1
WS-015304	4/3/2023	4/3/2024	Basement	Cooler	In girls locker room 011	Low Right WF-04032023-015304	11/21/2023	FT-FY24-10102023-015304-A	<1	FT-FY24-10102023-015304-B	<1
WS-015306	4/3/2023	4/3/2024	Basement	Bottle Filler	In gymnasium on northwest corner	WF-04032023-015306	11/21/2023	FT-FY24-10102023-015306-A	<1	FT-FY24-10102023-015306-B	<1
WS-015307	4/3/2023	4/3/2024	Basement	Cooler	In gymnasium on northwest corner	High Left WF-04032023-015307	11/21/2023	FT-FY24-10102023-015307-A	<1	FT-FY24-10102023-015307-B	<1
WS-015308	4/3/2023	4/3/2024	Basement	Cooler	In gymnasium on northwest corner	Low Right WF-04032023-015308	11/21/2023	FT-FY24-10102023-015308-A	<1	FT-FY24-10102023-015308-B	<1
WS-015309	4/3/2023	4/3/2024	Basement	Bottle Filler	In gym across from stairwell 3	WF-04032023-015309	11/21/2023	FT-FY24-10102023-015309-A	<1	FT-FY24-10102023-015309-B	<1

WS-015310	4/3/2023	4/3/2024	Basement	Cooler	In gym across from stairwell 3	High Left	WF-04032023-015310	11/21/2023	FT-FY24-10102023-015310-A	<1	FT-FY24-10102023-015310-B	<1
WS-015311	4/3/2023	4/3/2024	Basement	Cooler	In gym across from stairwell 3	Low Right	WF-04032023-015311	11/21/2023	FT-FY24-10102023-015311-A	<1	FT-FY24-10102023-015311-B	<1
WS-015312	4/3/2023	4/3/2024	Basement	Cooler	Inside team room 124A		WF-04032023-015312	11/21/2023	FT-FY24-10102023-015312-A	<1	FT-FY24-10102023-015312-B	<1
WS-015313	4/3/2023	4/3/2024	Basement	Cooler	In boys locker room	High Left	WF-04032023-015313	11/21/2023	FT-FY24-10102023-015313-A	2.5	FT-FY24-10102023-015313-B	<1
WS-015314	4/3/2023	4/3/2024	Basement	Cooler	In boys locker room	Low Right	WF-04032023-015314	11/21/2023	FT-FY24-10102023-015314-A	<1	FT-FY24-10102023-015314-B	<1
WS-015315	4/3/2023	4/3/2024	Basement	Bottle Filler	In gym adjacent to boys locker room 116		WF-04032023-015315	11/21/2023	FT-FY24-10102023-015315-A	<1	FT-FY24-10102023-015315-B	<1
WS-015316	4/3/2023	4/3/2024	Basement	Cooler	In gym adjacent to boys locker room 116	High Left	WF-04032023-015316	11/21/2023	FT-FY24-10102023-015316-A	<1	FT-FY24-10102023-015316-B	<1
WS-015317	4/3/2023	4/3/2024	Basement	Cooler	In gym adjacent to boys locker room 116	Low Right	WF-04032023-015317	11/21/2023	FT-FY24-10102023-015317-A	<1	FT-FY24-10102023-015317-B	<1
WS-015321	4/3/2023	4/3/2024	1	Bottle Filler	In gym overlook adjacent to 111 storage		WF-04032023-015321	11/21/2023	FT-FY24-10102023-015321-A	<1	FT-FY24-10102023-015321-B	<1
WS-015322	4/3/2023	4/3/2024	1	Cooler	In gym overlook adjacent to 111 storage	High Left	WF-04032023-015322	11/21/2023	FT-FY24-10102023-015322-A	<1	FT-FY24-10102023-015322-B	<1
WS-015323	4/3/2023	4/3/2024	1	Cooler	In gym overlook adjacent to 111 storage	Low Right	WF-04032023-015323	11/21/2023	FT-FY24-10102023-015323-A	<1	FT-FY24-10102023-015323-B	<1
WS-015324	4/3/2023	4/3/2024	1	Bottle Filler	In gym overlook adjacent to room 110		WF-04032023-015324	11/21/2023	FT-FY24-10102023-015324-A	<1	FT-FY24-10102023-015324-B	<1
WS-015325	4/3/2023	4/3/2024	1	Cooler	In gym overlook adjacent to room 110	High Left	WF-04032023-015325	11/21/2023	FT-FY24-10102023-015325-A	<1	FT-FY24-10102023-015325-B	<1
WS-015326	4/3/2023	4/3/2024	1	Cooler	In gym overlook adjacent to room 110	Low Right	WF-04032023-015326	11/21/2023	FT-FY24-10102023-015326-A	<1	FT-FY24-10102023-015326-B	<1
WS-015327	4/3/2023	4/3/2024	1	Bottle Filler	In gym overlook adjacent to room 106		WF-04032023-015327	11/21/2023	FT-FY24-10102023-015327-A	<1	FT-FY24-10102023-015327-B	<1
WS-015328	4/3/2023	4/3/2024	1	Cooler	In gym overlook adjacent to room 106	High Left	WF-04032023-015328	11/21/2023	FT-FY24-10102023-015328-A	<1	FT-FY24-10102023-015328-B	<1
WS-015329	4/3/2023	4/3/2024	1	Cooler	In gym overlook adjacent to room 106	Low Right	WF-04032023-015329	11/21/2023	FT-FY24-10102023-015329-A	<1	FT-FY24-10102023-015329-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-015182	1/3/2023	1/3/2024	1	Food Prep Sink	In kitchen tenth clockwise from entry	WF-01032023-015182	11/21/2023	FT-FY24-10102023-015182-A	<1	FT-FY24-10102023-015182-B	<1
WS-015278	1/3/2023	1/3/2024	3	Food Prep Sink	In room 301	WF-01032023-015278	11/21/2023	FT-FY24-10102023-015278-A	<1	FT-FY24-10102023-015278-B	<1