



COOLIDGE LEAD WATER TEST RESULTS

May 16th, 2016



Building Location	Sample Collected Date	Water Source ID	Device Type	Floor	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)	Remediation	Retest Date	Retest 1st Draw	Retest 2nd Draw	
1	COOLIDGE HIGH SCHOOL	5/17/2016	WS-012255	Cooler	3	In hallway adjacent to stairway 5	WT-042916-12272-A	< 1	WT-042916-12272-B	< 1				
2	COOLIDGE HIGH SCHOOL	5/17/2016	WS-012254	Cooler	3	In hallway adjacent to stairway 6	WT-042916-12271-A	< 1	WT-042916-12271-B	< 1				
3	COOLIDGE HIGH SCHOOL	5/17/2016	WS-012253	Cooler	3	In hallway adjacent staircase 4	WT-042916-12270-A	< 1	WT-042916-12270-B	< 1				
4	COOLIDGE HIGH SCHOOL	5/17/2016	WS-012252	Cooler	3	In hallway adjacent staircase 3	WT-042916-12269-A	< 1	WT-042916-12269-B	< 1				
5	COOLIDGE HIGH SCHOOL	5/17/2016	WS-012251	Cooler	2	In hallway adjacent to stairway 5	WT-042916-12268-A	< 1	WT-042916-12268-B	< 1				
6	COOLIDGE HIGH SCHOOL	5/17/2016	WS-012250	Cooler	2	In hallway adjacent to stairway 6	WT-042916-12267-A	< 1	WT-042916-12267-B	< 1				
7	COOLIDGE HIGH SCHOOL	5/17/2016	WS-012249	Cooler	2	In hallway adjacent to stairway 4	WT-042916-12266-A	< 1	WT-042916-12266-B	< 1				
8	COOLIDGE HIGH SCHOOL	5/17/2016	WS-012248	Cooler	2	In hallway adjacent to stairway 3	WT-042916-12265-A	< 1	WT-042916-12265-B	< 1				
9	COOLIDGE HIGH SCHOOL	5/17/2016	WS-012239	Classroom	1	In classroom 107 sink 1	WT-042916-12256-A	3.4	WT-042916-12256-B	< 1				
10	COOLIDGE HIGH SCHOOL	5/17/2016	WS-012238	Classroom	1	In room 127 clockwise sink 10	WT-042916-12255-A	41	WT-042916-12255-B	2	labeled "not for drinking"			
11	COOLIDGE HIGH SCHOOL	5/17/2016	WS-012237	Classroom	1	In room 127 clockwise sink 9	WT-042916-12254-A	58	WT-042916-12254-B	8.3	labeled "not for drinking"			
12	COOLIDGE HIGH SCHOOL	5/17/2016	WS-012236	Classroom	1	In room 127 clock wise sink 8	WT-042916-12253-A	4.6	WT-042916-12253-B	< 1				
13	COOLIDGE HIGH SCHOOL	5/17/2016	WS-012235	Classroom	1	In classroom 127 sink 7	WT-042916-12252-A	1.4	WT-042916-12252-B	< 1				
14	COOLIDGE HIGH SCHOOL	5/17/2016	WS-012234	Classroom	1	In classroom 127 sink 6	WT-042916-12251-A	< 1	WT-042916-12251-B	< 1				
15	COOLIDGE HIGH SCHOOL	5/17/2016	WS-012233	Classroom	1	In classroom 127 sink 5	WT-042916-12250-A	4.7	WT-042916-12250-B	< 1				
16	COOLIDGE HIGH SCHOOL	5/17/2016	WS-012232	Classroom	1	In classroom 127 sink 4	WT-042916-12249-A	1.3	WT-042916-12249-B	< 1				
17	COOLIDGE HIGH SCHOOL	5/17/2016	WS-012231	Classroom	1	In classroom 127 sink 3	WT-042916-12248-A	4.1	WT-042916-12248-B	< 1				
18	COOLIDGE HIGH SCHOOL	5/17/2016	WS-012230	Classroom	1	In classroom 127 sink 2	WT-042916-12247-A	60	WT-042916-12247-B	2.2	labeled "not for drinking"			
19	COOLIDGE HIGH SCHOOL	5/17/2016	WS-012229	Classroom	1	In classroom 127 sink 1	WT-042916-12246-A	76	WT-042916-12246-B	11	labeled "not for drinking"			
20	COOLIDGE HIGH SCHOOL	5/17/2016	WS-012228	Health Suite	1	In laboratory room 2673	WT-042916-12245-A	< 1	WT-042916-12245-B	< 1				
21	COOLIDGE HIGH SCHOOL	5/17/2016	WS-012227	Health Suite	1	In break room 2678	WT-042916-12244-A	< 1	WT-042916-12244-B	< 1				
22	COOLIDGE HIGH SCHOOL	5/17/2016	WS-012226	Health Suite	1	In exam room 2676	WT-042916-12243-A	< 1	WT-042916-12243-B	< 1				
23	COOLIDGE HIGH SCHOOL	5/17/2016	WS-012225	Health Suite	1	In exam room 2674	WT-042916-12242-A	< 1	WT-042916-12242-B	< 1				
24	COOLIDGE HIGH SCHOOL	5/17/2016	WS-012224	Health Suite	1	In exam room 2672	WT-042916-12241-A	< 1	WT-042916-12241-B	< 1				
25	COOLIDGE HIGH SCHOOL	5/17/2016	WS-012223	Classroom	1	In art classroom 105 sink 2	WT-042916-12240-A	67	WT-042916-12240-B	72	labeled "not for drinking"			
26	COOLIDGE HIGH SCHOOL	5/17/2016	WS-012222	Classroom	1	In art classroom 105 sink 1	WT-042916-12239-A	3.4	WT-042916-12239-B	1.9				
27	COOLIDGE HIGH SCHOOL	5/17/2016	WS-012221	Cooler	1	In hallway adjacent to stairway 3	WT-042916-12238-A	< 1	WT-042916-12238-B	1.4				
28	COOLIDGE HIGH SCHOOL	5/17/2016	WS-012219	Cooler	1	In hallway adjacent to stairway 6	WT-042916-12236-A	< 1	WT-042916-12236-B	< 1				
29	COOLIDGE HIGH SCHOOL	5/17/2016	WS-012218	Cooler	1	In hallway adjacent to stairway 4	WT-042916-12235-A	< 1	WT-042916-12235-B	< 1				
30	COOLIDGE HIGH SCHOOL	5/17/2016	WS-012216	Cooler	Ground Floor	In the Frank's r Williams activity center adjacent to door 174	WT-042916-12233-A	2.2	WT-042916-12233-B	< 1				
31	COOLIDGE HIGH SCHOOL	5/17/2016	WS-012215	Fountain	Ground Floor	In frank r William activity center adjacent to door 173	WT-042916-12232-A	5.6	WT-042916-12232-B	2.5				
32	COOLIDGE HIGH SCHOOL	5/17/2016	WS-012214	Cooler	Ground Floor	In frank r William activity center adjacent to door 173	WT-042916-12231-A	1.4	WT-042916-12231-B	2.6				
33	COOLIDGE HIGH SCHOOL	5/17/2016	WS-012213	Cooler	Ground Floor	In frank r William activity center adjacent to door 172	WT-042916-12230-A	< 1	WT-042916-12230-B	< 1				
34	COOLIDGE HIGH SCHOOL	5/17/2016	WS-012212	Cooler	Basement	In gymnasium adjacent to stairway 2	WT-042916-12229-A	< 1	WT-042916-12229-B	< 1				
35	COOLIDGE HIGH SCHOOL	5/17/2016	WS-012211	Cooler	Basement	In girl basketball locker room	WT-042916-12228-A		WT-042916-12228-B					
36	COOLIDGE HIGH SCHOOL	5/17/2016	WS-012210	Cooler	Basement	In girls locker room (new building)	WT-042916-12227-A	1.4	WT-042916-12227-B	2.1				
37	COOLIDGE HIGH SCHOOL	5/17/2016	WS-012209	Cooler	Basement	In hallway adjacent to girl locker room	WT-042916-12226-A	< 1	WT-042916-12226-B	< 1				
38	COOLIDGE HIGH SCHOOL	5/17/2016	WS-012208	Cooler	Basement	In boys locker room	WT-042916-12225-A	< 1	WT-042916-12225-B	< 1				
39	COOLIDGE HIGH SCHOOL	5/17/2016	WS-012207	Cooler	Basement	In gymnasium north side adjacent to stairway	WT-042916-12224-A	4.1	WT-042916-12224-B	< 1				
40	COOLIDGE HIGH SCHOOL	5/17/2016	WS-012206	Cooler	Basement	In boys varisty basketball locker room	WT-042916-12223-A	520	WT-042916-12223-B	760	Device removed			
41	COOLIDGE HIGH SCHOOL	5/17/2016	WS-012205	Cooler	Basement	In gymnasium	WT-042916-12222-A	1.9	WT-042916-12222-B	< 1				
42	COOLIDGE HIGH SCHOOL	5/17/2016	WS-012204	Cooler	Basement	In hallway adjacent to weight room 8105	WT-042916-12221-A	< 1	WT-042916-12221-B	< 1				
43	COOLIDGE HIGH SCHOOL	5/17/2016	WS-012203	Cooler	Ground Floor	In boys gymnasium	WT-042916-12220-A	< 1	WT-042916-12220-B	< 1				
44	COOLIDGE HIGH SCHOOL	5/17/2016	WS-012202	Cooler	Ground Floor	In hallway adjacent to armory	WT-042916-12219-A	< 1	WT-042916-12219-B	< 1				
45	COOLIDGE HIGH SCHOOL	5/18/2016	WS-012201	Cooler	Ground Floor	In girls gym adjacent to Cafeteria	WT-042916-12218-A	< 1	WT-042916-12218-B	< 1				
46	COOLIDGE HIGH SCHOOL	5/17/2016	WS-012200	Cooler	Ground Floor	In cafeteria adjacent to kitchen	WT-042916-12217-A	21	WT-042916-12217-B	1.5	Filtered	7/1/2016	<1	<1
47	COOLIDGE HIGH SCHOOL	5/17/2016	WS-012199	Kitchen	Ground Floor	In kitchen clockwise 2nd sink	WT-042916-12216-A	< 1	WT-042916-12216-B	< 1				
48	COOLIDGE HIGH SCHOOL	5/17/2016	WS-012198	Kitchen	Ground Floor	In kitchen clockwise 1st sink	WT-042916-12215-A	1.8	WT-042916-12215-B	< 1				
49	COOLIDGE HIGH SCHOOL	5/17/2016	WS-012197	Utility	Basement	Basement Sink	WT-042916-12214-A	1.6	WT-042916-12214-B	< 1				



COOLIDGE LEAD WATER TEST RESULTS

May 16th, 2016



Building Location	Sample Collected Date	Water Source ID	Device Type	Floor	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)	Remediation	Retest Date	Retest 1st Draw	Retest 2nd Draw
-------------------	-----------------------	-----------------	-------------	-------	-----------------	----------------------	--------------------------------	----------------------	--------------------------------	-------------	-------------	-----------------	-----------------

Footnotes:

A - First draw sample is collected after the plumbing system has not been used for at least 6 hours.

B - Second draw sample is collected after a 60 second flush at that device after the first draw.