



DC Therapeutic / TR Lead Water Test Results



FY18 Filter Test

Less than 5 ppb - Devices Requiring No Remediation												
RECORD ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location		WATER FILTERS Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 011549	5/30/2017	5/30/2018	1	Break Room	In activity room	Left	WF-52017-011549	3/1/2018	FT-FY18--52017-011549-A	<1	FT-FY18--52017-011549-B	<1

Greater than 5 ppb - Devices Requiring Remediation												
WS- 011550	5/30/2017	5/30/2018	1	Fountain	In activity room	Right	WF-52017-011550	3/1/2018	FT-FY18--52017-011550-A	17	FT-FY18--52017-011550-B	9.5

Food Prep Sink

Less than 5 ppb - Devices Requiring No Remediation												
RECORD ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location		WATER FILTERS Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 011548	5/30/2017	5/30/2018	1	Food Prep Sink	In kitchen		WF-52017-011548	3/1/2018	FT-FY18--52017-011548-A	<1	FT-FY18--52017-011548-B	<1

First Re-test (After Plumbing Check)

FY18 Filter Test

Less than 5 ppb - Devices Requiring No Remediation												
RECORD ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location		WATER FILTERS Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 011550	5/30/2017	5/30/2018	1	Combo Fountain	In activity room	Right	WF-52017-011550	3/9/2018	FT-FY18--52017-011550-A	2.5	FT-FY18--52017-011550-B	<1