



DUKE ELLINGTON LEAD WATER TEST RESULTS



Initial Filter Test After Installation

Below Actionable Level - Devices Requiring No Remediation

Building Location: Building Name	RECORD ID	Date Analyzed	Floor	Device Type	Device Location			1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
DUKE ELLINGTON	WS- 009191	8/25/2017	1	Cooler	In hallway across from electrical room 124a	Low	Right	FT-82017-009191-A	< 1	FT-82017-009191-B	< 1
DUKE ELLINGTON	WS- 009192	8/25/2017	1	Cooler	In hallway across from electrical room 124a	High	Left	FT-82017-009192-A	< 1	FT-82017-009192-B	< 1
DUKE ELLINGTON	WS- 009402	8/25/2017	Ground Floor	Cooler	In hallway adjacent to room G32A	High	Left	FT-82017-009402-A	< 1	FT-82017-009402-B	< 1
DUKE ELLINGTON	WS- 009403	8/25/2017	Ground Floor	Cooler	In hallway adjacent to room G32A	Low	Right	FT-82017-009403-A	< 1	FT-82017-009403-B	< 1
DUKE ELLINGTON	WS- 009404	8/25/2017	Ground Floor	Cooler	In hallway across from room G60	High	Left	FT-82017-009404-A	< 1	FT-82017-009404-B	< 1
DUKE ELLINGTON	WS- 009405	8/25/2017	Ground Floor	Cooler	In hallway across from room G60	Low	Right	FT-82017-009405-A	< 1	FT-82017-009405-B	< 1
DUKE ELLINGTON	WS- 009406	8/25/2017	Ground Floor	Cooler	In cafeteria	High	Left	FT-82017-009406-A	< 1	FT-82017-009406-B	< 1
DUKE ELLINGTON	WS- 009407	8/25/2017	Ground Floor	Cooler	In cafeteria	Low	Right	FT-82017-009407-A	< 1	FT-82017-009407-B	< 1
DUKE ELLINGTON	WS- 009417	8/25/2017	Ground Floor	Cooler	In hallway adjacent to workroom G08	High	Left	FT-82017-009417-A	< 1	FT-82017-009417-B	< 1
DUKE ELLINGTON	WS- 009418	8/25/2017	Ground Floor	Cooler	In hallway adjacent to workroom G08	Low	Right	FT-82017-009418-A	< 1	FT-82017-009418-B	< 1
DUKE ELLINGTON	WS- 009419	8/25/2017	Ground Floor	Health Suite	In health suite in alcove G16			FT-82017-009419-A	< 1	FT-82017-009419-B	< 1
DUKE ELLINGTON	WS- 009420	8/25/2017	Ground Floor	Health Suite	In health suite in health lab room G24			FT-82017-009420-A	< 1	FT-82017-009420-B	< 1
DUKE ELLINGTON	WS- 009421	8/25/2017	Ground Floor	Health Suite	In health suite in treatment room G18			FT-82017-009421-A	< 1	FT-82017-009421-B	< 1
DUKE ELLINGTON	WS- 009422	8/25/2017	Ground Floor	Cooler	In fitness center room G26	High	Left	FT-82017-009422-A	< 1	FT-82017-009422-B	< 1
DUKE ELLINGTON	WS- 009423	8/25/2017	Ground Floor	Cooler	In fitness center room G26	Low	Right	FT-82017-009423-A	< 1	FT-82017-009423-B	< 1
DUKE ELLINGTON	WS- 009424	8/25/2017	1	Cooler	In hallway adjacent to storage room 131	High	Left	FT-82017-009424-A	< 1	FT-82017-009424-B	< 1
DUKE ELLINGTON	WS- 009425	8/25/2017	1	Cooler	In hallway adjacent to storage room 131	Low	Right	FT-82017-009425-A	< 1	FT-82017-009425-B	< 1
DUKE ELLINGTON	WS- 009427	8/25/2017	1	Combo Fountain	In classroom 135			FT-82017-009427-A	< 1	FT-82017-009427-B	< 1
DUKE ELLINGTON	WS- 009429	8/25/2017	1	Combo Fountain	In office room 136			FT-82017-009429-A	< 1	FT-82017-009429-B	< 1
DUKE ELLINGTON	WS- 009430	8/25/2017	1	Cooler	In hallway adjacent to storage room 155			FT-82017-009430-A	< 1	FT-82017-009430-B	< 1
DUKE ELLINGTON	WS- 009431	8/25/2017	1	Cooler	In hallway adjacent to storage room 155	Low	Right	FT-82017-009431-A	< 1	FT-82017-009431-B	< 1
DUKE ELLINGTON	WS- 009440	8/25/2017	1	Cooler	In hallway adjacent to custodial room 123	High	Left	FT-82017-009440-A	< 1	FT-82017-009440-B	< 1
DUKE ELLINGTON	WS- 009441	8/25/2017	1	Cooler	In hallway adjacent to custodial room 123	Low	Right	FT-82017-009441-A	< 1	FT-82017-009441-B	< 1
DUKE ELLINGTON	WS- 009444	8/25/2017	1	Break Room	In workroom 108			FT-82017-009444-A	< 1	FT-82017-009444-B	< 1
DUKE ELLINGTON	WS- 009446	8/25/2017	1	Break Room	In main office across from office room 119			FT-82017-009446-A	< 1	FT-82017-009446-B	< 1
DUKE ELLINGTON	WS- 009447	8/25/2017	2	Cooler	In hallway adjacent to dance studio 218	High	Left	FT-82017-009447-A	< 1	FT-82017-009447-B	< 1
DUKE ELLINGTON	WS- 009448	8/25/2017	2	Cooler	In hallway adjacent to dance studio 218	Low	Right	FT-82017-009448-A	< 1	FT-82017-009448-B	< 1
DUKE ELLINGTON	WS- 009449	8/25/2017	2	Cooler	In hallway adjacent to dance studio 225	High	Left	FT-82017-009449-A	< 1	FT-82017-009449-B	< 1
DUKE ELLINGTON	WS- 009450	8/25/2017	2	Cooler	In hallway adjacent to dance studio 225	Low	Right	FT-82017-009450-A	< 1	FT-82017-009450-B	< 1
DUKE ELLINGTON	WS- 009452	8/25/2017	2	Cooler	In hallway adjacent to dance studio 232	High	Left	FT-82017-009452-A	< 1	FT-82017-009452-B	< 1
DUKE ELLINGTON	WS- 009453	8/25/2017	2	Cooler	In hallway adjacent to dance studio 232	Low	Right	FT-82017-009453-A	< 1	FT-82017-009453-B	< 1
DUKE ELLINGTON	WS- 009455	8/25/2017	2	Cooler	In hallway adjacent to LMC studio 245	High	Left	FT-82017-009455-A	< 1	FT-82017-009455-B	< 1
DUKE ELLINGTON	WS- 009456	8/25/2017	2	Cooler	In hallway adjacent to LMC studio 245	Low	Right	FT-82017-009456-A	< 1	FT-82017-009456-B	< 1
DUKE ELLINGTON	WS- 009457	8/25/2017	2	Cooler	In hallway adjacent to classroom 265	High	Left	FT-82017-009457-A	< 1	FT-82017-009457-B	< 1
DUKE ELLINGTON	WS- 009458	8/25/2017	2	Cooler	In hallway adjacent to classroom 265	Low	Right	FT-82017-009458-A	< 1	FT-82017-009458-B	< 1
DUKE ELLINGTON	WS- 009459	8/25/2017	2	Break Room	In workroom 206			FT-82017-009459-A	< 1	FT-82017-009459-B	< 1
DUKE ELLINGTON	WS- 009460	8/25/2017	2	Cooler	In hallway adjacent to classroom 209	High	Left	FT-82017-009460-A	< 1	FT-82017-009460-B	< 1
DUKE ELLINGTON	WS- 009461	8/25/2017	2	Cooler	In hallway adjacent to classroom 209	Low	Right	FT-82017-009461-A	< 1	FT-82017-009461-B	< 1
DUKE ELLINGTON	WS- 009462	8/25/2017	3	Cooler	In instrumental studio 313			FT-82017-009462-A	< 1	FT-82017-009462-B	< 1
DUKE ELLINGTON	WS- 009463	8/25/2017	3	Cooler	In hallway adjacent to instrumental studio 313	High	Left	FT-82017-009463-A	< 1	FT-82017-009463-B	< 1
DUKE ELLINGTON	WS- 009464	8/25/2017	3	Cooler	In hallway adjacent to instrumental studio 313	Low	Right	FT-82017-009464-A	< 1	FT-82017-009464-B	< 1
DUKE ELLINGTON	WS- 009465	8/25/2017	3	Cooler	In hallway adjacent to classroom 353	High	Left	FT-82017-009465-A	< 1	FT-82017-009465-B	< 1
DUKE ELLINGTON	WS- 009466	8/25/2017	3	Cooler	In hallway adjacent to classroom 353	Low	Right	FT-82017-009466-A	< 1	FT-82017-009466-B	< 1

DUKE ELLINGTON	WS- 009468	8/25/2017	3	Cooler	In orchestra rehearsal room 363			FT-82017-009468-A	< 1	FT-82017-009468-B	< 1
DUKE ELLINGTON	WS- 009469	8/25/2017	3	Cooler	In hallway adjacent to classroom 372	High	Left	FT-82017-009469-A	< 1	FT-82017-009469-B	< 1
DUKE ELLINGTON	WS- 009470	8/25/2017	3	Cooler	In hallway adjacent to classroom 372	Low	Right	FT-82017-009470-A	< 1	FT-82017-009470-B	< 1
DUKE ELLINGTON	WS- 009471	8/25/2017	3	Cooler	In hallway adjacent to classroom 304	High	Left	FT-82017-009471-A	< 1	FT-82017-009471-B	< 1
DUKE ELLINGTON	WS- 009472	8/25/2017	3	Cooler	In hallway adjacent to classroom 304	Low	Right	FT-82017-009472-A	< 1	FT-82017-009472-B	< 1