



# Davis Elementary Lead Water Test Results



## FY18 Filter Test

Less than 5 ppb - Devices Requiring No Remediation											
RECORD ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	WATER FILTERS Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 007502	8/31/2017	8/31/2018	2	Cooler	In hallway across from room 207	WF-92017-007502	12/19/2017	FT-FY18--92017-007502-A	<1	FT-FY18--92017-007502-B	<1
WS- 007504	11/22/2017	11/22/2018	1	Combo Faucet	In classroom c109	WF-112017-007504	12/19/2017	FT-FY18-112017-007504-A	<1	FT-FY18-112017-007504-B	<1
WS- 007506	11/22/2017	11/22/2018	1	Combo Faucet	In classroom c103	WF-112017-007506	12/19/2017	FT-FY18-112017-007506-A	<1	FT-FY18-112017-007506-B	<1
WS- 007507	11/22/2017	11/22/2018	1	Combo Faucet	In classroom c102	WF-112017-007507	12/19/2017	FT-FY18-112017-007507-A	<1	FT-FY18-112017-007507-B	<1
WS- 007508	8/31/2017	8/31/2018	1	Cooler	In hallway adjacent to b101c janitor closet	WF-92017-007508	12/19/2017	FT-FY18--92017-007508-A	<1	FT-FY18--92017-007508-B	<1
WS- 007509	8/31/2017	8/31/2018	1	Health Suite	In health suite room a103	WF-92017-007509	12/19/2017	FT-FY18--92017-007509-A	<1	FT-FY18--92017-007509-B	<1

## Food Prep Sink

Less than 5 ppb - Devices Requiring No Remediation										
RECORD ID	Floor	Device Type	Device Location		Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS- 007515	Basement	Food Prep Sink	In kitchen third from left	Right	12/19/2017	FT-FY18-122017-007515-A	<1	FT-FY18-122017-007515-B	<1	