



DEAL MS LEAD WATER TEST RESULTS



Building Location: Building Name	RECORD ID	Date Analyzed	Floor	Device Type	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)
1 DEAL MIDDLE SCHOOL	WS- 010535	8/20/2016	Ground Floor	Food Prep Sink	In kitchen on west wall Left	FT-72016-010535-A	< 1	FT-72016-010535-B	< 1
2 DEAL MIDDLE SCHOOL	WS- 011155	8/20/2016	Ground Floor	Cooler	In cafeteria room NG20 High Left	FT-72016-011155-A	< 1	FT-72016-011155-B	< 1
3 DEAL MIDDLE SCHOOL	WS- 011156	8/20/2016	Ground Floor	Cooler	In cafeteria room NG20 Low Right	FT-82016-011156-A	< 1	FT-82016-011156-B	< 1
4 DEAL MIDDLE SCHOOL	WS- 011157	8/20/2016	Ground Floor	Cooler	In hallway adjacent to room NG20	FT-72016-011157-A	< 1	FT-72016-011157-B	< 1
5 DEAL MIDDLE SCHOOL	WS- 011158	8/20/2016	Ground Floor	Cooler	In hallway adjacent to room NG20 Low Right	FT-82016-011158-A	< 1	FT-82016-011158-B	< 1
6 DEAL MIDDLE SCHOOL	WS- 011159	8/20/2016	Ground Floor	Cooler	In hallway adjacent to girls' restroom High Left	FT-82016-011159-A	< 1	FT-82016-011159-B	< 1
7 DEAL MIDDLE SCHOOL	WS- 011160	8/20/2016	Ground Floor	Cooler	In hallway adjacent to girls' restroom Low Right	FT-72016-011160-A	< 1	FT-72016-011160-B	< 1
8 DEAL MIDDLE SCHOOL	WS- 011161	8/20/2016	Ground Floor	Cooler	In gym NG01 High Left	FT-72016-011161-A	< 1	FT-72016-011161-B	< 1
9 DEAL MIDDLE SCHOOL	WS- 011162	8/20/2016	Ground Floor	Cooler	In gym NG01 Low Left	FT-82016-011162-A	< 1	FT-82016-011162-B	< 1
10 DEAL MIDDLE SCHOOL	WS- 011163	8/20/2016	Ground Floor	Cooler	In gym NG01 High Right	FT-72016-011163-A	< 1	FT-72016-011163-B	< 1
11 DEAL MIDDLE SCHOOL	WS- 011164	8/20/2016	Ground Floor	Cooler	In gym NG01 Low Right	FT-82016-011164-A	< 1	FT-82016-011164-B	< 1
12 DEAL MIDDLE SCHOOL	WS- 011165	8/20/2016	Ground Floor	Cooler	In hallway adjacent to boys' locker room NG12 High Left	FT-72016-011165-A	< 1	FT-72016-011165-B	< 1
13 DEAL MIDDLE SCHOOL	WS- 011166	8/20/2016	Ground Floor	Cooler	In hallway adjacent to boys' locker room NG12 Low Right	FT-82016-011166-A	< 1	FT-82016-011166-B	< 1
14 DEAL MIDDLE SCHOOL	WS- 011168	8/20/2016	Ground Floor	Fountain	In classroom RG02 second clockwise from entry door	FT-72016-011168-A	< 1	FT-72016-011168-B	< 1
15 DEAL MIDDLE SCHOOL	WS- 011170	8/20/2016	Ground Floor	Fountain	In classroom RG02 first clockwise from entry door	FT-72016-011170-A	< 1	FT-72016-011170-B	< 1
16 DEAL MIDDLE SCHOOL	WS- 011172	8/20/2016	Ground Floor	Fountain	In classroom RG02 third clockwise from entry door	FT-72016-011172-A	< 1	FT-72016-011172-B	< 1
17 DEAL MIDDLE SCHOOL	WS- 011174	8/20/2016	Ground Floor	Fountain	In classroom RG02 fourth clockwise from entry door	FT-72016-011174-A	< 1	FT-72016-011174-B	< 1
18 DEAL MIDDLE SCHOOL	WS- 011175	8/20/2016	Ground Floor	Bottle Filler	In hallway across from RG03 (bottle filler) High	FT-82016-011175-A	< 1	FT-82016-011175-B	< 1
19 DEAL MIDDLE SCHOOL	WS- 011176	8/20/2016	Ground Floor	Cooler	In hallway across from RG03 Low	FT-82016-011176-A	< 1	FT-82016-011176-B	< 1
20 DEAL MIDDLE SCHOOL	WS- 011177	8/20/2016	Ground Floor	Bottle Filler	In hallway across from elevator (bottle filler) High	FT-82016-011177-A	< 1	FT-82016-011177-B	< 1
21 DEAL MIDDLE SCHOOL	WS- 011178	8/20/2016	Ground Floor	Cooler	In hallway across from elevator Low	FT-82016-011178-A	< 1	FT-82016-011178-B	< 1
22 DEAL MIDDLE SCHOOL	WS- 011179	8/20/2016	1	Bottle Filler	In hallway across from room R109 (bottle filler) High Left	FT-82016-011179-A	< 1	FT-82016-011179-B	< 1
23 DEAL MIDDLE SCHOOL	WS- 011180	8/20/2016	1	Cooler	In hallway across from room R109 Low Left	FT-72016-011180-A	< 1	FT-72016-011180-B	< 1
24 DEAL MIDDLE SCHOOL	WS- 011181	8/20/2016	1	Cooler	In hallway across from room R109 Low Right	FT-82016-011181-A	< 1	FT-82016-011181-B	< 1
25 DEAL MIDDLE SCHOOL	WS- 011182	8/20/2016	1	Fountain	In classroom R111 Left	FT-72016-011182-A	< 1	FT-72016-011182-B	< 1
26 DEAL MIDDLE SCHOOL	WS- 011183	8/20/2016	1	Fountain	In classroom R111 Right	FT-72016-011183-A	< 1	FT-72016-011183-B	< 1
27 DEAL MIDDLE SCHOOL	WS- 011186	8/20/2016	1	Bottle Filler	In hallway adjacent to restrooms (bottle filler) High	FT-82016-011186-A	< 1	FT-82016-011186-B	< 1
28 DEAL MIDDLE SCHOOL	WS- 011187	8/20/2016	1	Cooler	In hallway adjacent to restrooms	FT-72016-011187-A	< 1	FT-72016-011187-B	< 1
29 DEAL MIDDLE SCHOOL	WS- 011189	8/20/2016	1	Fountain	In classroom R102 first clockwise from entry door	FT-72016-011189-A	< 1	FT-72016-011189-B	< 1
30 DEAL MIDDLE SCHOOL	WS- 011191	8/20/2016	1	Fountain	In classroom R102 second clockwise from entry door	FT-72016-011191-A	< 1	FT-72016-011191-B	< 1
31 DEAL MIDDLE SCHOOL	WS- 011193	8/20/2016	1	Fountain	In classroom R102 third clockwise from entry door	FT-72016-011193-A	< 1	FT-72016-011193-B	< 1
32 DEAL MIDDLE SCHOOL	WS- 011195	8/20/2016	1	Fountain	In classroom R102 fourth clockwise from entry door	FT-72016-011195-A	< 1	FT-72016-011195-B	< 1
33 DEAL MIDDLE SCHOOL	WS- 011197	8/20/2016	1	Health Suite	In health suite	FT-72016-011197-A	< 1	FT-72016-011197-B	< 1
34 DEAL MIDDLE SCHOOL	WS- 011206	8/20/2016	1	Cooler	In hallway adjacent to room E100 High Left	FT-72016-011206-A	< 1	FT-72016-011206-B	< 1

35	DEAL MIDDLE SCHOOL	WS- 011207	8/20/2016	1	Cooler	In hallway adjacent to room E100	Low	Right	FT-72016-011207-A	< 1	FT-72016-011207-B	< 1
36	DEAL MIDDLE SCHOOL	WS- 011209	8/20/2016	1	Cooler	In hallway across from stairwell C2	High	Left	FT-72016-011209-A	< 1	FT-72016-011209-B	< 1
37	DEAL MIDDLE SCHOOL	WS- 011210	8/20/2016	1	Cooler	In hallway across from stairwell C2	Low	Right	FT-72016-011210-A	< 1	FT-72016-011210-B	< 1
38	DEAL MIDDLE SCHOOL	WS- 011227	8/20/2016	2	Cooler	In hallway adjacent to room W200	High	Left	FT-82016-011227-A	< 1	FT-82016-011227-B	< 1
39	DEAL MIDDLE SCHOOL	WS- 011228	8/20/2016	2	Cooler	In hallway adjacent to room W200	Low	Right	FT-72016-011228-A	< 1	FT-72016-011228-B	< 1
40	DEAL MIDDLE SCHOOL	WS- 011266	8/20/2016	2	Cooler	In hallway adjacent to room E200	High	Left	FT-82016-011266-A	< 1	FT-82016-011266-B	< 1
41	DEAL MIDDLE SCHOOL	WS- 011267	8/20/2016	2	Cooler	In hallway adjacent to room E200	Low	Right	FT-72016-011267-A	< 1	FT-72016-011267-B	< 1
42	DEAL MIDDLE SCHOOL	WS- 011276	8/20/2016	3	Cooler	In hallway adjacent to stairwell C1	High	Left	FT-72016-011276-A	< 1	FT-72016-011276-B	< 1
43	DEAL MIDDLE SCHOOL	WS- 011277	8/20/2016	3	Cooler	In hallway adjacent to stairwell C1	Low	Right	FT-82016-011277-A	< 1	FT-82016-011277-B	< 1
44	DEAL MIDDLE SCHOOL	WS- 011278	8/20/2016	3	Cooler	In hallway adjacent to room W300	High	Left	FT-72016-011278-A	< 1	FT-72016-011278-B	< 1
45	DEAL MIDDLE SCHOOL	WS- 011279	8/20/2016	3	Cooler	In hallway adjacent to room W300	Low	Right	FT-82016-011279-A	< 1	FT-82016-011279-B	< 1