



# DEAL LEAD WATER TEST RESULTS

May 16th, 2016



Building Location	Sample Collected Date	Water Source ID	Device Type	Floor	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)	Remediation	Retest Date	Retest 1st Draw	Retest 2nd Draw
1	DEAL MIDDLE SCHOOL	5/13/2016	WS- 010528	Classroom	3	In room E301 (3)	WT-042916-10545- A	2.32	WT-042916-10545- B	< 1			
2	DEAL MIDDLE SCHOOL	5/13/2016	WS- 010529	Classroom	3	In room E301 (4)	WT-042916-10546- A	1.57	WT-042916-10546- B	< 1			
3	DEAL MIDDLE SCHOOL	5/13/2016	WS- 010530	Classroom	3	In room E301 (5)	WT-042916-10547- A	< 1	WT-042916-10547- B	< 1			
4	DEAL MIDDLE SCHOOL	5/13/2016	WS- 010531	Classroom	3	In room E301 (6)	WT-042916-10548- A	4.18	WT-042916-10548- B	< 1			
5	DEAL MIDDLE SCHOOL	5/13/2016	WS- 010532	Classroom	3	In room E301 (7)	WT-042916-10549- A	18.1	WT-042916-10549- B	< 1	Filter will be installed and then retested		
6	DEAL MIDDLE SCHOOL	5/13/2016	WS- 010533	Classroom	3	In room E301 (6)	WT-042916-10550- A	1.59	WT-042916-10550- B	< 1			
7	DEAL MIDDLE SCHOOL	5/13/2016	WS- 010534	Kitchen	Ground Floor	In kitchen (2) Right	WT-042916-10551- A	< 1	WT-042916-10551- B	< 1			
8	DEAL MIDDLE SCHOOL	5/13/2016	WS- 010535	Kitchen	Ground Floor	In kitchen (3) Left	WT-042916-10552- A	< 1	WT-042916-10552- B	< 1			
9	DEAL MIDDLE SCHOOL	5/13/2016	WS- 011147	Utility	Ground Floor	In room CG07 Left	WT-042916-11164- A	1.66	WT-042916-11164- B	< 1			
10	DEAL MIDDLE SCHOOL	5/13/2016	WS- 011148	Classroom	Ground Floor	In room CG07 Right	WT-042916-11165- A	2.99	WT-042916-11165- B	< 1			
11	DEAL MIDDLE SCHOOL	5/13/2016	WS- 011149	Classroom	Ground Floor	In media room (CG02)	WT-042916-11166- A	< 1	WT-042916-11166- B	< 1			
12	DEAL MIDDLE SCHOOL	5/13/2016	WS- 011150	Utility	1	Boiler room (Main Water Source)	WT-042916-11167- A	< 1	WT-042916-11167- B	< 1			
13	DEAL MIDDLE SCHOOL	5/13/2016	WS- 011151	Classroom	Ground Floor	In room CG20	WT-042916-11168- A	< 1	WT-042916-11168- B	< 1			
14	DEAL MIDDLE SCHOOL	5/13/2016	WS- 011152	Kitchen	Ground Floor	In kitchen Left	WT-042916-11169- A	< 1	WT-042916-11169- B	< 1			
15	DEAL MIDDLE SCHOOL	5/13/2016	WS- 011153	Kitchen	Ground Floor	In kitchen Mid	WT-042916-11170- A	< 1	WT-042916-11170- B	< 1			
16	DEAL MIDDLE SCHOOL	5/13/2016	WS- 011154	Kitchen	Ground Floor	In kitchen Right	WT-042916-11171- A	< 1	WT-042916-11171- B	< 1			
17	DEAL MIDDLE SCHOOL	5/13/2016	WS- 011155	Cooler	Ground Floor	In room NG20 Left High	WT-042916-11172- A	< 1	WT-042916-11172- B	< 1			
18	DEAL MIDDLE SCHOOL	5/13/2016	WS- 011156	Cooler	Ground Floor	In room NG20 Right Low	WT-042916-11173- A	< 1	WT-042916-11173- B	< 1			
19	DEAL MIDDLE SCHOOL	5/13/2016	WS- 011157	Cooler	Ground Floor	In hallway adjacent to room NG20	WT-042916-11174- A	< 1	WT-042916-11174- B	< 1			
20	DEAL MIDDLE SCHOOL	5/13/2016	WS- 011158	Cooler	1	In hallway adjacent to room NG20 Right Low	WT-042916-11175- A	< 1	WT-042916-11175- B	< 1			
21	DEAL MIDDLE SCHOOL	5/13/2016	WS- 011159	Cooler	Ground Floor	In hallway adjacent girls bathroom Left High	WT-042916-11176- A	< 1	WT-042916-11176- B	< 1			
22	DEAL MIDDLE SCHOOL	5/13/2016	WS- 011160	Cooler	Ground Floor	In hallway adjacent to girls bathroom Right Low	WT-042916-11177- A	< 1	WT-042916-11177- B	< 1			
23	DEAL MIDDLE SCHOOL	5/13/2016	WS- 011161	Cooler	Ground Floor	In room NG01 Left High	WT-042916-11178- A	< 1	WT-042916-11178- B	< 1			
24	DEAL MIDDLE SCHOOL	5/13/2016	WS- 011162	Cooler	Ground Floor	In room NG01 Left Low	WT-042916-11179- A	< 1	WT-042916-11179- B	< 1			
25	DEAL MIDDLE SCHOOL	5/13/2016	WS- 011163	Cooler	Ground Floor	In room NG01 Right High	WT-042916-11180- A	< 1	WT-042916-11180- B	< 1			
26	DEAL MIDDLE SCHOOL	5/13/2016	WS- 011164	Cooler	Ground Floor	In room NG01 Right Low	WT-042916-11181- A	< 1	WT-042916-11181- B	< 1			
27	DEAL MIDDLE SCHOOL	5/13/2016	WS- 011165	Cooler	Ground Floor	In hallway adjacent to boy's locker room Left High	WT-042916-11182- A	< 1	WT-042916-11182- B	< 1			
28	DEAL MIDDLE SCHOOL	5/13/2016	WS- 011166	Cooler	Ground Floor	In hallway adjacent to boys locker room Right Low	WT-042916-11183- A	< 1	WT-042916-11183- B	< 1			
29	DEAL MIDDLE SCHOOL	5/13/2016	WS- 011167	Classroom	Ground Floor	In room RG02 (1)	WT-042916-11184- A	< 1	WT-042916-11184- B	< 1			
30	DEAL MIDDLE SCHOOL	5/13/2016	WS- 011168	Fountain	Ground Floor	In room RG02 (2)	WT-042916-11185- A	6.37	WT-042916-11185- B	1.38			
31	DEAL MIDDLE SCHOOL	5/13/2016	WS- 011169	Classroom	Ground Floor	In room RG02 (2)	WT-042916-11186- A	2.34	WT-042916-11186- B	< 1			
32	DEAL MIDDLE SCHOOL	5/13/2016	WS- 011170	Fountain	Ground Floor	In room RG02 (1)	WT-042916-11187- A	< 1	WT-042916-11187- B	< 1			
33	DEAL MIDDLE SCHOOL	5/13/2016	WS- 011171	Classroom	Ground Floor	In room RG02 (3)	WT-042916-11188- A	2.94	WT-042916-11188- B	< 1			
34	DEAL MIDDLE SCHOOL	5/13/2016	WS- 011172	Fountain	Ground Floor	In room RG02 (3)	WT-042916-11189- A	2.65	WT-042916-11189- B	< 1			
35	DEAL MIDDLE SCHOOL	5/13/2016	WS- 011173	Classroom	Ground Floor	In room RG02 (4)	WT-042916-11190- A	2.15	WT-042916-11190- B	< 1			
36	DEAL MIDDLE SCHOOL	5/13/2016	WS- 011174	Fountain	Ground Floor	In room RG02	WT-042916-11191- A	1.75	WT-042916-11191- B	< 1			
37	DEAL MIDDLE SCHOOL	5/13/2016	WS- 011175	Cooler	Ground Floor	In hallway across from RG03 High	WT-042916-11192- A	< 1	WT-042916-11192- B	< 1			
38	DEAL MIDDLE SCHOOL	5/13/2016	WS- 011176	Cooler	Ground Floor	In hallway across RG02 Low	WT-042916-11193- A	< 1	WT-042916-11193- B	< 1			
39	DEAL MIDDLE SCHOOL	5/13/2016	WS- 011177	Cooler	Ground Floor	In hallway across from elevator High	WT-042916-11194- A	< 1	WT-042916-11194- B	< 1			
40	DEAL MIDDLE SCHOOL	5/13/2016	WS- 011178	Cooler	Ground Floor	In hallway across from elevator Low	WT-042916-11195- A	< 1	WT-042916-11195- B	< 1			
41	DEAL MIDDLE SCHOOL	5/13/2016	WS- 011179	Cooler	1	In hallway across from R109 (filler) Left High	WT-042916-11196- A	< 1	WT-042916-11196- B	< 1			
42	DEAL MIDDLE SCHOOL	5/13/2016	WS- 011180	Cooler	1	In hallway across from room R109 Left Low	WT-042916-11197- A	< 1	WT-042916-11197- B	< 1			
43	DEAL MIDDLE SCHOOL	5/13/2016	WS- 011181	Cooler	1	In hallway across from room R109 Right Low	WT-042916-11198- A	< 1	WT-042916-11198- B	< 1			
44	DEAL MIDDLE SCHOOL	5/13/2016	WS- 011182	Fountain	1	In room R111 Left Low	WT-042916-11199- A	< 1	WT-042916-11199- B	< 1			
45	DEAL MIDDLE SCHOOL	5/13/2016	WS- 011183	Fountain	1	In room R101 Right	WT-042916-11200- A	< 1	WT-042916-11200- B	< 1			
46	DEAL MIDDLE SCHOOL	5/13/2016	WS- 011184	Classroom	1	In room R111 Left High	WT-042916-11201- A	< 1	WT-042916-11201- B	< 1			
47	DEAL MIDDLE SCHOOL	5/13/2016	WS- 011185	Classroom	1	In room R101 Right	WT-042916-11202- A	< 1	WT-042916-11202- B	< 1			
48	DEAL MIDDLE SCHOOL	5/13/2016	WS- 011186	Cooler	1	In hallway adjacent to boys bathroom High	WT-042916-11203- A	< 1	WT-042916-11203- B	< 1			
49	DEAL MIDDLE SCHOOL	5/13/2016	WS- 011187	Cooler	1	In hallway adjacent to bathroom	WT-042916-11204- A	< 1	WT-042916-11204- B	< 1			
50	DEAL MIDDLE SCHOOL	5/13/2016	WS- 011188	Classroom	1	In room (R102)	WT-042916-11205- A	< 1	WT-042916-11205- B	< 1			
51	DEAL MIDDLE SCHOOL	5/13/2016	WS- 011189	Fountain	1	In room R102 (1)	WT-042916-11206- A	< 1	WT-042916-11206- B	< 1			
52	DEAL MIDDLE SCHOOL	5/13/2016	WS- 011190	Classroom	1	In room102 (2)	WT-042916-11207- A	< 1	WT-042916-11207- B	< 1			
53	DEAL MIDDLE SCHOOL	5/14/2016	WS- 011191	Fountain	1	In room R102 (2)	WT-042916-11208- A	< 1	WT-042916-11208- B	< 1			
54	DEAL MIDDLE SCHOOL	5/13/2016	WS- 011192	Classroom	1	In room R102 (3)	WT-042916-11209- A	< 1	WT-042916-11209- B	< 1			
55	DEAL MIDDLE SCHOOL	5/13/2016	WS- 011193	Fountain	1	In room R102 (3)	WT-042916-11210- A	< 1	WT-042916-11210- B	< 1			
56	DEAL MIDDLE SCHOOL	5/13/2016	WS- 011194	Classroom	1	In room R102 (4)	WT-042916-11211- A	< 1	WT-042916-11211- B	< 1			
57	DEAL MIDDLE SCHOOL	5/13/2016	WS- 011195	Fountain	1	In room R102 (4)	WT-042916-11212- A	< 1	WT-042916-11212- B	< 1			



# DEAL LEAD WATER TEST RESULTS

May 16th, 2016



Building Location	Sample Collected Date	Water Source ID	Device Type	Floor	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)	Remediation	Retest Date	Retest 1st Draw	Retest 2nd Draw
58	DEAL MIDDLE SCHOOL	5/13/2016	WS- 011196	Classroom	1	In room C103	WT-042916-11213- A	2.42	WT-042916-11213- B	< 1			
59	DEAL MIDDLE SCHOOL	5/13/2016	WS- 011197	Health Suite	1	In health room	WT-042916-11214- A	< 1	WT-042916-11214- B	< 1			
60	DEAL MIDDLE SCHOOL	5/13/2016	WS- 011198	Classroom	1	In room E101 (7)	WT-042916-11215- A	1.11	WT-042916-11215- B	< 1			
61	DEAL MIDDLE SCHOOL	5/13/2016	WS- 011199	Classroom	1	In room E101 (1)	WT-042916-11216- A	6.18	WT-042916-11216- B	< 1			
62	DEAL MIDDLE SCHOOL	5/13/2016	WS- 011200	Classroom	1	In room E101 (2)	WT-042916-11217- A	3.72	WT-042916-11217- B	< 1			
63	DEAL MIDDLE SCHOOL	5/13/2016	WS- 011201	Classroom	1	In room E101 (3)	WT-042916-11218- A	1.03	WT-042916-11218- B	< 1			
64	DEAL MIDDLE SCHOOL	5/13/2016	WS- 011202	Classroom	1	In room E101 (4)	WT-042916-11219- A	6.18	WT-042916-11219- B	2.39			
65	DEAL MIDDLE SCHOOL	5/13/2016	WS- 011203	Classroom	1	In room E101 (5)	WT-042916-11220- A	2.19	WT-042916-11220- B	< 1			
66	DEAL MIDDLE SCHOOL	5/13/2016	WS- 011204	Classroom	1	In room E101 (6)	WT-042916-11221- A	< 1	WT-042916-11221- B	< 1			
67	DEAL MIDDLE SCHOOL	5/13/2016	WS- 011205	Classroom	1	In room E107	WT-042916-11222- A	< 1	WT-042916-11222- B	< 1			
68	DEAL MIDDLE SCHOOL	5/13/2016	WS- 011206	Cooler	1	In hallway adjacent to room E100	Left High WT-042916-11223- A	< 1	WT-042916-11223- B	< 1			
69	DEAL MIDDLE SCHOOL	5/13/2016	WS- 011207	Cooler	1	In hallway adjacent to room E100	Right Low WT-042916-11224- A	< 1	WT-042916-11224- B	< 1			
70	DEAL MIDDLE SCHOOL	5/13/2016	WS- 011208	Classroom	1	In main office room C122	WT-042916-11225- A	< 1	WT-042916-11225- B	< 1			
71	DEAL MIDDLE SCHOOL	5/13/2016	WS- 011209	Cooler	1	In hallway across from Stairs C2	Left High WT-042916-11226- A	< 1	WT-042916-11226- B	< 1			
72	DEAL MIDDLE SCHOOL	5/13/2016	WS- 011210	Cooler	1	In hallway across from stairs C2	Right Low WT-042916-11227- A	< 1	WT-042916-11227- B	< 1			
73	DEAL MIDDLE SCHOOL	5/13/2016	WS- 011211	Classroom	1	In room W107	WT-042916-11228- A	< 1	WT-042916-11228- B	2.24			
74	DEAL MIDDLE SCHOOL	5/13/2016	WS- 011212	Classroom	1	In room W101 (1)	WT-042916-11229- A	1.12	WT-042916-11229- B	< 1			
75	DEAL MIDDLE SCHOOL	5/13/2016	WS- 011213	Classroom	1	In room W101 (2)	WT-042916-11230- A	1.05	WT-042916-11230- B	< 1			
76	DEAL MIDDLE SCHOOL	5/13/2016	WS- 011214	Classroom	1	In room W101 (3)	WT-042916-11231- A	1.96	WT-042916-11231- B	< 1			
77	DEAL MIDDLE SCHOOL	5/13/2016	WS- 011215	Classroom	1	In room W101 (4)	WT-042916-11232- A	2.57	WT-042916-11232- B	< 1			
78	DEAL MIDDLE SCHOOL	5/13/2016	WS- 011216	Classroom	1	In room W101	WT-042916-11233- A	7.68	WT-042916-11233- B	< 1			
79	DEAL MIDDLE SCHOOL	5/13/2016	WS- 011217	Classroom	1	In room W101 (7)	WT-042916-11234- A	2.73	WT-042916-11234- B	< 1			
80	DEAL MIDDLE SCHOOL	5/13/2016	WS- 011218	Classroom	1	In room W101 (1)	WT-042916-11235- A	5.15	WT-042916-11235- B	< 1			
81	DEAL MIDDLE SCHOOL	5/13/2016	WS- 011219	Classroom	1	In room W106 (1)	WT-042916-11236- A	3.02	WT-042916-11236- B	< 1			
82	DEAL MIDDLE SCHOOL	5/13/2016	WS- 011220	Classroom	1	In room W106 (2)	WT-042916-11237- A	< 1	WT-042916-11237- B	< 1			
83	DEAL MIDDLE SCHOOL	5/13/2016	WS- 011221	Classroom	1	In room W106 (3)	WT-042916-11238- A	1.54	WT-042916-11238- B	< 1			
84	DEAL MIDDLE SCHOOL	5/13/2016	WS- 011222	Classroom	1	In room W106 (4)	WT-042916-11239- A	< 1	WT-042916-11239- B	< 1			
85	DEAL MIDDLE SCHOOL	5/13/2016	WS- 011223	Classroom	1	In room W106 (5)	WT-042916-11240- A	< 1	WT-042916-11240- B	< 1			
86	DEAL MIDDLE SCHOOL	5/13/2016	WS- 011224	Classroom	1	In room W106 (6)	WT-042916-11241- A	3.5	WT-042916-11241- B	4.47			
87	DEAL MIDDLE SCHOOL	5/13/2016	WS- 011225	Classroom	1	In room W106 (7)	WT-042916-11242- A	< 1	WT-042916-11242- B	< 1			
88	DEAL MIDDLE SCHOOL	5/13/2016	WS- 011226	Classroom	1	In main office room C121	WT-042916-11243- A	< 1	WT-042916-11243- B	< 1			
89	DEAL MIDDLE SCHOOL	5/13/2016	WS- 011227	Cooler	2	In hallway adjacent to room W200	Left High WT-042916-11244- A	< 1	WT-042916-11244- B	< 1			
90	DEAL MIDDLE SCHOOL	5/13/2016	WS- 011228	Cooler	2	In hallway adjacent to room W200	Right Low WT-042916-11245- A	< 1	WT-042916-11245- B	< 1			
91	DEAL MIDDLE SCHOOL	5/13/2016	WS- 011229	Classroom	2	In room W200 (6)	WT-042916-11246- A	< 1	WT-042916-11246- B	< 1			
92	DEAL MIDDLE SCHOOL	5/13/2016	WS- 011230	Classroom	2	In room W200 (5)	WT-042916-11247- A	< 1	WT-042916-11247- B	< 1			
93	DEAL MIDDLE SCHOOL	5/13/2016	WS- 011231	Classroom	2	In room W200 (4)	WT-042916-11248- A	< 1	WT-042916-11248- B	< 1			
94	DEAL MIDDLE SCHOOL	5/13/2016	WS- 011232	Classroom	2	In room W200 (3)	WT-042916-11249- A	< 1	WT-042916-11249- B	< 1			
95	DEAL MIDDLE SCHOOL	5/13/2016	WS- 011233	Classroom	2	In room W200 (2)	WT-042916-11250- A	< 1	WT-042916-11250- B	< 1			
96	DEAL MIDDLE SCHOOL	5/13/2016	WS- 011234	Classroom	2	In room W200 (1)	WT-042916-11251- A	1.05	WT-042916-11251- B	< 1			
97	DEAL MIDDLE SCHOOL	5/13/2016	WS- 011235	Classroom	2	In room W200 (7)	WT-042916-11252- A	< 1	WT-042916-11252- B	< 1			
98	DEAL MIDDLE SCHOOL	5/13/2016	WS- 011236	Classroom	2	In room W201 (1)	WT-042916-11253- A	< 1	WT-042916-11253- B	< 1			
99	DEAL MIDDLE SCHOOL	5/13/2016	WS- 011237	Classroom	2	In room W201 (2)	WT-042916-11254- A	< 1	WT-042916-11254- B	< 1			
100	DEAL MIDDLE SCHOOL	5/13/2016	WS- 011238	Classroom	2	In room W201 (3)	WT-042916-11255- A	1.12	WT-042916-11255- B	< 1			
101	DEAL MIDDLE SCHOOL	5/13/2016	WS- 011239	Classroom	2	In room W201 (4)	WT-042916-11256- A	1.6	WT-042916-11256- B	< 1			
102	DEAL MIDDLE SCHOOL	5/13/2016	WS- 011240	Classroom	2	In room W201 (5)	WT-042916-11257- A	1.26	WT-042916-11257- B	< 1			
103	DEAL MIDDLE SCHOOL	5/13/2016	WS- 011241	Classroom	2	In room W201 (6)	WT-042916-11258- A	< 1	WT-042916-11258- B	< 1			
104	DEAL MIDDLE SCHOOL	5/13/2016	WS- 011242	Classroom	2	In room W201 (7)	WT-042916-11259- A	3.44	WT-042916-11259- B	< 1			
105	DEAL MIDDLE SCHOOL	5/13/2016	WS- 011243	Classroom	2	In room W201 (8)	WT-042916-11260- A	< 1	WT-042916-11260- B	< 1			
106	DEAL MIDDLE SCHOOL	5/13/2016	WS- 011244	Classroom	2	In room C217	WT-042916-11261- A	2.13	WT-042916-11261- B	1.81			
107	DEAL MIDDLE SCHOOL	5/13/2016	WS- 011245	Classroom	2	In room C224 (1)	Left WT-042916-11262- A	< 1	WT-042916-11262- B	< 1			
108	DEAL MIDDLE SCHOOL	5/13/2016	WS- 011246	Classroom	2	In room C224 (1)	Mid WT-042916-11263- A	< 1	WT-042916-11263- B	< 1			
109	DEAL MIDDLE SCHOOL	5/13/2016	WS- 011247	Classroom	2	In room C224 (1)	Right WT-042916-11264- A	< 1	WT-042916-11264- B	< 1			
110	DEAL MIDDLE SCHOOL	5/13/2016	WS- 011248	Classroom	2	In room C224 (2)	Left WT-042916-11265- A	< 1	WT-042916-11265- B	< 1			
111	DEAL MIDDLE SCHOOL	5/13/2016	WS- 011249	Classroom	2	In room C224 (2)	Mid WT-042916-11266- A	< 1	WT-042916-11266- B	< 1			
112	DEAL MIDDLE SCHOOL	5/13/2016	WS- 011250	Classroom	2	In room C224 (3)	Right WT-042916-11267- A	< 1	WT-042916-11267- B	< 1			
113	DEAL MIDDLE SCHOOL	5/13/2016	WS- 011251	Classroom	2	In classroom room 225 (3)	Left WT-042916-11268- A	< 1	WT-042916-11268- B	< 1			
114	DEAL MIDDLE SCHOOL	5/13/2016	WS- 011252	Classroom	2	In classroom C224 (3)	Right WT-042916-11269- A	6.3	WT-042916-11269- B	< 1			
115	DEAL MIDDLE SCHOOL	5/13/2016	WS- 011253	Classroom	2	In room C224 (3)	WT-042916-11270- A	< 1	WT-042916-11270- B	< 1			
116	DEAL MIDDLE SCHOOL	5/13/2016	WS- 011254	Classroom	2	In classroom C205 "1"	Left WT-042916-11271- A	1.82	WT-042916-11271- B	< 1			
117	DEAL MIDDLE SCHOOL	5/13/2016	WS- 011255	Classroom	2	In classroom C205 "1"	Mid WT-042916-11272- A	< 1	WT-042916-11272- B	< 1			
118	DEAL MIDDLE SCHOOL	5/13/2016	WS- 011256	Classroom	2	In classroom C205 "1"	Right WT-042916-11273- A	< 1	WT-042916-11273- B	< 1			
119	DEAL MIDDLE SCHOOL	5/13/2016	WS- 011257	Classroom	2	In room C205 (2)	Left WT-042916-11274- A	< 1	WT-042916-11274- B	< 1			



# DEAL LEAD WATER TEST RESULTS

May 16th, 2016



Building Location	Sample Collected Date	Water Source ID	Device Type	Floor	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)	Remediation	Retest Date	Retest 1st Draw	Retest 2nd Draw
120	DEAL MIDDLE SCHOOL	5/13/2016	WS- 011258	Classroom	2	In room C205 (2) Right	WT-042916-11275- A	< 1	WT-042916-11275- B	< 1			
121	DEAL MIDDLE SCHOOL	5/13/2016	WS- 011259	Classroom	2	In room C205 (2) Right	WT-042916-11276- A	< 1	WT-042916-11276- B	< 1			
122	DEAL MIDDLE SCHOOL	5/13/2016	WS- 011260	Classroom	2	In room C205 (3) Left	WT-042916-11277- A	< 1	WT-042916-11277- B	< 1			
123	DEAL MIDDLE SCHOOL	5/13/2016	WS- 011261	Classroom	2	In room C205 (3) Mid	WT-042916-11278- A	< 1	WT-042916-11278- B	< 1			
124	DEAL MIDDLE SCHOOL	5/13/2016	WS- 011262	Classroom	2	In room C205 (3) Right	WT-042916-11279- A	< 1	WT-042916-11279- B	< 1			
125	DEAL MIDDLE SCHOOL	5/13/2016	WS- 011263	Classroom	2	In office room C203	WT-042916-11280- A	< 1	WT-042916-11280- B	< 1			
126	DEAL MIDDLE SCHOOL	5/13/2016	WS- 011264	Classroom	2	In room C216	WT-042916-11281- A	< 1	WT-042916-11281- B	< 1			
127	DEAL MIDDLE SCHOOL	5/13/2016	WS- 011265	Classroom	2	In room C213	WT-042916-11282- A	< 1	WT-042916-11282- B	< 1			
128	DEAL MIDDLE SCHOOL	5/13/2016	WS- 011266	Cooler	2	In hallway adjacent to classroom E200 Left High	WT-042916-11283- A	< 1	WT-042916-11283- B	< 1			
129	DEAL MIDDLE SCHOOL	5/13/2016	WS- 011267	Cooler	2	In hallway adjacent to classroom E200 Right Low	WT-042916-11284- A	< 1	WT-042916-11284- B	1.08			
130	DEAL MIDDLE SCHOOL	5/13/2016	WS- 011268	Classroom	2	In room E201 (6)	WT-042916-11285- A	< 1	WT-042916-11285- B	< 1			
131	DEAL MIDDLE SCHOOL	5/13/2016	WS- 011269	Classroom	2	In room E201 (5)	WT-042916-11286- A	1.6	WT-042916-11286- B	< 1			
132	DEAL MIDDLE SCHOOL	5/13/2016	WS- 011270	Classroom	2	In room E201(4)	WT-042916-11287- A	1.33	WT-042916-11287- B	< 1			
133	DEAL MIDDLE SCHOOL	5/13/2016	WS- 011271	Classroom	2	In room E201 (3)	WT-042916-11288- A	1.45	WT-042916-11288- B	< 1			
134	DEAL MIDDLE SCHOOL	5/13/2016	WS- 011272	Classroom	2	In room E201 (2)	WT-042916-11289- A	1.8	WT-042916-11289- B	1.27			
135	DEAL MIDDLE SCHOOL	5/13/2016	WS- 011273	Classroom	2	In room E201 (1)	WT-042916-11290- A	1.2	WT-042916-11290- B	< 1			
136	DEAL MIDDLE SCHOOL	5/13/2016	WS- 011274	Classroom	2	In room E201 (8)	WT-042916-11291- A	5.3	WT-042916-11291- B	< 1			
137	DEAL MIDDLE SCHOOL	5/13/2016	WS- 011275	Classroom	2	In room E201 (7)	WT-042916-11292- A	< 1	WT-042916-11292- B	< 1			
138	DEAL MIDDLE SCHOOL	5/13/2016	WS- 011276	Cooler	3	In hallway adjacent to Stair C1 Left High	WT-042916-11293- A	< 1	WT-042916-11293- B	< 1			
139	DEAL MIDDLE SCHOOL	5/13/2016	WS- 011277	Cooler	3	In hallway adjacent to stair C1 Right Low	WT-042916-11294- A	< 1	WT-042916-11294- B	< 1			
140	DEAL MIDDLE SCHOOL	5/13/2016	WS- 011278	Cooler	3	In hallway adjacent to W300 Left High	WT-042916-11295- A	< 1	WT-042916-11295- B	< 1			
141	DEAL MIDDLE SCHOOL	5/13/2016	WS- 011279	Cooler	3	In hallway adjacent to room W300 Right Low	WT-042916-11296- A	< 1	WT-042916-11296- B	< 1			
142	DEAL MIDDLE SCHOOL	5/13/2016	WS- 011280	Classroom	3	In room W300 (1)	WT-042916-11297- A	11.8	WT-042916-11297- B	< 1			
143	DEAL MIDDLE SCHOOL	5/13/2016	WS- 011281	Classroom	3	In W300 (2)	WT-042916-11298- A	3.17	WT-042916-11298- B	< 1			
144	DEAL MIDDLE SCHOOL	5/13/2016	WS- 011282	Classroom	3	In room W300 (3)	WT-042916-11299- A	1.5	WT-042916-11299- B	< 1			
145	DEAL MIDDLE SCHOOL	5/13/2016	WS- 011283	Classroom	3	In room W300 (4)	WT-042916-11300- A	2.76	WT-042916-11300- B	< 1			
146	DEAL MIDDLE SCHOOL	5/13/2016	WS- 011284	Classroom	3	In classroom W300 "5"	WT-042916-11301- A	1.33	WT-042916-11301- B	< 1			
147	DEAL MIDDLE SCHOOL	5/13/2016	WS- 011285	Classroom	3	In room W300 (6)	WT-042916-11302- A	< 1	WT-042916-11302- B	< 1			
148	DEAL MIDDLE SCHOOL	5/13/2016	WS- 011286	Classroom	3	In room W300 (8)	WT-042916-11303- A	< 1	WT-042916-11303- B	< 1			
149	DEAL MIDDLE SCHOOL	5/13/2016	WS- 011287	Classroom	3	In room W301 (1)	WT-042916-11304- A	< 1	WT-042916-11304- B	< 1			
150	DEAL MIDDLE SCHOOL	5/13/2016	WS- 011288	Classroom	3	In room W301 (2)	WT-042916-11305- A	1.31	WT-042916-11305- B	< 1			
151	DEAL MIDDLE SCHOOL	5/13/2016	WS- 011289	Classroom	3	In classroom W301 "3"	WT-042916-11306- A	1.31	WT-042916-11306- B	< 1			
152	DEAL MIDDLE SCHOOL	5/13/2016	WS- 011290	Classroom	3	In room W301 (4)	WT-042916-11307- A	< 1	WT-042916-11307- B	< 1			
153	DEAL MIDDLE SCHOOL	5/13/2016	WS- 011291	Classroom	3	In room W301 (5)	WT-042916-11308- A	< 1	WT-042916-11308- B	< 1			
154	DEAL MIDDLE SCHOOL	5/13/2016	WS- 011292	Classroom	3	In room W301 (6)	WT-042916-11309- A	4.08	WT-042916-11309- B	< 1			
155	DEAL MIDDLE SCHOOL	5/13/2016	WS- 011293	Classroom	3	In room W301 (8)	WT-042916-11310- A	14.8	WT-042916-11310- B	< 1			
156	DEAL MIDDLE SCHOOL	5/13/2016	WS- 011294	Classroom	3	In room W301 (7)	WT-042916-11311- A	2.89	WT-042916-11311- B	1.17			
157	DEAL MIDDLE SCHOOL	5/13/2016	WS- 011295	Classroom	3	In room E301 (1)	WT-042916-11312- A	2.83	WT-042916-11312- B	< 1			
158	DEAL MIDDLE SCHOOL	5/13/2016	WS- 011296	Bathroom	3	In room E301 (2)	WT-042916-11313- A	7.58	WT-042916-11313- B	2.45			

Footnotes:

- A - First draw sample is collected after the plumbing system has not been used for at least 6 hours.
- B - Second draw sample is collected after a 60 second flush at that device after the first draw.