



Deal Middle School Lead in Water Test Results

FY25 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS-005837	2/26/2024	2/26/2025	Ground Floor	Bottle Filler	In hallway adjacent to room NG20	WF-02262024-005837	8/19/2024	FT-FY25-08012024-005837-A	<1	FT-FY25-08012024-005837-B	<1	
WS-005845	7/24/2024	7/24/2025	1	Bottle Filler	In hallway across from elevator	WF-07242024-005845	8/19/2024	FT-FY25-08012024-005845-A	<1	FT-FY25-08012024-005845-B	<1	
WS-005846	7/24/2024	7/24/2025	1	Cooler	In hallway across from elevator	High Left	WF-07242024-005846	8/19/2024	FT-FY25-08012024-005846-A	<1	FT-FY25-08012024-005846-B	<1
WS-005847	7/24/2024	7/24/2025	1	Cooler	In hallway across from elevator	Low Right	WF-07242024-005847	8/19/2024	FT-FY25-08012024-005847-A	<1	FT-FY25-08012024-005847-B	<1
WS-005848	7/24/2024	7/24/2025	2	Bottle Filler	In hallway across from elevator	WF-07242024-005848	8/19/2024	FT-FY25-08012024-005848-A	<1	FT-FY25-08012024-005848-B	<1	
WS-005849	7/24/2024	7/24/2025	2	Cooler	In hallway across from elevator	High Left	WF-07242024-005849	8/19/2024	FT-FY25-08012024-005849-A	<1	FT-FY25-08012024-005849-B	<1
WS-005850	7/24/2024	7/24/2025	2	Cooler	In hallway across from elevator	Low Right	WF-07242024-005850	8/19/2024	FT-FY25-08012024-005850-A	<1	FT-FY25-08012024-005850-B	<1
WS-005851	7/24/2024	7/24/2025	3	Bottle Filler	In hallway across from elevator	WF-07242024-005851	8/19/2024	FT-FY25-08012024-005851-A	<1	FT-FY25-08012024-005851-B	<1	
WS-005852	7/24/2024	7/24/2025	3	Cooler	In hallway across from elevator	High Left	WF-07242024-005852	8/19/2024	FT-FY25-08012024-005852-A	<1	FT-FY25-08012024-005852-B	<1
WS-005853	7/24/2024	7/24/2025	3	Cooler	In hallway across from elevator	Low Right	WF-07242024-005853	8/19/2024	FT-FY25-08012024-005853-A	<1	FT-FY25-08012024-005853-B	<1
WS-011157	2/26/2024	2/26/2025	Ground Floor	Cooler	In hallway adjacent to room NG20	High Left	WF-02262024-011157	8/19/2024	FT-FY25-08012024-011157-A	<1	FT-FY25-08012024-011157-B	<1
WS-011158	2/26/2024	2/26/2025	Ground Floor	Cooler	In hallway adjacent to room NG20	Low Right	WF-02262024-011158	8/19/2024	FT-FY25-08012024-011158-A	<1	FT-FY25-08012024-011158-B	<1
WS-011161	2/26/2024	2/26/2025	Ground Floor	Cooler	In gym NG01	WF-02262024-011161	8/19/2024	FT-FY25-08012024-011161-A	<1	FT-FY25-08012024-011161-B	<1	
WS-011165	2/26/2024	2/26/2025	Ground Floor	Cooler	In hallway adjacent to boys' locker room NG12	High Left	WF-02262024-011165	8/19/2024	FT-FY25-08012024-011165-A	<1	FT-FY25-08012024-011165-B	<1
WS-011170	2/26/2024	2/26/2025	Ground Floor	Combo Fountain	In classroom RG02 first clockwise from entry door	WF-02262024-011170	8/19/2024	FT-FY25-08012024-011170-A	<1	FT-FY25-08012024-011170-B	<1	
WS-011174	2/26/2024	2/26/2025	Ground Floor	Combo Fountain	In classroom RG02 fourth clockwise from entry door	WF-02262024-011174	8/19/2024	FT-FY25-08012024-011174-A	<1	FT-FY25-08012024-011174-B	<1	
WS-011176	2/26/2024	2/26/2025	Ground Floor	Cooler	In hallway across from RG03	WF-02262024-011176	8/19/2024	FT-FY25-08012024-011176-A	<1	FT-FY25-08012024-011176-B	<1	
WS-011178	2/26/2024	2/26/2025	Ground Floor	Cooler	In hallway across from elevator	WF-02262024-011178	8/19/2024	FT-FY25-08012024-011178-A	<1	FT-FY25-08012024-011178-B	<1	
WS-011181	2/26/2024	2/26/2025	1	Cooler	In hallway across from room R109	Low Right	WF-02262024-011181	8/19/2024	FT-FY25-08012024-011181-A	<1	FT-FY25-08012024-011181-B	<1
WS-011182	2/26/2024	2/26/2025	1	Combo Fountain	In classroom R111	Left	WF-02262024-011182	8/19/2024	FT-FY25-08012024-011182-A	<1	FT-FY25-08012024-011182-B	<1
WS-011186	2/26/2024	2/26/2025	1	Bottle Filler	In hallway adjacent to restrooms (bottle filler)	WF-02262024-011186	8/19/2024	FT-FY25-08012024-011186-A	<1	FT-FY25-08012024-011186-B	<1	
WS-011187	2/26/2024	2/26/2025	1	Cooler	In hallway adjacent to restrooms	WF-02262024-011187	8/19/2024	FT-FY25-08012024-011187-A	<1	FT-FY25-08012024-011187-B	<1	
WS-011189	2/26/2024	2/26/2025	1	Combo Fountain	In classroom R102 first clockwise from entry door	WF-02262024-011189	8/19/2024	FT-FY25-08012024-011189-A	<1	FT-FY25-08012024-011189-B	<1	
WS-011191	2/26/2024	2/26/2025	1	Combo Fountain	In classroom R102 second clockwise from entry door	WF-02262024-011191	8/19/2024	FT-FY25-08012024-011191-A	<1	FT-FY25-08012024-011191-B	<1	
WS-011195	2/26/2024	2/26/2025	1	Combo Fountain	In classroom R102 fourth clockwise from entry door	WF-02262024-011195	8/19/2024	FT-FY25-08012024-011195-A	<1	FT-FY25-08012024-011195-B	<1	
WS-011206	2/26/2024	2/26/2025	1	Cooler	In hallway adjacent to room E100	High Left	WF-02262024-011206	8/19/2024	FT-FY25-08012024-011206-A	<1	FT-FY25-08012024-011206-B	<1
WS-011207	2/26/2024	2/26/2025	1	Cooler	In hallway adjacent to room E100	Low Right	WF-02262024-011207	8/19/2024	FT-FY25-08012024-011207-A	<1	FT-FY25-08012024-011207-B	<1
WS-011210	2/26/2024	2/26/2025	1	Cooler	In hallway across from stairwell C2	Low Right	WF-02262024-011210	8/19/2024	FT-FY25-08012024-011210-A	<1	FT-FY25-08012024-011210-B	<1
WS-011227	2/26/2024	2/26/2025	2	Cooler	In hallway adjacent to room W200	High Left	WF-02262024-011227	8/19/2024	FT-FY25-08012024-011227-A	<1	FT-FY25-08012024-011227-B	<1
WS-011228	2/26/2024	2/26/2025	2	Cooler	In hallway adjacent to room W200	Low Right	WF-02262024-011228	8/19/2024	FT-FY25-08012024-011228-A	<1	FT-FY25-08012024-011228-B	<1
WS-011264	2/26/2024	2/26/2025	2	Break Room	In staff lounge C216	WF-02262024-011264	8/19/2024	FT-FY25-08012024-011264-A	<1	FT-FY25-08012024-011264-B	<1	
WS-011266	2/26/2024	2/26/2025	2	Cooler	In hallway adjacent to room E200	High Left	WF-02262024-011266	8/19/2024	FT-FY25-08012024-011266-A	<1	FT-FY25-08012024-011266-B	<1
WS-011267	2/26/2024	2/26/2025	2	Cooler	In hallway adjacent to room E200	Low Right	WF-02262024-011267	8/19/2024	FT-FY25-08012024-011267-A	<1	FT-FY25-08012024-011267-B	<1

WS- 011276	2/26/2024	2/26/2025	3	Cooler	In hallway adjacent to stairwell C1	High Left	WF-02262024-011276	8/19/2024	FT-FY25-08012024-011276-A	<1	FT-FY25-08012024-011276-B	<1
WS- 011277	2/26/2024	2/26/2025	3	Cooler	In hallway adjacent to stairwell C1	Low Right	WF-02262024-011277	8/19/2024	FT-FY25-08012024-011277-A	<1	FT-FY25-08012024-011277-B	<1
WS- 011278	2/26/2024	2/26/2025	3	Cooler	In hallway adjacent to room W300	High Left	WF-02262024-011278	8/19/2024	FT-FY25-08012024-011278-A	<1	FT-FY25-08012024-011278-B	<1
WS- 011279	2/26/2024	2/26/2025	3	Cooler	In hallway adjacent to room W300	Low Right	WF-02262024-011279	8/19/2024	FT-FY25-08012024-011279-A	<1	FT-FY25-08012024-011279-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS- 010535	11/20/2023	11/20/2024	Ground Floor	Food Prep Sink	In kitchen on west wall	Left	WF-11202023-010535	8/19/2024	FT-FY25-08012024-010535-A	<1	FT-FY25-08012024-010535-B	<1
WS- 011153	11/20/2023	11/20/2024	Ground Floor	Food Prep Sink	In kitchen on north wall	Mid	WF-11202023-011153	8/19/2024	FT-FY25-08012024-011153-A	<1	FT-FY25-08012024-011153-B	<1
WS- 011154	11/20/2023	11/20/2024	Ground Floor	Food Prep Sink	In kitchen on north wall	Right	WF-11202023-011154	8/19/2024	FT-FY25-08012024-011154-A	<1	FT-FY25-08012024-011154-B	<1