



Deal Middle School Lead in Water Test Results

FY22 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 011157	3/23/2021	3/23/2022	Ground Floor	Cooler	In hallway adjacent to room NG20 High Left	WF-03232021-011157	2/25/2022	FT-FY22-02032022-011157-A	<1	FT-FY22-02032022-011157-B	<1
WS- 011158	3/23/2021	3/23/2022	Ground Floor	Cooler	In hallway adjacent to room NG20 Low Right	WF-03232021-011158	2/25/2022	FT-FY22-02032022-011158-A	<1	FT-FY22-02032022-011158-B	<1
WS- 011161	3/23/2021	3/23/2022	Ground Floor	Cooler	In gym NG01	WF-03232021-011161	2/25/2022	FT-FY22-02032022-011161-A	<1	FT-FY22-02032022-011161-B	<1
WS- 011168	3/23/2021	3/23/2022	Ground Floor	Combo Fountain	In classroom RG02 second clockwise from entry door	WF-03232021-011168	2/25/2022	FT-FY22-02032022-011168-A	<1	FT-FY22-02032022-011168-B	<1
WS- 011170	3/23/2021	3/23/2022	Ground Floor	Combo Fountain	In classroom RG02 first clockwise from entry door	WF-03232021-011170	2/25/2022	FT-FY22-02032022-011170-A	<1	FT-FY22-02032022-011170-B	<1
WS- 011172	3/23/2021	3/23/2022	Ground Floor	Combo Fountain	In classroom RG02 third clockwise from entry door	WF-03232021-011172	2/25/2022	FT-FY22-02032022-011172-A	<1	FT-FY22-02032022-011172-B	<1
WS- 011174	3/23/2021	3/23/2022	Ground Floor	Combo Fountain	In classroom RG02 fourth clockwise from entry door	WF-03232021-011174	2/25/2022	FT-FY22-02032022-011174-A	<1	FT-FY22-02032022-011174-B	<1
WS- 011175	3/23/2021	3/23/2022	Ground Floor	Bottle Filler	In hallway across from RG03 (bottle filler)	WF-03232021-011175	2/25/2022	FT-FY22-02032022-011175-A	<1	FT-FY22-02032022-011175-B	<1
WS- 011176	3/23/2021	3/23/2022	Ground Floor	Cooler	In hallway across from RG03	WF-03232021-011176	2/25/2022	FT-FY22-02032022-011176-A	<1	FT-FY22-02032022-011176-B	<1
WS- 011177	3/23/2021	3/23/2022	Ground Floor	Bottle Filler	In hallway across from elevator (bottle filler)	WF-03232021-011177	2/25/2022	FT-FY22-02032022-011177-A	<1	FT-FY22-02032022-011177-B	<1
WS- 011178	3/23/2021	3/23/2022	Ground Floor	Cooler	In hallway across from elevator	WF-03232021-011178	2/25/2022	FT-FY22-02032022-011178-A	<1	FT-FY22-02032022-011178-B	<1
WS- 011179	3/23/2021	3/23/2022	1	Bottle Filler	In hallway across from room R109 (bottle filler)	WF-03232021-011179	2/25/2022	FT-FY22-02032022-011179-A	<1	FT-FY22-02032022-011179-B	<1
WS- 011180	3/23/2021	3/23/2022	1	Cooler	In hallway across from room R109 Low Left	WF-03232021-011180	2/25/2022	FT-FY22-02032022-011180-A	<1	FT-FY22-02032022-011180-B	<1
WS- 011181	3/23/2021	3/23/2022	1	Cooler	In hallway across from room R109 Low Right	WF-03232021-011181	2/25/2022	FT-FY22-02032022-011181-A	<1	FT-FY22-02032022-011181-B	<1
WS- 011183	3/23/2021	3/23/2022	1	Combo Fountain	In classroom R111 Right	WF-03232021-011183	2/25/2022	FT-FY22-02032022-011183-A	<1	FT-FY22-02032022-011183-B	<1
WS- 011186	3/23/2021	3/23/2022	1	Bottle Filler	In hallway adjacent to restrooms (bottle filler)	WF-03232021-011186	2/25/2022	FT-FY22-02032022-011186-A	<1	FT-FY22-02032022-011186-B	<1
WS- 011187	3/23/2021	3/23/2022	1	Cooler	In hallway adjacent to restrooms	WF-03232021-011187	2/25/2022	FT-FY22-02032022-011187-A	<1	FT-FY22-02032022-011187-B	<1
WS- 011189	3/23/2021	3/23/2022	1	Combo Fountain	In classroom R102 first clockwise from entry door	WF-03232021-011189	2/25/2022	FT-FY22-02032022-011189-A	<1	FT-FY22-02032022-011189-B	<1
WS- 011191	3/23/2021	3/23/2022	1	Combo Fountain	In classroom R102 second clockwise from entry door	WF-03232021-011191	2/25/2022	FT-FY22-02032022-011191-A	<1	FT-FY22-02032022-011191-B	<1
WS- 011193	3/23/2021	3/23/2022	1	Combo Fountain	In classroom R102 third clockwise from entry door	WF-03232021-011193	2/25/2022	FT-FY22-02032022-011193-A	<1	FT-FY22-02032022-011193-B	<1
WS- 011195	3/23/2021	3/23/2022	1	Combo Fountain	In classroom R102 fourth clockwise from entry door	WF-03232021-011195	2/25/2022	FT-FY22-02032022-011195-A	<1	FT-FY22-02032022-011195-B	<1
WS- 011197	3/23/2021	3/23/2022	1	Health Suite	In health suite	WF-03232021-011197	2/25/2022	FT-FY22-02032022-011197-A	<1	FT-FY22-02032022-011197-B	<1
WS- 011206	3/23/2021	3/23/2022	1	Cooler	In hallway adjacent to room E100 High Left	WF-03232021-011206	2/25/2022	FT-FY22-02032022-011206-A	<1	FT-FY22-02032022-011206-B	<1
WS- 011207	3/23/2021	3/23/2022	1	Cooler	In hallway adjacent to room E100 Low Right	WF-03232021-011207	2/25/2022	FT-FY22-02032022-011207-A	<1	FT-FY22-02032022-011207-B	<1
WS- 011209	3/23/2021	3/23/2022	1	Cooler	In hallway across from stairwell C2 High Left	WF-03232021-011209	2/25/2022	FT-FY22-02032022-011209-A	<1	FT-FY22-02032022-011209-B	<1
WS- 011210	3/23/2021	3/23/2022	1	Cooler	In hallway across from stairwell C2 Low Right	WF-03232021-011210	2/25/2022	FT-FY22-02032022-011210-A	<1	FT-FY22-02032022-011210-B	<1
WS- 011264	3/23/2021	3/23/2022	2	Break Room	In staff lounge C216	WF-03232021-011264	2/25/2022	FT-FY22-02032022-011264-A	<1	FT-FY22-02032022-011264-B	<1
WS- 011266	3/23/2021	3/23/2022	2	Cooler	In hallway adjacent to room E200 High Left	WF-03232021-011266	2/25/2022	FT-FY22-02032022-011266-A	<1	FT-FY22-02032022-011266-B	<1
WS- 011267	3/23/2021	3/23/2022	2	Cooler	In hallway adjacent to room E200 Low Right	WF-03232021-011267	2/25/2022	FT-FY22-02032022-011267-A	<1	FT-FY22-02032022-011267-B	<1
WS- 011276	3/23/2021	3/23/2022	3	Cooler	In hallway adjacent to stairwell C1 High Left	WF-03232021-011276	2/25/2022	FT-FY22-02032022-011276-A	<1	FT-FY22-02032022-011276-B	<1
WS- 011277	3/23/2021	3/23/2022	3	Cooler	In hallway adjacent to stairwell C1 Low Right	WF-03232021-011277	2/25/2022	FT-FY22-02032022-011277-A	<1	FT-FY22-02032022-011277-B	<1
WS- 011278	3/23/2021	3/23/2022	3	Cooler	In hallway adjacent to room W300 High Left	WF-03232021-011278	2/25/2022	FT-FY22-02032022-011278-A	<1	FT-FY22-02032022-011278-B	<1
WS- 011279	3/23/2021	3/23/2022	3	Cooler	In hallway adjacent to room W300 Low Right	WF-03232021-011279	2/25/2022	FT-FY22-02032022-011279-A	<1	FT-FY22-02032022-011279-B	<1
WS- 011496	3/23/2021	3/23/2022	Ground Floor	Cooler	In annex adjacent to COT 8 High Left	WF-03232021-011496	2/25/2022	FT-FY22-02032022-011496-A	<1	FT-FY22-02032022-011496-B	<1
WS- 011497	3/23/2021	3/23/2022	Ground Floor	Cooler	In annex adjacent to COT 8 Low Right	WF-03232021-011497	2/25/2022	FT-FY22-02032022-011497-A	<1	FT-FY22-02032022-011497-B	<1
WS- 011498	3/23/2021	3/23/2022	Ground Floor	Cooler	In annex across from COT 9 High Left	WF-03232021-011498	2/25/2022	FT-FY22-02032022-011498-A	<1	FT-FY22-02032022-011498-B	<1

WS- 011499	3/23/2021	3/23/2022	Ground Floor	Cooler	In annex across from COT 9	Low Right	WF-03232021-011499	2/25/2022	FT-FY22-02032022-011499-A	<1	FT-FY22-02032022-011499-B	<1
------------	-----------	-----------	--------------	--------	----------------------------	-----------	--------------------	-----------	---------------------------	----	---------------------------	----

Food Prep Sink

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location		Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 010535	4/21/2021	4/21/2022	Ground Floor	Food Prep Sink	In kitchen on west wall	Left	WF-04212021-010535	2/25/2022	FT-FY22-02032022-010535-A	<1	FT-FY22-02032022-010535-B	<1
WS- 011153	1/18/2022	1/18/2023	Ground Floor	Food Prep Sink	In kitchen on north wall	Mid	WF-01182022-011153	2/25/2022	FT-FY22-02032022-011153-A	<1	FT-FY22-02032022-011153-B	<1
WS- 011154	1/18/2022	1/18/2023	Ground Floor	Food Prep Sink	In kitchen on north wall	Right	WF-01182022-011154	2/25/2022	FT-FY22-02032022-011154-A	<1	FT-FY22-02032022-011154-B	<1