



Deal Middle School Lead in Water Test Results

FY23 Filter Test

Less than 5ppb - Devices requiring no remediation													
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location			Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-011155	3/14/2022	3/14/2023	Ground Floor	Cooler	In cafeteria room NG20	High	Left	WF-03142022-011155	2/1/2023	FT-FY23-01102023-011155-A	<1	FT-FY23-01102023-011155-B	<1
WS-011156	3/14/2022	3/14/2023	Ground Floor	Cooler	In cafeteria room NG20	Low	Right	WF-03142022-011156	2/1/2023	FT-FY23-01102023-011156-A	<1	FT-FY23-01102023-011156-B	<1
WS-011157	3/14/2022	3/14/2023	Ground Floor	Cooler	In hallway adjacent to room NG20	High	Left	WF-03142022-011157	2/1/2023	FT-FY23-01102023-011157-A	<1	FT-FY23-01102023-011157-B	<1
WS-011158	3/14/2022	3/14/2023	Ground Floor	Cooler	In hallway adjacent to room NG20	Low	Right	WF-03142022-011158	2/1/2023	FT-FY23-01102023-011158-A	<1	FT-FY23-01102023-011158-B	<1
WS-011161	3/14/2022	3/14/2023	Ground Floor	Cooler	In gym NG01			WF-03142022-011161	2/1/2023	FT-FY23-01102023-011161-A	<1	FT-FY23-01102023-011161-B	<1
WS-011170	3/14/2022	3/14/2023	Ground Floor	Combo Fountain	In classroom RG02 first clockwise from entry door			WF-03142022-011170	2/1/2023	FT-FY23-01102023-011170-A	<1	FT-FY23-01102023-011170-B	<1
WS-011172	3/14/2022	3/14/2023	Ground Floor	Combo Fountain	In classroom RG02 third clockwise from entry door			WF-03142022-011172	2/1/2023	FT-FY23-01102023-011172-A	<1	FT-FY23-01102023-011172-B	<1
WS-011174	3/14/2022	3/14/2023	Ground Floor	Combo Fountain	In classroom RG02 fourth clockwise from entry door			WF-03142022-011174	2/1/2023	FT-FY23-01102023-011174-A	<1	FT-FY23-01102023-011174-B	<1
WS-011175	3/14/2022	3/14/2023	Ground Floor	Bottle Filler	In hallway across from RG03 (bottle filler)			WF-03142022-011175	2/1/2023	FT-FY23-01102023-011175-A	<1	FT-FY23-01102023-011175-B	<1
WS-011176	3/14/2022	3/14/2023	Ground Floor	Cooler	In hallway across from RG03			WF-03142022-011176	2/1/2023	FT-FY23-01102023-011176-A	<1	FT-FY23-01102023-011176-B	<1
WS-011179	3/14/2022	3/14/2023	1	Bottle Filler	In hallway across from room R109 (bottle filler)			WF-03142022-011179	2/1/2023	FT-FY23-01102023-011179-A	<1	FT-FY23-01102023-011179-B	<1
WS-011180	3/14/2022	3/14/2023	1	Cooler	In hallway across from room R109	Low	Left	WF-03142022-011180	2/1/2023	FT-FY23-01102023-011180-A	<1	FT-FY23-01102023-011180-B	<1
WS-011181	3/14/2022	3/14/2023	1	Cooler	In hallway across from room R109	Low	Right	WF-03142022-011181	2/1/2023	FT-FY23-01102023-011181-A	<1	FT-FY23-01102023-011181-B	<1
WS-011182	3/14/2022	3/14/2023	1	Combo Fountain	In classroom R111		Left	WF-03142022-011182	2/1/2023	FT-FY23-01102023-011182-A	<1	FT-FY23-01102023-011182-B	<1
WS-011183	3/14/2022	3/14/2023	1	Combo Fountain	In classroom R111		Right	WF-03142022-011183	2/1/2023	FT-FY23-01102023-011183-A	<1	FT-FY23-01102023-011183-B	<1
WS-011186	3/14/2022	3/14/2023	1	Bottle Filler	In hallway adjacent to restrooms (bottle filler)			WF-03142022-011186	2/1/2023	FT-FY23-01102023-011186-A	<1	FT-FY23-01102023-011186-B	<1
WS-011187	3/14/2022	3/14/2023	1	Cooler	In hallway adjacent to restrooms			WF-03142022-011187	2/1/2023	FT-FY23-01102023-011187-A	<1	FT-FY23-01102023-011187-B	<1
WS-011189	3/14/2022	3/14/2023	1	Combo Fountain	In classroom R102 first clockwise from entry door			WF-03142022-011189	2/1/2023	FT-FY23-01102023-011189-A	<1	FT-FY23-01102023-011189-B	<1
WS-011191	3/14/2022	3/14/2023	1	Combo Fountain	In classroom R102 second clockwise from entry door			WF-03142022-011191	2/1/2023	FT-FY23-01102023-011191-A	<1	FT-FY23-01102023-011191-B	<1
WS-011195	3/14/2022	3/14/2023	1	Combo Fountain	In classroom R102 fourth clockwise from entry door			WF-03142022-011195	2/1/2023	FT-FY23-01102023-011195-A	<1	FT-FY23-01102023-011195-B	<1
WS-011206	3/14/2022	3/14/2023	1	Cooler	In hallway adjacent to room E100	High	Left	WF-03142022-011206	2/1/2023	FT-FY23-01102023-011206-A	<1	FT-FY23-01102023-011206-B	<1
WS-011207	3/14/2022	3/14/2023	1	Cooler	In hallway adjacent to room E100	Low	Right	WF-03142022-011207	2/1/2023	FT-FY23-01102023-011207-A	<1	FT-FY23-01102023-011207-B	<1
WS-011209	3/14/2022	3/14/2023	1	Cooler	In hallway across from stairwell C2	High	Left	WF-03142022-011209	2/1/2023	FT-FY23-01102023-011209-A	<1	FT-FY23-01102023-011209-B	<1
WS-011210	3/14/2022	3/14/2023	1	Cooler	In hallway across from stairwell C2	Low	Right	WF-03142022-011210	2/1/2023	FT-FY23-01102023-011210-A	<1	FT-FY23-01102023-011210-B	<1
WS-011264	3/14/2022	3/14/2023	2	Break Room	In staff lounge C216			WF-03142022-011264	2/1/2023	FT-FY23-01102023-011264-A	<1	FT-FY23-01102023-011264-B	<1
WS-011266	3/14/2022	3/14/2023	2	Cooler	In hallway adjacent to room E200	High	Left	WF-03142022-011266	2/1/2023	FT-FY23-01102023-011266-A	<1	FT-FY23-01102023-011266-B	<1
WS-011267	3/14/2022	3/14/2023	2	Cooler	In hallway adjacent to room E200	Low	Right	WF-03142022-011267	2/1/2023	FT-FY23-01102023-011267-A	<1	FT-FY23-01102023-011267-B	<1
WS-011276	3/14/2022	3/14/2023	3	Cooler	In hallway adjacent to stairwell C1	High	Left	WF-03142022-011276	2/1/2023	FT-FY23-01102023-011276-A	<1	FT-FY23-01102023-011276-B	<1
WS-011277	3/14/2022	3/14/2023	3	Cooler	In hallway adjacent to stairwell C1	Low	Right	WF-03142022-011277	2/1/2023	FT-FY23-01102023-011277-A	<1	FT-FY23-01102023-011277-B	<1
WS-011278	3/14/2022	3/14/2023	3	Cooler	In hallway adjacent to room W300	High	Left	WF-03142022-011278	2/1/2023	FT-FY23-01102023-011278-A	<1	FT-FY23-01102023-011278-B	<1
WS-011279	3/14/2022	3/14/2023	3	Cooler	In hallway adjacent to room W300	Low	Right	WF-03142022-011279	2/1/2023	FT-FY23-01102023-011279-A	<1	FT-FY23-01102023-011279-B	<1
WS-011497	3/14/2022	3/14/2023	Ground Floor	Cooler	In annex adjacent to COT 8	Low	Right	WF-03142022-011497	2/1/2023	FT-FY23-01102023-011497-A	<1	FT-FY23-01102023-011497-B	<1
WS-011498	3/14/2022	3/14/2023	Ground Floor	Cooler	In annex across from COT 9	High	Left	WF-03142022-011498	2/1/2023	FT-FY23-01102023-011498-A	<1	FT-FY23-01102023-011498-B	<1
WS-011499	3/14/2022	3/14/2023	Ground Floor	Cooler	In annex across from COT 9	Low	Right	WF-03142022-011499	2/1/2023	FT-FY23-01102023-011499-A	<1	FT-FY23-01102023-011499-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location		Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 010535	12/28/2022	12/28/2023	Ground Floor	Food Prep Sink	In kitchen on west wall	Left	WF-12282022-010535	2/1/2023	FT-FY23-01102023-010535-A	<1	FT-FY23-01102023-010535-B	<1
WS- 011153	12/28/2022	12/28/2023	Ground Floor	Food Prep Sink	In kitchen on north wall	Mid	WF-12282022-011153	2/1/2023	FT-FY23-01102023-011153-A	<1	FT-FY23-01102023-011153-B	<1
WS- 011154	12/28/2022	12/28/2023	Ground Floor	Food Prep Sink	In kitchen on north wall	Right	WF-12282022-011154	2/1/2023	FT-FY23-01102023-011154-A	<1	FT-FY23-01102023-011154-B	<1