



Deal MS Lead in Water Test Results



FY20 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 011157	4/8/2019	4/8/2020	Ground Floor	Cooler	In hallway adjacent to room NG20 High Left	WF-04082019-011157	1/6/2020	FT-FY20-122019-011157-A	<1	FT-FY20-122019-011157-B	<1
WS- 011158	4/8/2019	4/8/2020	Ground Floor	Cooler	In hallway adjacent to room NG20 Low Right	WF-04082019-011158	1/6/2020	FT-FY20-122019-011158-A	<1	FT-FY20-122019-011158-B	<1
WS- 011168	4/8/2019	4/8/2020	Ground Floor	Combo Fountain	In classroom RG02 second clockwise from entry door	WF-04082019-011168	1/6/2020	FT-FY20-122019-011168-A	<1	FT-FY20-122019-011168-B	<1
WS- 011170	4/8/2019	4/8/2020	Ground Floor	Combo Fountain	In classroom RG02 first clockwise from entry door	WF-04082019-011170	1/6/2020	FT-FY20-122019-011170-A	<1	FT-FY20-122019-011170-B	<1
WS- 011172	4/8/2019	4/8/2020	Ground Floor	Combo Fountain	In classroom RG02 third clockwise from entry door	WF-04082019-011172	1/6/2020	FT-FY20-122019-011172-A	<1	FT-FY20-122019-011172-B	<1
WS- 011174	4/8/2019	4/8/2020	Ground Floor	Combo Fountain	In classroom RG02 fourth clockwise from entry door	WF-04082019-011174	1/6/2020	FT-FY20-122019-011174-A	<1	FT-FY20-122019-011174-B	<1
WS- 011175	4/8/2019	4/8/2020	Ground Floor	Bottle Filler	In hallway across from RG03 (bottle filler)	WF-04082019-011175	1/6/2020	FT-FY20-122019-011175-A	<1	FT-FY20-122019-011175-B	<1
WS- 011176	4/8/2019	4/8/2020	Ground Floor	Cooler	In hallway across from RG03	WF-04082019-011176	1/6/2020	FT-FY20-122019-011176-A	<1	FT-FY20-122019-011176-B	<1
WS- 011177	4/8/2019	4/8/2020	Ground Floor	Bottle Filler	In hallway across from elevator (bottle filler)	WF-04082019-011177	1/6/2020	FT-FY20-122019-011177-A	<1	FT-FY20-122019-011177-B	<1
WS- 011178	4/8/2019	4/8/2020	Ground Floor	Cooler	In hallway across from elevator	WF-04082019-011178	1/6/2020	FT-FY20-122019-011178-A	<1	FT-FY20-122019-011178-B	<1
WS- 011179	4/8/2019	4/8/2020	1	Bottle Filler	In hallway across from room R109 (bottle filler)	WF-04082019-011179	1/6/2020	FT-FY20-122019-011179-A	<1	FT-FY20-122019-011179-B	<1
WS- 011180	4/8/2019	4/8/2020	1	Cooler	In hallway across from room R109 Low Left	WF-04082019-011180	1/6/2020	FT-FY20-122019-011180-A	<1	FT-FY20-122019-011180-B	<1
WS- 011181	4/8/2019	4/8/2020	1	Cooler	In hallway across from room R109 Low Right	WF-04082019-011181	1/6/2020	FT-FY20-122019-011181-A	<1	FT-FY20-122019-011181-B	<1
WS- 011182	4/8/2019	4/8/2020	1	Combo Fountain	In classroom R111 Left	WF-04082019-011182	1/6/2020	FT-FY20-122019-011182-A	<1	FT-FY20-122019-011182-B	<1
WS- 011183	4/8/2019	4/8/2020	1	Combo Fountain	In classroom R111 Right	WF-04082019-011183	1/6/2020	FT-FY20-122019-011183-A	<1	FT-FY20-122019-011183-B	<1
WS- 011186	11/4/2019	11/4/2020	1	Bottle Filler	In hallway adjacent to restrooms (bottle filler)	WF-11042019-011186	1/6/2020	FT-FY20-122019-011186-A	<1	FT-FY20-122019-011186-B	<1
WS- 011187	11/4/2019	11/4/2020	1	Cooler	In hallway adjacent to restrooms	WF-11042019-011187	1/6/2020	FT-FY20-122019-011187-A	<1	FT-FY20-122019-011187-B	<1
WS- 011189	4/8/2019	4/8/2020	1	Combo Fountain	In classroom R102 first clockwise from entry door	WF-04082019-011189	1/6/2020	FT-FY20-122019-011189-A	<1	FT-FY20-122019-011189-B	<1
WS- 011191	4/8/2019	4/8/2020	1	Combo Fountain	In classroom R102 second clockwise from entry door	WF-04082019-011191	1/6/2020	FT-FY20-122019-011191-A	<1	FT-FY20-122019-011191-B	<1
WS- 011195	4/8/2019	4/8/2020	1	Combo Fountain	In classroom R102 fourth clockwise from entry door	WF-04082019-011195	1/6/2020	FT-FY20-122019-011195-A	<1	FT-FY20-122019-011195-B	<1
WS- 011197	4/8/2019	4/8/2020	1	Health Suite	In health suite	WF-04082019-011197	1/6/2020	FT-FY20-122019-011197-A	<1	FT-FY20-122019-011197-B	<1
WS- 011206	4/8/2019	4/8/2020	1	Cooler	In hallway adjacent to room E100 High Left	WF-04082019-011206	1/6/2020	FT-FY20-122019-011206-A	<1	FT-FY20-122019-011206-B	<1
WS- 011207	4/8/2019	4/8/2020	1	Cooler	In hallway adjacent to room E100 Low Right	WF-04082019-011207	1/6/2020	FT-FY20-122019-011207-A	<1	FT-FY20-122019-011207-B	<1
WS- 011209	4/8/2019	4/8/2020	1	Cooler	In hallway across from stairwell C2 High Left	WF-04082019-011209	1/6/2020	FT-FY20-122019-011209-A	<1	FT-FY20-122019-011209-B	<1
WS- 011210	4/8/2019	4/8/2020	1	Cooler	In hallway across from stairwell C2 Low Right	WF-04082019-011210	1/6/2020	FT-FY20-122019-011210-A	<1	FT-FY20-122019-011210-B	<1
WS- 011264	4/8/2019	4/8/2020	2	Break Room	In staff lounge C216	WF-04082019-011264	1/6/2020	FT-FY20-122019-011264-A	<1	FT-FY20-122019-011264-B	<1
WS- 011267	4/8/2019	4/8/2020	2	Cooler	In hallway adjacent to room E200 Low Right	WF-04082019-011267	1/6/2020	FT-FY20-122019-011267-A	<1	FT-FY20-122019-011267-B	<1
WS- 011276	4/8/2019	4/8/2020	3	Cooler	In hallway adjacent to stairwell C1 High Left	WF-04082019-011276	1/6/2020	FT-FY20-122019-011276-A	<1	FT-FY20-122019-011276-B	<1
WS- 011277	4/8/2019	4/8/2020	3	Cooler	In hallway adjacent to stairwell C1 Low Right	WF-04082019-011277	1/6/2020	FT-FY20-122019-011277-A	<1	FT-FY20-122019-011277-B	<1
WS- 011278	4/8/2019	4/8/2020	3	Cooler	In hallway adjacent to room W300 High Left	WF-04082019-011278	1/6/2020	FT-FY20-122019-011278-A	<1	FT-FY20-122019-011278-B	<1
WS- 011279	4/8/2019	4/8/2020	3	Cooler	In hallway adjacent to room W300 Low Right	WF-04082019-011279	1/6/2020	FT-FY20-122019-011279-A	<1	FT-FY20-122019-011279-B	<1
WS- 011496	4/8/2019	4/8/2020	Ground Floor	Cooler	In annex adjacent to COT 8 High Left	WF-04082019-011496	1/6/2020	FT-FY20-122019-011496-A	<1	FT-FY20-122019-011496-B	<1
WS- 011497	4/8/2019	4/8/2020	Ground Floor	Cooler	In annex adjacent to COT 8 Low Right	WF-04082019-011497	1/6/2020	FT-FY20-122019-011497-A	<1	FT-FY20-122019-011497-B	<1
WS- 011498	4/8/2019	4/8/2020	Ground Floor	Cooler	In annex across from COT 9 High Left	WF-04082019-011498	1/6/2020	FT-FY20-122019-011498-A	<1	FT-FY20-122019-011498-B	<1
WS- 011499	4/8/2019	4/8/2020	Ground Floor	Cooler	In annex across from COT 9 Low Right	WF-04082019-011499	1/6/2020	FT-FY20-122019-011499-A	<1	FT-FY20-122019-011499-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS- 010535	7/18/2019	7/18/2020	Ground Floor	Food Prep Sink	In kitchen on west wall	Left	WF-07182019-010535	1/6/2020	FT-FY20-122019-010535-A	<1	FT-FY20-122019-010535-B	<1
WS- 011153	7/18/2019	7/18/2020	Ground Floor	Food Prep Sink	In kitchen on north wall	Mid	WF-07182019-011153	1/6/2020	FT-FY20-122019-011153-A	<1	FT-FY20-122019-011153-B	<1
WS- 011154	7/18/2019	7/18/2020	Ground Floor	Food Prep Sink	In kitchen on north wall	Right	WF-07182019-011154	1/6/2020	FT-FY20-122019-011154-A	<1	FT-FY20-122019-011154-B	<1