



Deal Middle School Lead in Water Test Results

FY24 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location		Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-011155	3/6/2023	3/6/2024	Ground Floor	Cooler	In cafeteria room NG20	High Left	WF-03062023-011155	11/3/2023	FT-FY24-09282023-011155-A	<1	FT-FY24-09282023-011155-B	<1
WS-011157	3/6/2023	3/6/2024	Ground Floor	Cooler	In hallway adjacent to room NG20	High Left	WF-03062023-011157	11/3/2023	FT-FY24-09282023-011157-A	<1	FT-FY24-09282023-011157-B	<1
WS-011158	3/6/2023	3/6/2024	Ground Floor	Cooler	In hallway adjacent to room NG20	Low Right	WF-03062023-011158	11/3/2023	FT-FY24-09282023-011158-A	<1	FT-FY24-09282023-011158-B	<1
WS-011161	3/6/2023	3/6/2024	Ground Floor	Cooler	In gym NG01		WF-03062023-011161	11/3/2023	FT-FY24-09282023-011161-A	<1	FT-FY24-09282023-011161-B	<1
WS-011170	3/6/2023	3/6/2024	Ground Floor	Combo Fountain	In classroom RG02 first clockwise from entry door		WF-03062023-011170	11/3/2023	FT-FY24-09282023-011170-A	<1	FT-FY24-09282023-011170-B	<1
WS-011172	3/6/2023	3/6/2024	Ground Floor	Combo Fountain	In classroom RG02 third clockwise from entry door		WF-03062023-011172	11/3/2023	FT-FY24-09282023-011172-A	<1	FT-FY24-09282023-011172-B	<1
WS-011174	3/6/2023	3/6/2024	Ground Floor	Combo Fountain	In classroom RG02 fourth clockwise from entry door		WF-03062023-011174	11/3/2023	FT-FY24-09282023-011174-A	<1	FT-FY24-09282023-011174-B	<1
WS-011175	3/6/2023	3/6/2024	Ground Floor	Bottle Filler	In hallway across from RG03 (bottle filler)		WF-03062023-011175	11/3/2023	FT-FY24-09282023-011175-A	<1	FT-FY24-09282023-011175-B	<1
WS-011176	3/6/2023	3/6/2024	Ground Floor	Cooler	In hallway across from RG03		WF-03062023-011176	11/3/2023	FT-FY24-09282023-011176-A	<1	FT-FY24-09282023-011176-B	<1
WS-011177	3/6/2023	3/6/2024	Ground Floor	Bottle Filler	In hallway across from elevator (bottle filler)		WF-03062023-011177	11/3/2023	FT-FY24-10202023-011177-A	<1	FT-FY24-10202023-011177-B	<1
WS-011178	6/21/2023	6/21/2024	Ground Floor	Cooler	In hallway across from elevator		WF-06212023-011178	11/3/2023	FT-FY24-09282023-011178-A	<1	FT-FY24-09282023-011178-B	<1
WS-011179	3/6/2023	3/6/2024	1	Bottle Filler	In hallway across from room R109 (bottle filler)		WF-03062023-011179	11/3/2023	FT-FY24-09282023-011179-A	<1	FT-FY24-09282023-011179-B	<1
WS-011180	3/6/2023	3/6/2024	1	Cooler	In hallway across from room R109	Low Left	WF-03062023-011180	11/3/2023	FT-FY24-09282023-011180-A	<1	FT-FY24-09282023-011180-B	<1
WS-011181	3/6/2023	3/6/2024	1	Cooler	In hallway across from room R109	Low Right	WF-03062023-011181	11/3/2023	FT-FY24-09282023-011181-A	1.7	FT-FY24-09282023-011181-B	<1
WS-011182	3/6/2023	3/6/2024	1	Combo Fountain	In classroom R111	Left	WF-03062023-011182	11/3/2023	FT-FY24-09282023-011182-A	<1	FT-FY24-09282023-011182-B	<1
WS-011183	3/6/2023	3/6/2024	1	Combo Fountain	In classroom R111	Right	WF-03062023-011183	11/3/2023	FT-FY24-09282023-011183-A	3.2	FT-FY24-09282023-011183-B	<1
WS-011186	3/6/2023	3/6/2024	1	Bottle Filler	In hallway adjacent to restrooms (bottle filler)		WF-03062023-011186	11/3/2023	FT-FY24-09282023-011186-A	<1	FT-FY24-09282023-011186-B	<1
WS-011187	3/6/2023	3/6/2024	1	Cooler	In hallway adjacent to restrooms		WF-03062023-011187	11/3/2023	FT-FY24-09282023-011187-A	<1	FT-FY24-09282023-011187-B	<1
WS-011189	3/6/2023	3/6/2024	1	Combo Fountain	In classroom R102 first clockwise from entry door		WF-03062023-011189	11/3/2023	FT-FY24-09282023-011189-A	<1	FT-FY24-09282023-011189-B	<1
WS-011191	3/6/2023	3/6/2024	1	Combo Fountain	In classroom R102 second clockwise from entry door		WF-03062023-011191	11/3/2023	FT-FY24-09282023-011191-A	<1	FT-FY24-09282023-011191-B	<1
WS-011195	3/6/2023	3/6/2024	1	Combo Fountain	In classroom R102 fourth clockwise from entry door		WF-03062023-011195	11/3/2023	FT-FY24-09282023-011195-A	<1	FT-FY24-09282023-011195-B	<1
WS-011206	3/6/2023	3/6/2024	1	Cooler	In hallway adjacent to room E100	High Left	WF-03062023-011206	11/3/2023	FT-FY24-09282023-011206-A	<1	FT-FY24-09282023-011206-B	<1
WS-011209	3/6/2023	3/6/2024	1	Cooler	In hallway across from stairwell C2	High Left	WF-03062023-011209	11/3/2023	FT-FY24-09282023-011209-A	<1	FT-FY24-09282023-011209-B	<1
WS-011210	3/6/2023	3/6/2024	1	Cooler	In hallway across from stairwell C2	Low Right	WF-03062023-011210	11/3/2023	FT-FY24-09282023-011210-A	<1	FT-FY24-09282023-011210-B	<1
WS-011227	8/28/2023	8/28/2024	2	Cooler	In hallway adjacent to room W200	High Left	WF-08282023-011227	11/3/2023	FT-FY24-09282023-011227-A	<1	FT-FY24-09282023-011227-B	<1
WS-011228	8/28/2023	8/28/2024	2	Cooler	In hallway adjacent to room W200	Low Right	WF-08282023-011228	11/3/2023	FT-FY24-09282023-011228-A	<1	FT-FY24-09282023-011228-B	<1
WS-011264	3/6/2023	3/6/2024	2	Break Room	In staff lounge C216		WF-03062023-011264	11/3/2023	FT-FY24-09282023-011264-A	<1	FT-FY24-09282023-011264-B	<1
WS-011266	3/6/2023	3/6/2024	2	Cooler	In hallway adjacent to room E200	High Left	WF-03062023-011266	11/3/2023	FT-FY24-09282023-011266-A	<1	FT-FY24-09282023-011266-B	<1
WS-011267	3/6/2023	3/6/2024	2	Cooler	In hallway adjacent to room E200	Low Right	WF-03062023-011267	11/3/2023	FT-FY24-09282023-011267-A	<1	FT-FY24-09282023-011267-B	<1
WS-011276	3/6/2023	3/6/2024	3	Cooler	In hallway adjacent to stairwell C1	High Left	WF-03062023-011276	11/3/2023	FT-FY24-09282023-011276-A	<1	FT-FY24-09282023-011276-B	<1
WS-011277	3/6/2023	3/6/2024	3	Cooler	In hallway adjacent to stairwell C1	Low Right	WF-03062023-011277	11/3/2023	FT-FY24-09282023-011277-A	<1	FT-FY24-09282023-011277-B	<1
WS-011278	3/6/2023	3/6/2024	3	Cooler	In hallway adjacent to room W300	High Left	WF-03062023-011278	11/3/2023	FT-FY24-09282023-011278-A	<1	FT-FY24-09282023-011278-B	<1
WS-011279	3/6/2023	3/6/2024	3	Cooler	In hallway adjacent to room W300	Low Right	WF-03062023-011279	11/3/2023	FT-FY24-09282023-011279-A	<1	FT-FY24-09282023-011279-B	<1
WS-011497	3/6/2023	3/6/2024	Ground Floor	Cooler	In annex adjacent to COT 8	Low Right	WF-03062023-011497	11/3/2023	FT-FY24-09282023-011497-A	<1	FT-FY24-09282023-011497-B	<1
WS-011498	3/6/2023	3/6/2024	Ground Floor	Cooler	In annex across from COT 9	High Left	WF-03062023-011498	11/3/2023	FT-FY24-09282023-011498-A	<1	FT-FY24-09282023-011498-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS- 010535	12/28/2022	12/28/2023	Ground Floor	Food Prep Sink	In kitchen on west wall	Left	WF-12282022-010535	11/3/2023	FT-FY24-09282023-010535-A	3.1	FT-FY24-09282023-010535-B	<1
WS- 011153	12/28/2022	12/28/2023	Ground Floor	Food Prep Sink	In kitchen on north wall	Mid	WF-12282022-011153	11/3/2023	FT-FY24-09282023-011153-A	<1	FT-FY24-09282023-011153-B	<1
WS- 011154	12/28/2022	12/28/2023	Ground Floor	Food Prep Sink	In kitchen on north wall	Right	WF-12282022-011154	11/3/2023	FT-FY24-09282023-011154-A	<1	FT-FY24-09282023-011154-B	<1