



Deal MS Lead in Water Test Results

FY26 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS-005837	2/19/2025	2/19/2026	Ground Floor	Bottle Filler	In hallway adjacent to room NG20	WF-02192025-005837	10/25/2025	FT-FY26-09302025-005837-A	<2	FT-FY26-09302025-005837-B	<2	
WS-005845	2/19/2025	2/19/2026	1	Bottle Filler	In hallway across from elevator	WF-02192025-005845	10/25/2025	FT-FY26-09302025-005845-A	<2	FT-FY26-09302025-005845-B	<2	
WS-005846	2/19/2025	2/19/2026	1	Cooler	In hallway across from elevator	High Left	WF-02192025-005846	10/25/2025	FT-FY26-09302025-005846-A	<2	FT-FY26-09302025-005846-B	<2
WS-005847	2/19/2025	2/19/2026	1	Cooler	In hallway across from elevator	Low Right	WF-02192025-005847	10/25/2025	FT-FY26-09302025-005847-A	<2	FT-FY26-09302025-005847-B	<2
WS-005848	6/3/2025	6/3/2026	2	Bottle Filler	In hallway across from elevator	WF-06032025-005848	10/25/2025	FT-FY26-09302025-005848-A	<2	FT-FY26-09302025-005848-B	<2	
WS-005849	6/3/2025	6/3/2026	2	Cooler	In hallway across from elevator	High Left	WF-06032025-005849	10/25/2025	FT-FY26-09302025-005849-A	<2	FT-FY26-09302025-005849-B	<2
WS-005850	6/3/2025	6/3/2026	2	Cooler	In hallway across from elevator	Low Right	WF-06032025-005850	10/25/2025	FT-FY26-09302025-005850-A	<2	FT-FY26-09302025-005850-B	<2
WS-005851	6/3/2025	6/3/2026	3	Bottle Filler	In hallway across from elevator	WF-06032025-005851	10/25/2025	FT-FY26-09302025-005851-A	<2	FT-FY26-09302025-005851-B	<2	
WS-005852	6/3/2025	6/3/2026	3	Cooler	In hallway across from elevator	High Left	WF-06032025-005852	10/25/2025	FT-FY26-09302025-005852-A	<2	FT-FY26-09302025-005852-B	<2
WS-005853	6/3/2025	6/3/2026	3	Cooler	In hallway across from elevator	Low Right	WF-06032025-005853	10/25/2025	FT-FY26-09302025-005853-A	<2	FT-FY26-09302025-005853-B	<2
WS-011157	2/19/2025	2/19/2026	Ground Floor	Cooler	In hallway adjacent to room NG20	High Left	WF-02192025-011157	10/25/2025	FT-FY26-09302025-011157-A	<2	FT-FY26-09302025-011157-B	<2
WS-011158	2/19/2025	2/19/2026	Ground Floor	Cooler	In hallway adjacent to room NG20	Low Right	WF-02192025-011158	10/25/2025	FT-FY26-09302025-011158-A	<2	FT-FY26-09302025-011158-B	<2
WS-011161	2/19/2025	2/19/2026	Ground Floor	Cooler	In gym NG01	WF-02192025-011161	10/25/2025	FT-FY26-09302025-011161-A	<2	FT-FY26-09302025-011161-B	<2	
WS-011165	2/19/2025	2/19/2026	Ground Floor	Cooler	In hallway adjacent to boys' locker room NG12	High Left	WF-02192025-011165	10/25/2025	FT-FY26-09302025-011165-A	<2	FT-FY26-09302025-011165-B	<2
WS-011174	2/19/2025	2/19/2026	Ground Floor	Combo Fountain	In classroom RG02 fourth clockwise from entry door	WF-02192025-011174	10/25/2025	FT-FY26-09302025-011174-A	<2	FT-FY26-09302025-011174-B	<2	
WS-011177	2/19/2025	2/19/2026	Ground Floor	Bottle Filler	In hallway across from elevator (bottle filler)	WF-02192025-011177	10/25/2025	FT-FY26-09302025-011177-A	<2	FT-FY26-09302025-011177-B	<2	
WS-011178	2/19/2025	2/19/2026	Ground Floor	Cooler	In hallway across from elevator	WF-02192025-011178	10/25/2025	FT-FY26-09302025-011178-A	<2	FT-FY26-09302025-011178-B	<2	
WS-011179	2/19/2025	2/19/2026	1	Bottle Filler	In hallway across from room R109 (bottle filler)	WF-02192025-011179	10/25/2025	FT-FY26-09302025-011179-A	<2	FT-FY26-09302025-011179-B	<2	
WS-011180	2/19/2025	2/19/2026	1	Cooler	In hallway across from room R109	Low Left	WF-02192025-011180	10/25/2025	FT-FY26-09302025-011180-A	<2	FT-FY26-09302025-011180-B	<2
WS-011181	2/19/2025	2/19/2026	1	Cooler	In hallway across from room R109	Low Right	WF-02192025-011181	10/25/2025	FT-FY26-09302025-011181-A	<2	FT-FY26-09302025-011181-B	<2
WS-011186	2/19/2025	2/19/2026	1	Bottle Filler	In hallway adjacent to restrooms (bottle filler)	WF-02192025-011186	10/25/2025	FT-FY26-09302025-011186-A	<2	FT-FY26-09302025-011186-B	<2	
WS-011187	2/19/2025	2/19/2026	1	Cooler	In hallway adjacent to restrooms	WF-02192025-011187	10/25/2025	FT-FY26-09302025-011187-A	<2	FT-FY26-09302025-011187-B	<2	
WS-011189	2/19/2025	2/19/2026	1	Combo Fountain	In classroom R102 first clockwise from entry door	WF-02192025-011189	10/25/2025	FT-FY26-09302025-011189-A	<2	FT-FY26-09302025-011189-B	<2	
WS-011191	2/19/2025	2/19/2026	1	Combo Fountain	In classroom R102 second clockwise from entry door	WF-02192025-011191	10/25/2025	FT-FY26-09302025-011191-A	<2	FT-FY26-09302025-011191-B	<2	
WS-011195	2/19/2025	2/19/2026	1	Combo Fountain	In classroom R102 fourth clockwise from entry door	WF-02192025-011195	10/25/2025	FT-FY26-09302025-011195-A	<2	FT-FY26-09302025-011195-B	<2	
WS-011197	2/19/2025	2/19/2026	1	Health Suite	In health suite	WF-02192025-011197	10/25/2025	FT-FY26-09302025-011197-A	<2	FT-FY26-09302025-011197-B	<2	
WS-011209	2/19/2025	2/19/2026	1	Cooler	In hallway across from stairwell C2	High Left	WF-02192025-011209	10/25/2025	FT-FY26-09302025-011209-A	<2	FT-FY26-09302025-011209-B	<2
WS-011210	2/19/2025	2/19/2026	1	Cooler	In hallway across from stairwell C2	Low Right	WF-02192025-011210	10/25/2025	FT-FY26-09302025-011210-A	<2	FT-FY26-09302025-011210-B	<2
WS-011227	2/19/2025	2/19/2026	2	Cooler	In hallway adjacent to room W200	High Left	WF-02192025-011227	10/25/2025	FT-FY26-09302025-011227-A	<2	FT-FY26-09302025-011227-B	<2
WS-011228	2/19/2025	2/19/2026	2	Cooler	In hallway adjacent to room W200	Low Right	WF-02192025-011228	10/25/2025	FT-FY26-09302025-011228-A	<2	FT-FY26-09302025-011228-B	<2
WS-011264	2/19/2025	2/19/2026	2	Break Room	In staff lounge C216	WF-02192025-011264	10/25/2025	FT-FY26-09302025-011264-A	<2	FT-FY26-09302025-011264-B	<2	
WS-011266	2/19/2025	2/19/2026	2	Cooler	In hallway adjacent to room E200	High Left	WF-02192025-011266	10/25/2025	FT-FY26-09302025-011266-A	<2	FT-FY26-09302025-011266-B	<2
WS-011267	2/19/2025	2/19/2026	2	Cooler	In hallway adjacent to room E200	Low Right	WF-02192025-011267	10/25/2025	FT-FY26-09302025-011267-A	<2	FT-FY26-09302025-011267-B	<2
WS-011276	2/19/2025	2/19/2026	3	Cooler	In hallway adjacent to stairwell C1	High Left	WF-02192025-011276	10/25/2025	FT-FY26-09302025-011276-A	<2	FT-FY26-09302025-011276-B	<2

WS- 011277	2/19/2025	2/19/2026	3	Cooler	In hallway adjacent to stairwell C1	Low Right	WF-02192025-011277	10/25/2025	FT-FY26-09302025-011277-A	<2	FT-FY26-09302025-011277-B	<2
WS- 011278	2/19/2025	2/19/2026	3	Cooler	In hallway adjacent to room W300	High Left	WF-02192025-011278	10/25/2025	FT-FY26-09302025-011278-A	<2	FT-FY26-09302025-011278-B	<2
WS- 011279	2/19/2025	2/19/2026	3	Cooler	In hallway adjacent to room W300	Low Right	WF-02192025-011279	10/25/2025	FT-FY26-09302025-011279-A	<2	FT-FY26-09302025-011279-B	<2

Food Prep Sink

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location		Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 010535	11/19/2024	11/19/2025	Ground Floor	Food Prep Sink	In kitchen on west wall	Left	WF-11192024-010535	10/25/2025	FT-FY26-09302025-010535-A	<2	FT-FY26-09302025-010535-B	<2
WS- 011153	11/19/2024	11/19/2025	Ground Floor	Food Prep Sink	In kitchen on north wall	Mid	WF-11192024-011153	10/25/2025	FT-FY26-09302025-011153-A	<2	FT-FY26-09302025-011153-B	<2
WS- 011154	11/19/2024	11/19/2025	Ground Floor	Food Prep Sink	In kitchen on north wall	Right	WF-11192024-011154	10/25/2025	FT-FY26-09302025-011154-A	<2	FT-FY26-09302025-011154-B	<2

Due to changes in water sampling analysis equipment at the laboratory from previous years, the level of detection (LOD) for lead in drinking water is now <2ppb.