



Deal Middle School Lead in Water Test Results

FY21 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-011155	3/23/2021	3/23/2022	Ground Floor	Cooler	In cafeteria room NG20 High Left	WF-03232021-011155	4/5/2021	FT-FY21-032021-011155-A	<1	FT-FY21-032021-011155-B	<1
WS-011156	3/23/2021	3/23/2022	Ground Floor	Cooler	In cafeteria room NG20 Low Right	WF-03232021-011156	4/5/2021	FT-FY21-032021-011156-A	<1	FT-FY21-032021-011156-B	<1
WS-011157	3/23/2021	3/23/2022	Ground Floor	Cooler	In hallway adjacent to room NG20 High Left	WF-03232021-011157	4/5/2021	FT-FY21-032021-011157-A	<1	FT-FY21-032021-011157-B	<1
WS-011158	3/23/2021	3/23/2022	Ground Floor	Cooler	In hallway adjacent to room NG20 Low Right	WF-03232021-011158	4/5/2021	FT-FY21-032021-011158-A	<1	FT-FY21-032021-011158-B	<1
WS-011161	3/23/2021	3/23/2022	Ground Floor	Cooler	In gym NG01 High Left	WF-03232021-011161	4/5/2021	FT-FY21-032021-011161-A	<1	FT-FY21-032021-011161-B	<1
WS-011162	3/23/2021	3/23/2022	Ground Floor	Cooler	In gym NG01 Low Left	WF-03232021-011162	4/5/2021	FT-FY21-032021-011162-A	<1	FT-FY21-032021-011162-B	<1
WS-011165	3/23/2021	3/23/2022	Ground Floor	Cooler	In hallway adjacent to boys' locker room NG12 High Left	WF-03232021-011165	4/5/2021	FT-FY21-032021-011165-A	<1	FT-FY21-032021-011165-B	<1
WS-011166	3/23/2021	3/23/2022	Ground Floor	Cooler	In hallway adjacent to boys' locker room NG12 Low Right	WF-03232021-011166	4/5/2021	FT-FY21-032021-011166-A	<1	FT-FY21-032021-011166-B	<1
WS-011168	3/23/2021	3/23/2022	Ground Floor	Combo Fountain	In classroom RG02 second clockwise from entry door	WF-03232021-011168	4/5/2021	FT-FY21-032021-011168-A	<1	FT-FY21-032021-011168-B	<1
WS-011170	3/23/2021	3/23/2022	Ground Floor	Combo Fountain	In classroom RG02 first clockwise from entry door	WF-03232021-011170	4/5/2021	FT-FY21-032021-011170-A	<1	FT-FY21-032021-011170-B	<1
WS-011172	3/23/2021	3/23/2022	Ground Floor	Combo Fountain	In classroom RG02 third clockwise from entry door	WF-03232021-011172	4/5/2021	FT-FY21-032021-011172-A	<1	FT-FY21-032021-011172-B	<1
WS-011174	3/23/2021	3/23/2022	Ground Floor	Combo Fountain	In classroom RG02 fourth clockwise from entry door	WF-03232021-011174	4/5/2021	FT-FY21-032021-011174-A	<1	FT-FY21-032021-011174-B	<1
WS-011175	3/23/2021	3/23/2022	Ground Floor	Bottle Filler	In hallway across from RG03 (bottle filler)	WF-03232021-011175	4/5/2021	FT-FY21-032021-011175-A	<1	FT-FY21-032021-011175-B	<1
WS-011176	3/23/2021	3/23/2022	Ground Floor	Cooler	In hallway across from RG03	WF-03232021-011176	4/5/2021	FT-FY21-032021-011176-A	<1	FT-FY21-032021-011176-B	<1
WS-011177	3/23/2021	3/23/2022	Ground Floor	Bottle Filler	In hallway across from elevator (bottle filler)	WF-03232021-011177	4/5/2021	FT-FY21-032021-011177-A	<1	FT-FY21-032021-011177-B	<1
WS-011178	3/23/2021	3/23/2022	Ground Floor	Cooler	In hallway across from elevator	WF-03232021-011178	4/5/2021	FT-FY21-032021-011178-A	<1	FT-FY21-032021-011178-B	<1
WS-011179	3/23/2021	3/23/2022	1	Bottle Filler	In hallway across from room R109 (bottle filler)	WF-03232021-011179	4/5/2021	FT-FY21-032021-011179-A	<1	FT-FY21-032021-011179-B	<1
WS-011180	3/23/2021	3/23/2022	1	Cooler	In hallway across from room R109 Low Left	WF-03232021-011180	4/5/2021	FT-FY21-032021-011180-A	<1	FT-FY21-032021-011180-B	<1
WS-011181	3/23/2021	3/23/2022	1	Cooler	In hallway across from room R109 Low Right	WF-03232021-011181	4/5/2021	FT-FY21-032021-011181-A	<1	FT-FY21-032021-011181-B	<1
WS-011183	3/23/2021	3/23/2022	1	Combo Fountain	In classroom R111 Right	WF-03232021-011183	4/5/2021	FT-FY21-032021-011183-A	<1	FT-FY21-032021-011183-B	<1
WS-011186	3/23/2021	3/23/2022	1	Bottle Filler	In hallway adjacent to restrooms (bottle filler)	WF-03232021-011186	4/5/2021	FT-FY21-032021-011186-A	<1	FT-FY21-032021-011186-B	<1
WS-011187	3/23/2021	3/23/2022	1	Cooler	In hallway adjacent to restrooms	WF-03232021-011187	4/5/2021	FT-FY21-032021-011187-A	<1	FT-FY21-032021-011187-B	<1
WS-011189	3/23/2021	3/23/2022	1	Combo Fountain	In classroom R102 first clockwise from entry door	WF-03232021-011189	4/5/2021	FT-FY21-032021-011189-A	<1	FT-FY21-032021-011189-B	<1
WS-011191	3/23/2021	3/23/2022	1	Combo Fountain	In classroom R102 second clockwise from entry door	WF-03232021-011191	4/5/2021	FT-FY21-032021-011191-A	<1	FT-FY21-032021-011191-B	<1
WS-011195	3/23/2021	3/23/2022	1	Combo Fountain	In classroom R102 fourth clockwise from entry door	WF-03232021-011195	4/5/2021	FT-FY21-032021-011195-A	<1	FT-FY21-032021-011195-B	<1
WS-011197	3/23/2021	3/23/2022	1	Health Suite	In health suite	WF-03232021-011197	4/5/2021	FT-FY21-032021-011197-A	3.4	FT-FY21-032021-011197-B	<1
WS-011206	3/23/2021	3/23/2022	1	Cooler	In hallway adjacent to room E100 High Left	WF-03232021-011206	4/5/2021	FT-FY21-032021-011206-A	<1	FT-FY21-032021-011206-B	<1
WS-011207	3/23/2021	3/23/2022	1	Cooler	In hallway adjacent to room E100 Low Right	WF-03232021-011207	4/5/2021	FT-FY21-032021-011207-A	<1	FT-FY21-032021-011207-B	<1
WS-011209	3/23/2021	3/23/2022	1	Cooler	In hallway across from stairwell C2 High Left	WF-03232021-011209	4/5/2021	FT-FY21-032021-011209-A	<1	FT-FY21-032021-011209-B	<1
WS-011210	3/23/2021	3/23/2022	1	Cooler	In hallway across from stairwell C2 Low Right	WF-03232021-011210	4/5/2021	FT-FY21-032021-011210-A	<1	FT-FY21-032021-011210-B	<1
WS-011264	3/23/2021	3/23/2022	2	Break Room	In staff lounge C216	WF-03232021-011264	4/5/2021	FT-FY21-032021-011264-A	<1	FT-FY21-032021-011264-B	<1
WS-011266	3/23/2021	3/23/2022	2	Cooler	In hallway adjacent to room E200 High Left	WF-03232021-011266	4/5/2021	FT-FY21-032021-011266-A	<1	FT-FY21-032021-011266-B	<1
WS-011267	3/23/2021	3/23/2022	2	Cooler	In hallway adjacent to room E200 Low Right	WF-03232021-011267	4/5/2021	FT-FY21-032021-011267-A	<1	FT-FY21-032021-011267-B	<1
WS-011276	3/23/2021	3/23/2022	3	Cooler	In hallway adjacent to stairwell C1 High Left	WF-03232021-011276	4/5/2021	FT-FY21-032021-011276-A	<1	FT-FY21-032021-011276-B	<1
WS-011277	3/23/2021	3/23/2022	3	Cooler	In hallway adjacent to stairwell C1 Low Right	WF-03232021-011277	4/5/2021	FT-FY21-032021-011277-A	<1	FT-FY21-032021-011277-B	<1

WS- 011278	3/23/2021	3/23/2022	3	Cooler	In hallway adjacent to room W300	High	Left	WF-03232021-011278	4/5/2021	FT-FY21-032021-011278-A	<1	FT-FY21-032021-011278-B	<1
WS- 011279	3/23/2021	3/23/2022	3	Cooler	In hallway adjacent to room W300	Low	Right	WF-03232021-011279	4/5/2021	FT-FY21-032021-011279-A	<1	FT-FY21-032021-011279-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location		Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 011153	1/26/2021	1/26/2022	Ground Floor	Food Prep Sink	In kitchen on north wall	Mid	WF-01262021-011153	4/5/2021	FT-FY21-032021-011153-A	<1	FT-FY21-032021-011153-B	<1
WS- 011154	1/26/2021	1/26/2022	Ground Floor	Food Prep Sink	In kitchen on north wall	Right	WF-01262021-011154	4/5/2021	FT-FY21-032021-011154-A	<1	FT-FY21-032021-011154-B	<1

Food Prep Sink

Greater than 5ppb - Devices requiring remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location		Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 010535	1/26/2021	1/26/2022	Ground Floor	Food Prep Sink	In kitchen on west wall	Left	WF-01262021-010535	4/5/2021	FT-FY21-032021-010535-A	13.0	FT-FY21-032021-010535-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location		Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 010535	4/21/2021	4/21/2022	Ground Floor	Food Prep Sink	In kitchen on west wall	Left	WF-04212021-010535	4/28/2021	FT-FY21-042021-010535-A	<1	FT-FY21-042021-010535-B	<1