



# DEANWOOD REC LEAD WATER TEST RESULTS



	Building Location: Building Name	RECORD ID	Date Analyzed	Floor	Device Type	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)
1	DEANWOOD RECREATION CENTER	WS- 005334	9/20/2016	1	Fountain	In hallway adjacent to room 1301 High	FT-82016-005334-A	< 1	FT-82016-005334-B	< 1
2	DEANWOOD RECREATION CENTER	WS- 005335	9/20/2016	1	Fountain	In hallway adjacent to room 1301 Low Right	FT-82016-005335-A	< 1	FT-82016-005335-B	< 1
3	DEANWOOD RECREATION CENTER	WS- 005336	9/20/2016	1	Food Prep Sink	In kitchen 1202	FT-82016-005336-A	< 1	FT-82016-005336-B	< 1
4	DEANWOOD RECREATION CENTER	WS- 005337	9/20/2016	1	Cooler	In hallway adjacent to room 1105 High	FT-82016-005337-A	< 1	FT-82016-005337-B	< 1
5	DEANWOOD RECREATION CENTER	WS- 005338	9/20/2016	1	Cooler	In hallway adjacent to room 1105 Low Right	FT-82016-005338-A	< 1	FT-82016-005338-B	< 1
6	DEANWOOD RECREATION CENTER	WS- 005340	9/20/2016	1	Cooler	In hallway adjacent to room 1505 High Left	FT-82016-005340-A	< 1	FT-82016-005340-B	< 1
7	DEANWOOD RECREATION CENTER	WS- 005341	9/20/2016	1	Cooler	In hallway adjacent to room 1505 Low Right	FT-82016-005341-A	< 1	FT-82016-005341-B	< 1
8	DEANWOOD RECREATION CENTER	WS- 005343	9/20/2016	1	Fountain	In classroom 1410 in restroom area first clockwise around room from entry door Left	FT-82016-005343-A	< 1	FT-82016-005343-B	< 1
9	DEANWOOD RECREATION CENTER	WS- 005345	9/20/2016	1	Fountain	In classroom 1410 in restroom area second clockwise around room from entry door Mid	FT-82016-005345-A	< 1	FT-82016-005345-B	< 1
10	DEANWOOD RECREATION CENTER	WS- 005347	9/20/2016	1	Fountain	In classroom 1410 in restroom area third clockwise around room from entry door Right	FT-82016-005347-A	< 1	FT-82016-005347-B	< 1
11	DEANWOOD RECREATION CENTER	WS- 005358	9/20/2016	1	Fountain	In classroom 1414 in restroom area second clockwise around room from entry door	FT-82016-005358-A	< 1	FT-82016-005358-B	< 1
12	DEANWOOD RECREATION CENTER	WS- 005360	9/20/2016	1	Fountain	In classroom 1414 in restroom area third clockwise around room from entry door	FT-82016-005360-A	< 1	FT-82016-005360-B	< 1
13	DEANWOOD RECREATION CENTER	WS- 005367	9/20/2016	1	Food Prep Sink	In kitchen 1417	FT-82016-005367-A	< 1	FT-82016-005367-B	< 1