



Dorothy Height Elementary School Lead in Water Test Results

FY21 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 008548	7/7/2020	7/7/2021	1	Health Suite	In health suite 116 in restroom	WF-07072020-008548	4/1/2021	FT-FY21-032021-008548-A	<1	FT-FY21-032021-008548-B	<1
WS- 008549	10/12/2020	10/12/2021	2	Cooler	In hallway adjacent to room 212 High Left	WF-10122020-008549	4/1/2021	FT-FY21-032021-008549-A	<1	FT-FY21-032021-008549-B	<1
WS- 008550	10/12/2020	10/12/2021	2	Cooler	In hallway adjacent to room 212 Low Right	WF-10122020-008550	4/1/2021	FT-FY21-032021-008550-A	<1	FT-FY21-032021-008550-B	<1
WS- 008556	9/15/2020	9/15/2021	1	Classroom Faucet	Annex, in classroom 015	WF-09152020-008556	4/1/2021	FT-FY21-032021-008556-A	<1	FT-FY21-032021-008556-B	<1
WS- 008557	9/15/2020	9/15/2021	1	Classroom Faucet	Annex, in classroom 017	WF-09152020-008557	4/1/2021	FT-FY21-032021-008557-A	<1	FT-FY21-032021-008557-B	<1
WS- 008558	6/22/2020	6/22/2021	1	Break Room	Annex, in staff lounge 009	WF-06222020-008558	4/1/2021	FT-FY21-032021-008558-A	<1	FT-FY21-032021-008558-B	<1
WS- 008560	9/15/2020	9/15/2021	1	Classroom Faucet	Annex, in classroom 016	WF-09152020-008560	4/1/2021	FT-FY21-032021-008560-A	<1	FT-FY21-032021-008560-B	<1
WS- 008561	9/15/2020	9/15/2021	1	Classroom Faucet	Annex, in classroom 014	WF-09152020-008561	4/1/2021	FT-FY21-032021-008561-A	<1	FT-FY21-032021-008561-B	<1
WS- 008590	9/15/2020	9/15/2021	1	Classroom Faucet	Annex, in classroom 007 west wall	WF-09152020-008590	4/1/2021	FT-FY21-032021-008590-A	<1	FT-FY21-032021-008590-B	<1
WS- 008591	6/22/2020	6/22/2021	1	Cooler	Annex, in classroom 007	WF-06222020-008591	4/1/2021	FT-FY21-032021-008591-A	<1	FT-FY21-032021-008591-B	<1
WS- 008592	9/15/2020	9/15/2021	1	Classroom Faucet	Annex, in classroom 012	WF-09152020-008592	4/1/2021	FT-FY21-032021-008592-A	1.4	FT-FY21-032021-008592-B	<1
WS- 008700	10/12/2020	10/12/2021	1	Cooler	Annex, in hallway adjacent to room 12	WF-10122020-008700	4/1/2021	FT-FY21-032021-008700-A	<1	FT-FY21-032021-008700-B	<1
WS- 010543	9/15/2020	9/15/2021	1	Classroom Faucet	Annex, in classroom 006	WF-09152020-010543	4/1/2021	FT-FY21-032021-010543-A	<1	FT-FY21-032021-010543-B	<1
WS- 010970	10/12/2020	10/12/2021	3	Bottle Filler	In hallway adjacent to room 310	WF-10122020-010970	4/1/2021	FT-FY21-032021-010970-A	<1	FT-FY21-032021-010970-B	<1
WS- 010971	10/12/2020	10/12/2021	3	Bottle Filler	In hallway adjacent to room 310	WF-10122020-010971	4/1/2021	FT-FY21-032021-010971-A	<1	FT-FY21-032021-010971-B	<1
WS- 010972	10/12/2020	10/12/2021	2	Bottle Filler	In hallway adjacent to room 212	WF-10122020-010972	4/1/2021	FT-FY21-032021-010972-A	<1	FT-FY21-032021-010972-B	<1
WS- 010973	10/12/2020	10/12/2021	2	Bottle Filler	In hallway adjacent to room 212	WF-10122020-010973	4/1/2021	FT-FY21-032021-010973-A	<1	FT-FY21-032021-010973-B	<1
WS- 010974	10/12/2020	10/12/2021	1	Bottle Filler	In hallway adjacent to 104	WF-10122020-010974	4/1/2021	FT-FY21-032021-010974-A	<1	FT-FY21-032021-010974-B	<1
WS- 010975	10/12/2020	10/12/2021	1	Bottle Filler	In hallway adjacent to 104	WF-10122020-010975	4/1/2021	FT-FY21-032021-010975-A	<1	FT-FY21-032021-010975-B	<1
WS- 010976	10/12/2020	10/12/2021	1	Bottle Filler	Annex, in hallway adjacent to room 011	WF-10122020-010976	4/1/2021	FT-FY21-032021-010976-A	<1	FT-FY21-032021-010976-B	<1
WS- 010977	10/12/2020	10/12/2021	1	Bottle Filler	Annex, in hallway adjacent to room 12	WF-10122020-010977	4/1/2021	FT-FY21-032021-010977-A	<1	FT-FY21-032021-010977-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 008541	2/1/2021	2/1/2022	1	Food Prep Sink	In kitchen Left	WF-02012021-008541	4/1/2021	FT-FY21-032021-008541-A	<1	FT-FY21-032021-008541-B	<1