



# Dorothy Height ES Lead in Water Test Results

## FY26 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-001834	7/31/2025	7/31/2026	1	Bottle Filler	In student dining	WF-07312025-001834	2/12/2026	FT-FY26-01122026-001834-A	<2	FT-FY26-01122026-001834-B	<2
WS-001835	7/31/2025	7/31/2026	1	Cooler	In student dining High Left	WF-07312025-001835	2/12/2026	FT-FY26-01122026-001835-A	<2	FT-FY26-01122026-001835-B	<2
WS-001836	7/31/2025	7/31/2026	1	Cooler	In student dining Low Right	WF-07312025-001836	2/12/2026	FT-FY26-01122026-001836-A	<2	FT-FY26-01122026-001836-B	<2
WS-001837	7/31/2025	7/31/2026	1	Bottle Filler	In hallway across from 115	WF-07312025-001837	2/12/2026	FT-FY26-01122026-001837-A	<2	FT-FY26-01122026-001837-B	<2
WS-001838	7/31/2025	7/31/2026	1	Cooler	In hallway across from 115 High Left	WF-07312025-001838	2/12/2026	FT-FY26-01122026-001838-A	<2	FT-FY26-01122026-001838-B	<2
WS-001839	7/31/2025	7/31/2026	1	Cooler	In hallway across from 115 Low Right	WF-07312025-001839	2/12/2026	FT-FY26-01122026-001839-A	<2	FT-FY26-01122026-001839-B	<2
WS-001840	5/13/2025	5/13/2026	1	Bottle Filler	In gym	WF-05132025-001840	2/12/2026	FT-FY26-01122026-001840-A	<2	FT-FY26-01122026-001840-B	<2
WS-001841	5/13/2025	5/13/2026	1	Cooler	In gym High Left	WF-05132025-001841	2/12/2026	FT-FY26-01122026-001841-A	<2	FT-FY26-01122026-001841-B	<2
WS-001842	5/13/2025	5/13/2026	1	Cooler	In gym Low Right	WF-05132025-001842	2/12/2026	FT-FY26-01122026-001842-A	<2	FT-FY26-01122026-001842-B	<2
WS-001843	9/22/2025	9/22/2026	1	Combo Faucet	In classroom 115 Low Left	WF-09222025-001843	2/12/2026	FT-FY26-01122026-001843-A	2.7	FT-FY26-01122026-001843-B	4.8
WS-001844	5/13/2025	5/13/2026	1	Combo Fountain	In classroom 115 Low Left	WF-05132025-001844	2/12/2026	FT-FY26-01122026-001844-A	<2	FT-FY26-01122026-001844-B	<2
WS-001846	5/13/2025	5/13/2026	1	Combo Fountain	In classroom 115 High Right	WF-05132025-001846	2/12/2026	FT-FY26-01122026-001846-A	<2	FT-FY26-01122026-001846-B	<2
WS-001848	5/13/2025	5/13/2026	1	Combo Fountain	In classroom 116 High Left	WF-05132025-001848	2/12/2026	FT-FY26-01122026-001848-A	<2	FT-FY26-01122026-001848-B	<2
WS-001849	9/22/2025	9/22/2026	1	Combo Faucet	In classroom 116 Low Right	WF-09222025-001849	2/12/2026	FT-FY26-01122026-001849-A	<2	FT-FY26-01122026-001849-B	<2
WS-001850	5/13/2025	5/13/2026	1	Combo Fountain	In classroom 116 Low Right	WF-05132025-001850	2/12/2026	FT-FY26-01122026-001850-A	<2	FT-FY26-01122026-001850-B	<2
WS-001852	5/13/2025	5/13/2026	1	Combo Fountain	In room 109 OPT	WF-05132025-001852	2/12/2026	FT-FY26-01122026-001852-A	<2	FT-FY26-01122026-001852-B	<2
WS-001854	5/13/2025	5/13/2026	1	Combo Fountain	In room 111 speech	WF-05132025-001854	2/12/2026	FT-FY26-01122026-001854-A	<2	FT-FY26-01122026-001854-B	<2
WS-001855	5/13/2025	5/13/2026	1	Health Suite	In room 121D treatment	WF-05132025-001855	2/12/2026	FT-FY26-01122026-001855-A	<2	FT-FY26-01122026-001855-B	<2
WS-001856	5/13/2025	5/13/2026	1	Combo Fountain	In room 121D treatment	WF-05132025-001856	2/12/2026	FT-FY26-01122026-001856-A	<2	FT-FY26-01122026-001856-B	<2
WS-001858	5/13/2025	5/13/2026	1	Combo Fountain	In classroom 117 High Left	WF-05132025-001858	2/12/2026	FT-FY26-01122026-001858-A	<2	FT-FY26-01122026-001858-B	<2
WS-001859	9/22/2025	9/22/2026	1	Combo Faucet	In classroom 117 Low Right	WF-09222025-001859	2/12/2026	FT-FY26-01122026-001859-A	2.7	FT-FY26-01122026-001859-B	<2
WS-001860	5/13/2025	5/13/2026	1	Combo Fountain	In classroom 117 Low Right	WF-05132025-001860	2/12/2026	FT-FY26-01122026-001860-A	<2	FT-FY26-01122026-001860-B	<2
WS-001861	9/22/2025	9/22/2026	1	Combo Faucet	In classroom 118 Low Left	WF-09222025-001861	2/12/2026	FT-FY26-01122026-001861-A	<2	FT-FY26-01122026-001861-B	<2
WS-001862	5/13/2025	5/13/2026	1	Combo Fountain	In classroom 118 Low Left	WF-05132025-001862	2/12/2026	FT-FY26-01122026-001862-A	<2	FT-FY26-01122026-001862-B	<2
WS-001864	5/13/2025	5/13/2026	1	Combo Fountain	In classroom 118 High Right	WF-05132025-001864	2/12/2026	FT-FY26-01122026-001864-A	<2	FT-FY26-01122026-001864-B	<2
WS-001866	5/13/2025	5/13/2026	1	Combo Fountain	In classroom 120 Low Left	WF-05132025-001866	2/12/2026	FT-FY26-01122026-001866-A	<2	FT-FY26-01122026-001866-B	<2
WS-001868	5/13/2025	5/13/2026	1	Combo Fountain	In classroom 120 High Right	WF-05132025-001868	2/12/2026	FT-FY26-01122026-001868-A	<2	FT-FY26-01122026-001868-B	<2
WS-001870	5/13/2025	5/13/2026	2	Combo Fountain	In classroom 208	WF-05132025-001870	2/12/2026	FT-FY26-01122026-001870-A	<2	FT-FY26-01122026-001870-B	<2
WS-001872	5/13/2025	5/13/2026	2	Combo Fountain	In classroom 209	WF-05132025-001872	2/12/2026	FT-FY26-01122026-001872-A	<2	FT-FY26-01122026-001872-B	<2
WS-001874	5/13/2025	5/13/2026	2	Combo Fountain	In classroom 203	WF-05132025-001874	2/12/2026	FT-FY26-01122026-001874-A	<2	FT-FY26-01122026-001874-B	<2
WS-001875	8/21/2025	8/21/2026	2	Bottle Filler	In hallway adjacent to 203	WF-08212025-001875	2/12/2026	FT-FY26-01122026-001875-A	<2	FT-FY26-01122026-001875-B	<2
WS-001876	8/21/2025	8/21/2026	2	Cooler	In hallway adjacent to 203 High Left	WF-08212025-001876	2/12/2026	FT-FY26-01122026-001876-A	<2	FT-FY26-01122026-001876-B	<2
WS-001877	8/21/2025	8/21/2026	2	Cooler	In hallway adjacent to 203 Low Right	WF-08212025-001877	2/12/2026	FT-FY26-01122026-001877-A	<2	FT-FY26-01122026-001877-B	<2
WS-001879	5/13/2025	5/13/2026	2	Combo Fountain	In classroom 211	WF-05132025-001879	2/12/2026	FT-FY26-01122026-001879-A	<2	FT-FY26-01122026-001879-B	<2

WS-001881	5/13/2025	5/13/2026	2	Combo Fountain	In classroom 213		WF-05132025-001881	2/12/2026	FT-FY26-01122026-001881-A	<2	FT-FY26-01122026-001881-B	<2
WS-001883	5/13/2025	5/13/2026	2	Combo Fountain	In classroom 214		WF-05132025-001883	2/12/2026	FT-FY26-01122026-001883-A	<2	FT-FY26-01122026-001883-B	<2
WS-001885	5/13/2025	5/13/2026	2	Combo Fountain	In classroom 215		WF-05132025-001885	2/12/2026	FT-FY26-01122026-001885-A	<2	FT-FY26-01122026-001885-B	<2
WS-001887	5/13/2025	5/13/2026	2	Combo Fountain	In classroom 202		WF-05132025-001887	2/12/2026	FT-FY26-01122026-001887-A	<2	FT-FY26-01122026-001887-B	<2
WS-001889	5/13/2025	5/13/2026	2	Combo Fountain	In classroom 232		WF-05132025-001889	2/12/2026	FT-FY26-01122026-001889-A	<2	FT-FY26-01122026-001889-B	<2
WS-001891	5/13/2025	5/13/2026	2	Combo Fountain	In teacher collaboration 233		WF-05132025-001891	2/12/2026	FT-FY26-01122026-001891-A	<2	FT-FY26-01122026-001891-B	<2
WS-001893	5/13/2025	5/13/2026	2	Combo Fountain	In art lab 234	High Left	WF-05132025-001893	2/12/2026	FT-FY26-01122026-001893-A	<2	FT-FY26-01122026-001893-B	<2
WS-001895	5/13/2025	5/13/2026	2	Combo Fountain	In art lab 234	Low Right	WF-05132025-001895	2/12/2026	FT-FY26-01122026-001895-A	<2	FT-FY26-01122026-001895-B	<2
WS-001897	5/13/2025	5/13/2026	2	Combo Fountain	In teacher collaboration 237		WF-05132025-001897	2/12/2026	FT-FY26-01122026-001897-A	<2	FT-FY26-01122026-001897-B	<2
WS-001952	5/13/2025	5/13/2026	2	Combo Fountain	In classroom 239		WF-05132025-001952	2/12/2026	FT-FY26-01122026-001952-A	<2	FT-FY26-01122026-001952-B	<2
WS-001954	5/13/2025	5/13/2026	3	Combo Fountain	In classroom 310		WF-05132025-001954	2/12/2026	FT-FY26-01122026-001954-A	<2	FT-FY26-01122026-001954-B	<2
WS-001956	5/13/2025	5/13/2026	3	Combo Fountain	In classroom 311		WF-05132025-001956	2/12/2026	FT-FY26-01122026-001956-A	<2	FT-FY26-01122026-001956-B	<2
WS-001958	5/13/2025	5/13/2026	3	Combo Fountain	In classroom 305		WF-05132025-001958	2/12/2026	FT-FY26-01122026-001958-A	<2	FT-FY26-01122026-001958-B	<2
WS-001959	5/13/2025	5/13/2026	3	Bottle Filler	In hallway adjacent to M301		WF-05132025-001959	2/12/2026	FT-FY26-01122026-001959-A	<2	FT-FY26-01122026-001959-B	<2
WS-001971	5/13/2025	5/13/2026	3	Cooler	In hallway adjacent to M301		WF-05132025-001971	2/12/2026	FT-FY26-01122026-001971-A	<2	FT-FY26-01122026-001971-B	<2
WS-001973	5/13/2025	5/13/2026	3	Combo Fountain	In classroom 312		WF-05132025-001973	2/12/2026	FT-FY26-01122026-001973-A	<2	FT-FY26-01122026-001973-B	<2
WS-001975	5/13/2025	5/13/2026	3	Combo Fountain	In classroom 313		WF-05132025-001975	2/12/2026	FT-FY26-01122026-001975-A	<2	FT-FY26-01122026-001975-B	<2
WS-001977	5/13/2025	5/13/2026	3	Combo Fountain	In classroom 314		WF-05132025-001977	2/12/2026	FT-FY26-01122026-001977-A	<2	FT-FY26-01122026-001977-B	<2
WS-001979	5/13/2025	5/13/2026	3	Combo Fountain	In classroom 315		WF-05132025-001979	2/12/2026	FT-FY26-01122026-001979-A	<2	FT-FY26-01122026-001979-B	<2
WS-001981	5/13/2025	5/13/2026	3	Combo Fountain	In classroom 304		WF-05132025-001981	2/12/2026	FT-FY26-01122026-001981-A	<2	FT-FY26-01122026-001981-B	<2
WS-001986	5/13/2025	5/13/2026	Basement	Combo Fountain	In specials L13	Left	WF-05132025-001986	2/12/2026	FT-FY26-01122026-001986-A	<2	FT-FY26-01122026-001986-B	<2
WS-001988	5/13/2025	5/13/2026	Basement	Combo Fountain	In specials L13	Mid	WF-05132025-001988	2/12/2026	FT-FY26-01122026-001988-A	<2	FT-FY26-01122026-001988-B	<2
WS-001995	5/13/2025	5/13/2026	Basement	Bottle Filler	In hallway opposite restroom		WF-05132025-001995	2/12/2026	FT-FY26-01122026-001995-A	<2	FT-FY26-01122026-001995-B	<2
WS-001996	5/13/2025	5/13/2026	Basement	Cooler	In hallway opposite restroom		WF-05132025-001996	2/12/2026	FT-FY26-01122026-001996-A	<2	FT-FY26-01122026-001996-B	<2
WS-001997	5/13/2025	5/13/2026	Basement	Bottle Filler	In Library		WF-05132025-001997	2/12/2026	FT-FY26-01122026-001997-A	<2	FT-FY26-01122026-001997-B	<2
WS-001998	5/13/2025	5/13/2026	Basement	Cooler	In Library		WF-05132025-001998	2/12/2026	FT-FY26-01122026-001998-A	<2	FT-FY26-01122026-001998-B	<2
WS-001999	5/13/2025	5/13/2026	Basement	Bottle Filler	In music room L10		WF-05132025-001999	2/12/2026	FT-FY26-01122026-001999-A	<2	FT-FY26-01122026-001999-B	<2
WS-002000	5/13/2025	5/13/2026	Basement	Cooler	In music room L10		WF-05132025-002000	2/12/2026	FT-FY26-01122026-002000-A	<2	FT-FY26-01122026-002000-B	<2
WS-002002	5/13/2025	5/13/2026	1	Combo Fountain	In classroom 171	High Left	WF-05132025-002002	2/12/2026	FT-FY26-01122026-002002-A	<2	FT-FY26-01122026-002002-B	<2
WS-002003	9/22/2025	9/22/2026	1	Combo Faucet	In classroom 171	Low Right	WF-09222025-002003	2/12/2026	FT-FY26-01122026-002003-A	<2	FT-FY26-01122026-002003-B	<2
WS-002004	5/13/2025	5/13/2026	1	Combo Fountain	In classroom 171	Low Right	WF-05132025-002004	2/12/2026	FT-FY26-01122026-002004-A	<2	FT-FY26-01122026-002004-B	<2
WS-002006	5/13/2025	5/13/2026	1	Combo Fountain	In classroom 168	High Left	WF-05132025-002006	2/12/2026	FT-FY26-01122026-002006-A	<2	FT-FY26-01122026-002006-B	<2
WS-002007	9/22/2025	9/22/2026	1	Combo Faucet	In classroom 168	Low Right	WF-09222025-002007	2/12/2026	FT-FY26-01122026-002007-A	<2	FT-FY26-01122026-002007-B	<2
WS-002008	5/13/2025	5/13/2026	1	Combo Fountain	In classroom 168	Low Right	WF-05132025-002008	2/12/2026	FT-FY26-01122026-002008-A	<2	FT-FY26-01122026-002008-B	<2
WS-002010	5/13/2025	5/13/2026	1	Combo Fountain	In classroom 165	High Left	WF-05132025-002010	2/12/2026	FT-FY26-01122026-002010-A	<2	FT-FY26-01122026-002010-B	<2
WS-002011	9/22/2025	9/22/2026	1	Combo Faucet	In classroom 165	Low Right	WF-09222025-002011	2/12/2026	FT-FY26-01122026-002011-A	<2	FT-FY26-01122026-002011-B	<2
WS-002012	5/13/2025	5/13/2026	1	Combo Fountain	In classroom 165	Low Right	WF-05132025-002012	2/12/2026	FT-FY26-01122026-002012-A	<2	FT-FY26-01122026-002012-B	<2
WS-002014	5/13/2025	5/13/2026	1	Combo Fountain	In room 162		WF-05132025-002014	2/12/2026	FT-FY26-01122026-002014-A	<2	FT-FY26-01122026-002014-B	<2
WS-002016	5/13/2025	5/13/2026	1	Combo Fountain	In classroom 157	High Left	WF-05132025-002016	2/12/2026	FT-FY26-01122026-002016-A	<2	FT-FY26-01122026-002016-B	<2
WS-002017	9/22/2025	9/22/2026	1	Combo Faucet	In classroom 157	Low Right	WF-09222025-002017	2/12/2026	FT-FY26-01122026-002017-A	3.0	FT-FY26-01122026-002017-B	<2
WS-002018	5/13/2025	5/13/2026	1	Combo Fountain	In classroom 157	Low Right	WF-05132025-002018	2/12/2026	FT-FY26-01122026-002018-A	<2	FT-FY26-01122026-002018-B	<2

WS- 002021	9/22/2025	9/22/2026	1	Combo Faucet	In classroom 159	Low Right	WF-09222025-002021	2/12/2026	FT-FY26-01122026-002021-A	<2	FT-FY26-01122026-002021-B	<2
WS- 002048	8/21/2025	8/21/2026	1	Cooler	In hallway across from Parent Resource room 155	High Left	WF-08212025-002048	2/12/2026	FT-FY26-01122026-002048-A	<2	FT-FY26-01122026-002048-B	<2
WS- 002159	8/21/2025	8/21/2026	1	Cooler	In hallway across from Parent Resource room 155	Low Right	WF-08212025-002159	2/12/2026	FT-FY26-01122026-002159-A	<2	FT-FY26-01122026-002159-B	<2
WS- 002160	8/21/2025	8/21/2026	1	Bottle Filler	In hallway across from Parent Resource room 155		WF-08212025-002160	2/12/2026	FT-FY26-01122026-002160-A	<2	FT-FY26-01122026-002160-B	<2
WS- 005746	8/21/2025	8/21/2026	1	Cooler	In Staff Lounge 156		WF-08212025-005746	2/12/2026	FT-FY26-01122026-005746-A	<2	FT-FY26-01122026-005746-B	<2
WS- 005747	8/21/2025	8/21/2026	1	Bottle Filler	In Staff Lounge 156		WF-08212025-005747	2/12/2026	FT-FY26-01122026-005747-A	<2	FT-FY26-01122026-005747-B	<2

### Food Prep Sink

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 001982	12/15/2025	12/15/2026	Ground Floor	Food Prep Sink	In kitchen	WF-12152025-001982	2/12/2026	FT-FY26-01122026-001982-A	<2	FT-FY26-01122026-001982-B	<2

### FY26 Filter Test

Greater than 5ppb - Devices requiring remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS- 001865	9/22/2025	9/22/2026	1	Combo Faucet	In classroom 120	Low Left	WF-09222025-001865	2/12/2026	FT-FY26-01122026-001865-A	6.7	FT-FY26-01122026-001865-B	<2

Due to changes in water sampling analysis equipment at the laboratory from previous years, the level of detection (LOD) for lead in drinking water is now <2ppb.