



Dorothy Height ES Lead Water Test Results



FY19 Filter Test

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS-008545	5/14/2018	5/14/2019	1	Cooler	In hallway adjacent to 104 High Left	WF-05142018-008545	11/11/2018	FT-FY19-112018-008545-A	< 1	FT-FY19-112018-008545-B	< 1	
WS-008546	5/14/2018	5/14/2019	1	Cooler	In hallway adjacent to 104 Low Right	WF-05142018-008546	11/11/2018	FT-FY19-112018-008546-A	< 1	FT-FY19-112018-008546-B	< 1	
WS-008548	5/14/2018	5/14/2019	1	Health Suite	In health suite 116 in restroom	WF-05142018-008548	11/11/2018	FT-FY19-112018-008548-A	< 1	FT-FY19-112018-008548-B	< 1	
WS-008549	5/14/2018	5/14/2019	2	Cooler	In hallway adjacent to room 212 High Left	WF-05142018-008549	11/11/2018	FT-FY19-112018-008549-A	< 1	FT-FY19-112018-008549-B	< 1	
WS-008550	5/14/2018	5/14/2019	2	Cooler	In hallway adjacent to room 212 Low Right	WF-05142018-008550	11/11/2018	FT-FY19-112018-008550-A	< 1	FT-FY19-112018-008550-B	< 1	
WS-008553	5/14/2018	5/14/2019	3	Cooler	In hallway adjacent to room 310 High Left	WF-05142018-008553	11/11/2018	FT-FY19-112018-008553-A	< 1	FT-FY19-112018-008553-B	< 1	
WS-008554	5/14/2018	5/14/2019	3	Cooler	In hallway adjacent to room 310 Low Right	WF-05142018-008554	11/11/2018	FT-FY19-112018-008554-A	< 1	FT-FY19-112018-008554-B	< 1	
WS-008555	10/2/2018	10/2/2019	1	Classroom Faucet	Annex, in classroom 013	WF-10022018-008555	11/11/2018	FT-FY19-112018-008555-A	< 1	FT-FY19-112018-008555-B	< 1	
WS-008556	10/2/2018	10/2/2019	1	Classroom Faucet	Annex, in classroom 015	WF-10022018-008556	11/11/2018	FT-FY19-112018-008556-A	< 1	FT-FY19-112018-008556-B	< 1	
WS-008557	10/2/2018	10/2/2019	1	Classroom Faucet	Annex, in classroom 017	WF-10022018-008557	11/11/2018	FT-FY19-112018-008557-A	< 1	FT-FY19-112018-008557-B	< 1	
WS-008558	5/14/2018	5/14/2019	1	Break Room	Annex, in staff lounge 009	WF-05142018-008558	11/11/2018	FT-FY19-112018-008558-A	< 1	FT-FY19-112018-008558-B	< 1	
WS-008559	5/14/2018	5/14/2019	1	Cooler	Annex, in hallway adjacent to room 012	WF-05142018-008559	11/11/2018	FT-FY19-112018-008559-A	< 1	FT-FY19-112018-008559-B	< 1	
WS-008560	10/2/2018	10/2/2019	1	Classroom Faucet	Annex, in classroom 016	WF-10022018-008560	11/11/2018	FT-FY19-112018-008560-A	< 1	FT-FY19-112018-008560-B	< 1	
WS-008561	10/2/2018	10/2/2019	1	Classroom Faucet	Annex, in classroom 014	WF-10022018-008561	11/11/2018	FT-FY19-112018-008561-A	< 1	FT-FY19-112018-008561-B	< 1	
WS-008590	10/2/2018	10/2/2019	1	Classroom Faucet	Annex, in classroom 007 west wall	WF-10022018-008590	11/11/2018	FT-FY19-112018-008590-A	< 1	FT-FY19-112018-008590-B	< 1	
WS-008591	5/14/2018	5/14/2019	1	Cooler	Annex, in classroom 007	WF-05142018-008591	11/11/2018	FT-FY19-112018-008591-A	< 1	FT-FY19-112018-008591-B	< 1	
WS-008592	10/2/2018	10/2/2019	1	Classroom Faucet	Annex, in classroom 012	WF-10022018-008592	11/11/2018	FT-FY19-112018-008592-A	< 1	FT-FY19-112018-008592-B	< 1	
WS-008700	5/14/2018	5/14/2019	1	Cooler	Annex, in hallway adjacent to girl's restroom	WF-05142018-008700	11/11/2018	FT-FY19-112018-008700-A	< 1	FT-FY19-112018-008700-B	< 1	
WS-010543	10/2/2018	10/2/2019	1	Classroom Faucet	Annex, in classroom 006	WF-10022018-010543	11/11/2018	FT-FY19-112018-010543-A	< 1	FT-FY19-112018-010543-B	< 1	

Food Prep Sink

Less than 5ppb - Devices requiring no remediation									
Record ID	Floor	Device Type	Device Location	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS-008541	1	Food Prep Sink	In kitchen Left	11/11/2018	FT-FY19-112018-008541-A	< 1	FT-FY19-112018-008541-B	< 1	
WS-008542	1	Food Prep Sink	In kitchen Mid	11/11/2018	FT-FY19-112018-008542-A	< 1	FT-FY19-112018-008542-B	< 1	