

Douglass CC and Pool Lead Water Test Results



Food Prep Sink

	Greater than 5ppb - Devices requiring remediation											
Record ID	Filter	Filter				Water Filter's Name	Date	1st Draw - Sample ID	FT Final		FT Final	
	Installed	Expiration	Floor	Device Type	Device Location				Result - 1st	2nd Draw - Sample ID	Result - 2nd	
	Date	Date					Analyzed		Draw (ppb)		Draw (ppb)	
WS- 011563	4/11/2018	4/11/2019	1	Food Prep Sink	In kitchen Left	WF-04112018-011563	3/19/2019	FT-FY19-032019-011563-A	9.8	FT-FY19-032019-011563-B	5.6	

First Re-test (After Plumbing Check)

Food Prep Sink

	Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed	Filter Expiration	Floor	Device Type	Device Location		Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st	2nd Draw - Sample ID	FT Final Result - 2nd
	Date	Date						Anaryzea		Draw (ppb)		Draw (ppb)
WS- 011563	3/21/2019	3/21/2020	1	Food Prep Sink	In kitchen	Left	WF-04112018-011563	3/28/2019	FT-FY19-032019-011563-A	<1	FT-FY19-032019-011563-B	<1