



# Drew ES Lead in Water Test Results

## FY26 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 004590	2/19/2025	2/19/2026	1	Bottle Filler	In hallway across from health suite	WF-02192025-004590	1/8/2026	FT-FY26-12302025-004590-A	<2	FT-FY26-12302025-004590-B	<2
WS- 004592	2/19/2025	2/19/2026	1	Cooler	In auditorium High Left	WF-02192025-004592	1/8/2026	FT-FY26-12302025-004592-A	<2	FT-FY26-12302025-004592-B	<2
WS- 004593	2/19/2025	2/19/2026	1	Cooler	In auditorium Low Right	WF-02192025-004593	1/8/2026	FT-FY26-12302025-004593-A	<2	FT-FY26-12302025-004593-B	<2
WS- 004595	2/19/2025	2/19/2026	1	Cooler	In hallway across from health suite High Left	WF-02192025-004595	1/8/2026	FT-FY26-12302025-004595-A	<2	FT-FY26-12302025-004595-B	<2
WS- 004596	2/19/2025	2/19/2026	1	Cooler	In hallway across from health suite Low Right	WF-02192025-004596	1/8/2026	FT-FY26-12302025-004596-A	<2	FT-FY26-12302025-004596-B	<2
WS- 004599	8/12/2025	8/12/2026	1	Combo Faucet	In classroom 104	WF-08122025-004599	1/8/2026	FT-FY26-12302025-004599-A	<2	FT-FY26-12302025-004599-B	<2
WS- 004600	2/19/2025	2/19/2026	1	Combo Fountain	In classroom 104	WF-02192025-004600	1/8/2026	FT-FY26-12302025-004600-A	3.1	FT-FY26-12302025-004600-B	<2
WS- 004602	8/12/2025	8/12/2026	1	Combo Faucet	In classroom 108 High Left	WF-08122025-004602	1/8/2026	FT-FY26-12302025-004602-A	<2	FT-FY26-12302025-004602-B	<2
WS- 004603	2/19/2025	2/19/2026	1	Combo Fountain	In classroom 108 Low Right	WF-02192025-004603	1/8/2026	FT-FY26-12302025-004603-A	<2	FT-FY26-12302025-004603-B	<2
WS- 004604	8/12/2025	8/12/2026	1	Combo Faucet	In classroom 105	WF-08122025-004604	1/8/2026	FT-FY26-12302025-004604-A	<2	FT-FY26-12302025-004604-B	<2
WS- 004605	2/19/2025	2/19/2026	1	Combo Fountain	In classroom 105	WF-02192025-004605	1/8/2026	FT-FY26-12302025-004605-A	<2	FT-FY26-12302025-004605-B	<2
WS- 004606	2/19/2025	2/19/2026	1	Cooler	In hallway adjacent to room 107 High Left	WF-02192025-004606	1/8/2026	FT-FY26-12302025-004606-A	<2	FT-FY26-12302025-004606-B	<2
WS- 004607	2/19/2025	2/19/2026	1	Cooler	In hallway adjacent to room 107 Low Right	WF-02192025-004607	1/8/2026	FT-FY26-12302025-004607-A	<2	FT-FY26-12302025-004607-B	<2
WS- 004608	8/12/2025	8/12/2026	1	Combo Faucet	In classroom 107 High Left	WF-08122025-004608	1/8/2026	FT-FY26-12302025-004608-A	<2	FT-FY26-12302025-004608-B	<2
WS- 004609	2/19/2025	2/19/2026	1	Combo Fountain	In classroom 107 Low Right	WF-02192025-004609	1/8/2026	FT-FY26-12302025-004609-A	<2	FT-FY26-12302025-004609-B	<2
WS- 004610	8/12/2025	8/12/2026	1	Combo Faucet	In classroom 106	WF-08122025-004610	1/8/2026	FT-FY26-12302025-004610-A	<2	FT-FY26-12302025-004610-B	<2
WS- 004611	2/19/2025	2/19/2026	1	Combo Fountain	In classroom 106	WF-02192025-004611	1/8/2026	FT-FY26-12302025-004611-A	<2	FT-FY26-12302025-004611-B	<2
WS- 004612	8/12/2025	8/12/2026	2	Combo Faucet	In classroom 205 High Left	WF-08122025-004612	1/8/2026	FT-FY26-12302025-004612-A	<2	FT-FY26-12302025-004612-B	<2
WS- 004613	2/19/2025	2/19/2026	2	Combo Fountain	In classroom 205 Low Right	WF-02192025-004613	1/8/2026	FT-FY26-12302025-004613-A	4.3	FT-FY26-12302025-004613-B	<2
WS- 004614	8/12/2025	8/12/2026	2	Combo Faucet	In classroom 207 High Left	WF-08122025-004614	1/8/2026	FT-FY26-12302025-004614-A	4.5	FT-FY26-12302025-004614-B	<2
WS- 004615	2/19/2025	2/19/2026	2	Combo Fountain	In classroom 207 Low Right	WF-02192025-004615	1/8/2026	FT-FY26-12302025-004615-A	<2	FT-FY26-12302025-004615-B	<2
WS- 004616	2/19/2025	2/19/2026	2	Cooler	In hallway adjacent to room 207 High Left	WF-02192025-004616	1/8/2026	FT-FY26-12302025-004616-A	<2	FT-FY26-12302025-004616-B	<2
WS- 004617	2/19/2025	2/19/2026	2	Cooler	In hallway adjacent to room 207 Low Right	WF-02192025-004617	1/8/2026	FT-FY26-12302025-004617-A	<2	FT-FY26-12302025-004617-B	<2
WS- 004622	8/12/2025	8/12/2026	2	Combo Faucet	In classroom 200 Left	WF-08122025-004622	1/8/2026	FT-FY26-12302025-004622-A	<2	FT-FY26-12302025-004622-B	<2
WS- 004623	2/19/2025	2/19/2026	2	Combo Fountain	In classroom 200 Right	WF-02192025-004623	1/8/2026	FT-FY26-12302025-004623-A	<2	FT-FY26-12302025-004623-B	<2
WS- 004624	2/19/2025	2/19/2026	2	Cooler	In hallway adjacent to room 212 High Left	WF-02192025-004624	1/8/2026	FT-FY26-12302025-004624-A	<2	FT-FY26-12302025-004624-B	<2
WS- 004625	2/19/2025	2/19/2026	2	Cooler	In hallway adjacent to room 212 Low Right	WF-02192025-004625	1/8/2026	FT-FY26-12302025-004625-A	<2	FT-FY26-12302025-004625-B	<2
WS- 004626	2/19/2025	2/19/2026	2	Break Room	In staff lounge 213	WF-02192025-004626	1/8/2026	FT-FY26-12302025-004626-A	<2	FT-FY26-12302025-004626-B	<2
WS- 004627	2/19/2025	2/19/2026	2	Cooler	In staff lounge 213	WF-02192025-004627	1/8/2026	FT-FY26-12302025-004627-A	<2	FT-FY26-12302025-004627-B	<2
WS- 004629	8/12/2025	8/12/2026	3	Combo Faucet	In classroom 312	WF-08122025-004629	1/8/2026	FT-FY26-12302025-004629-A	<2	FT-FY26-12302025-004629-B	<2
WS- 004631	2/19/2025	2/19/2026	3	Cooler	In hallway adjacent to room 300 High Left	WF-02192025-004631	1/8/2026	FT-FY26-12302025-004631-A	<2	FT-FY26-12302025-004631-B	<2
WS- 004632	2/19/2025	2/19/2026	3	Cooler	In hallway adjacent to room 300 Low Right	WF-02192025-004632	1/8/2026	FT-FY26-12302025-004632-A	<2	FT-FY26-12302025-004632-B	<2
WS- 004641	2/19/2025	2/19/2026	4	Break Room	In staff lounge	WF-02192025-004641	1/8/2026	FT-FY26-12302025-004641-A	<2	FT-FY26-12302025-004641-B	<2
WS- 004642	2/19/2025	2/19/2026	4	Cooler	In hallway adjacent to arts studio High Left	WF-02192025-004642	1/8/2026	FT-FY26-12302025-004642-A	<2	FT-FY26-12302025-004642-B	<2

WS- 004643	2/19/2025	2/19/2026	4	Cooler	In hallway adjacent to arts studio	Low Right	WF-02192025-004643	1/8/2026	FT-FY26-12302025-004643-A	<2	FT-FY26-12302025-004643-B	<2
WS- 004645	2/19/2025	2/19/2026	4	Cooler	In hallway adjacent to room 407	Low Right	WF-02192025-004645	1/8/2026	FT-FY26-12302025-004645-A	<2	FT-FY26-12302025-004645-B	<2
WS- 004649	2/19/2025	2/19/2026	4	Bottle Filler	In hallway adjacent to arts studio		WF-02192025-004649	1/8/2026	FT-FY26-12302025-004649-A	<2	FT-FY26-12302025-004649-B	<2
WS- 009118	8/12/2025	8/12/2026	2	Combo Faucet	In classroom 212		WF-08122025-009118	1/8/2026	FT-FY26-12302025-009118-A	2.1	FT-FY26-12302025-009118-B	<2
WS- 009119	2/19/2025	2/19/2026	2	Combo Fountain	In classroom 212		WF-02192025-009119	1/8/2026	FT-FY26-12302025-009119-A	<2	FT-FY26-12302025-009119-B	<2

### Food Prep Sink

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 004601	12/2/2025	12/2/2026	1	Food Prep Sink	In kitchen	WF-12022025-004601	1/8/2026	FT-FY26-12302025-004601-A	<2	FT-FY26-12302025-004601-B	<2

Due to changes in water sampling analysis equipment at the laboratory from previous years, the level of detection (LOD) for lead in drinking water is now <2ppb.